

TECHNO-ECONOMIC ANALYSIS OF DECENTRALISED STPS (DEWATS) FOR PERIPHERAL AREA IN CHENNAI

A DISSERTATION

*Submitted in partial fulfillment of the
requirements for the award of the degree*

of



MASTER OF TECHNOLOGY

in

CONSERVATION OF RIVERS AND LAKES

By

K.BALASUBRAMANIAN



ALTERNATE HYDRO ENERGY CENTRE
INDIAN INSTITUTE OF TECHNOLOGY ROORKEE
ROORKEE - 247 667 (INDIA)

JUNE, 2008

CANDIDATE'S DECLARATION

I hereby declare that the work which has been presented in the dissertation entitled **“TECHNO-ECONOMIC ANALYSIS OF DECENTRALISED STPS (DEWATS) FOR PERIPHERAL AREA IN CHENNAI”** in partial fulfillment of the requirements for the award of the degree of **Master of Technology in Conservation of Rivers and Lakes**, submitted in Alternate Hydro Energy Centre, Indian Institute of Technology, Roorkee, is an authentic record of my own work carried out during the period from July 2006 to June 2008 under the supervision of Dr. M.P. Sharma, Senior Scientific Officer, AHEC and Shri M.K. Singhal, Senior Scientific Officer, AHEC, Indian Institute of Technology Roorkee.

The matter embodied in the dissertation has not been submitted by me for the award of any other degree or diploma.

Date: June 27th, 2008



(K.BALASUBRAMANIAN)

Place: Roorkee

CERTIFICATE

This is to certify that the above statement made by the candidate is correct to the best of my knowledge.

(Dr. M.P. Sharma)
Senior Scientific Officer,
Alternate Hydro Energy Centre,
Indian Institute of Technology Roorkee
Roorkee, (Uttarakhand)


(M. K. Singhal) 30/6/08
Senior Scientific officer,
Alternate Hydro Energy Centre,
Indian Institute of Technology,
Roorkee, (Uttarakhand)

ACKNOWLEDGEMENT

First of all I pray the almighty for giving me, 'hale and healthiness' both mentally and physically and interest in continuous study. Secondly the **NRCD, IIT Roorkee** for making the CRL programme M.Tech course and feeding current knowledge on Conservation of Rivers and Lakes to the sponsoring staff.

From my deep depth of my heart sincere thanks and gratitude to my Guides **Dr.M.P.Sharma**, Senior Scientific Officer, Alternate Hydro Energy Centre and **Shri.M.K. Singal**, Senior Scientific Officer, Alternate Hydro Energy Centre, I.I.T.Roorkee for their inspiration and continuous motivation on guiding me in successful completion of my Dissertation.

I also express my deep gratitude to **Shri. Arun Kumar**, Head, Alternative Hydro Energy Centre, IIT,Roorkee, **Dr.R.P.Saini**, Senior Scientific officer and Course Coordinator, AHEC, IIT Roorkee

I specially thank **Managing Director, Engineer Director of CMWSS Board** for their Support and approval for this programme.

I also express my sincere thanks to **Thiru M.Thirunavukkarasu, Thiru G.Senbahanandam Retired S.Es of CMWSSB** for their sincere efforts in motivating me to complete the Dissertation in time.

I also express my thanks to **Thiru Kirupanithi Retd C.E., CMWSSB Thiru Perumal Retd, Engineer TWAD Board, Thiru Kathir, Thiru Immanuvel, Thiru Madaswamy of M/s SPT Consultancy** for their help in preparing the drawings and charts.

My special thanks to **my wife, children, brother and all my friends** for their motivation in my study.

It would not be fair if I do not thanks to my dear **Rudra Rameswar**, Ph.d. Scholar, Management Studies, IIT Roorkee for his continuous motivation in completion of the dissertation.

Date: 27th June 2008

K.Balasubramanian
(K.Balasubramanian)

ABSTRACT

Health is Wealth. Good public Health makes the earth, "Hale & Healthy". Poor public Health makes "Pale & Sick". Sustainable health, especially for children and age old person is not possible without safe and hygienic environmental sanitation. But these, good health issues are hindered by the problems of burgeoning population and sinking resources on one side and the LPG policies (Liberalization, Privataization and Globalization) and Industrialization on the other side. Once worshiped, purified form of running water bodies now becomes putrefied due to free disposal of human wastes and no minimum environmental flow. But Developments and Destructions are both sides of coin in the Universe Hence it is the duty of Environmental Engineers, to adopt the opt Technology for treating the wastewater, harmonizing with BAT(Best available Technology) and LCT(Least Cost Technology) that is appropriate for the adjacent area to Chennai Metropolitan City and there by attaining the goal of ' Sanitation for all'.The adjacent area to Chennai City, Ward No-45 of Ambattur Municipality is selected since and water supply is provided from Chennai Metropolitan Water Supply and Sewerage Board where as the area has not been provided with sewerage system.. Since the area has been developed to its capacity and the area is low lying and is not ease with economic cost to include the area into the Chennai City Sewerage net work. Hence the only solution to go for DEWATs Technology (Decentralized Wastewater Treatments) for upkeeping the area for hygienic at economic cost with sustainability. Hence detail studies has been made on DEWATs technology available internationally and opt technology, locally suitable has been elected from the selected DEWATs namely WSP(Waste Stabilization Ponds),ISF(Intermittent Sand Filtration) and the Modern Technology,SBR(Sequencing Batch Reactor).By designing and estimating these traditional DEWATs, and analyzing their Performances' both Technically and Economically among them also comparing the DEWATS with the Centralized Technology, MASP (Modified Activated Sludge process)..The benefits of smaller dia pipes, reaping the benefit of 3Rs (Reduce, Reuse & Recycle) here, selling the treated effluent to near by Industries, since Ambattur is famous for its Industrial Area, where water scarcity is prevailing. From the analysis of data on selected DEWATs technologies said above, sound decision of 'adoption of SBR Technology' to treat the ward No-45 of Ambattur Municipality located adjacent to Chennai City, has been taken.

CONTENTS

| Chapter | Title | Page No |
|----------------|---|----------------|
| | CANDIDATURE DECLARATION | i |
| | ACKNOWLEDGEMENT | ii |
| | ABSTRACT | iii |
| | CONTENTS | iv |
| | LIST OF FIGURES | ix |
| | LIST OF TABLES | x |
| 1 | INTRODUCTION | 1 |
| 1.1 | Preamble | 1 |
| 1.2 | Rational Behind the Study | 2 |
| 1.3 | Objective of the study | 3 |
| 1.4 | Study Area | 4 |
| 1.5 | Methodology adopted | 5 |
| 1.6 | Technology considered | 6 |
| 1.7 | Economics of Treatment Technologies | 6 |
| 1.8 | Awareness Creation | 7 |
| 1.9 | Public, Private, Participation (PPP) | 8 |
| 2 | LITERATURE REVIEW | 10 |
| 2.1 | History of Onsite Wastewater Treatment Systems | 10 |
| 2.2 | Background and Use of Onsite Wastewater Treatment Systems | 10 |
| 2.3 | The Conventional Wastewater Management Approach | 11 |
| 2.4 | Sewage Composition | 12 |
| 2.5 | The Conventional Treatment Method Includes | 13 |
| 2.5.1 | Bar Racks & Screens | 13 |
| 2.5.2 | Grit Chamber | 14 |
| 2.5.3 | Sedimentation | 14 |

| | | |
|---------|--|----|
| 2.6 | Biological or Secondary Treatment | 15 |
| 2.6.1 | Aerobic Processes | 15 |
| 2.6.2 | Anaerobic Processes | 15 |
| 2.6.3 | Aerobic & Anaerobic In Tandem | 15 |
| 2.6.4 | Pond Systems | 15 |
| 2.6.5 | Natural Treatment Systems | 16 |
| 2.7 | Tertiary Or Advanced Treatment | 16 |
| 2.7.1 | Advanced Treatment Systems | 16 |
| 2.8 | The Conventional Wastewater Treatment System at Chennai in Tamilnadu | 17 |
| 2.9 | Science and Technology | 20 |
| 2.9.1 | Decentralised Approach | 20 |
| 2.9.2 | Conventional Onsite Wastewater Treatment System | 21 |
| 2.9.3 | About Dewats | 21 |
| 2.9.4 | Four Basic Technical Treatment Modules According To Demand For Dewats Applications | 22 |
| 2.9.5 | Dewats Applications | 23 |
| 2.9.6 | Demand of Dewats System | 23 |
| 2.9.7 | Dewats-Modules for Physical and Biological Wastewater Treatment | 23 |
| 2.9.8 | Advantages of Dewats Technology | 24 |
| 2.9.9 | Dewats Technology Principles | 24 |
| 2.9.9.1 | Biogas Digester | 24 |
| 2.9.9.2 | Basic Septic Tank | 25 |
| 2.9.9.3 | Baffled Up-Flow Reactor | 25 |
| 2.9.9.4 | Anaerobic Filter Reactor | 26 |
| 2.9.9.5 | Horizontal Sand Filter | 26 |
| 2.9.9.6 | Improving Treatment Through Performance Requirements | 27 |
| 2.9.9.7 | Most Of The Alternative Treatment Technologies Applied Today Treat Wastes After They Exit The Septic Tank | 28 |
| 2.9.9.8 | Towards More Comprehensive Approach | 28 |

| | | |
|---------|--|----|
| 2.9.9.9 | Onsite Wastewater Treatment Systems (OWTS) | 29 |
| 2.10 | Onsite Wastewater Treatment Systems Technology by Continuous-Flow, Suspended-Growth Aerobic Systems (CFSGAS) | 29 |
| 2.10.1 | Costs | 31 |
| 2.11 | Onsite Wastewater Treatment Systems Technology by Fixed-Film Processes | 31 |
| 2.11.1 | Description | 31 |
| 2.11.2 | Trickling Filter (T.F) | 32 |
| 2.11.3 | Rotating Biological Contactor (RBC) | 32 |
| 2.11.4 | Costs | 33 |
| 2.12 | Onsite Wastewater Treatment Systems Technology by Trickling Filter Processes | 34 |
| 2.13 | Onsite Wastewater Treatment Systems Technology with Sequencing Batch Reactor Systems | 35 |
| 2.13.1 | Description | 35 |
| 2.13.2 | Performance | 36 |
| 2.13.3 | Costs | 37 |
| 2.14 | Onsite Wastewater Treatment Systems Technology with Stabilization Ponds, Fws Constructed Wetlands, And Other aquatic Systems | 37 |
| 2.14.1 | Description | 37 |
| 2.15 | Onsite Wastewater Treatment Systemstechnology With Intermittent Sand/Media Filters | 38 |
| 2.15.1 | Description | 38 |
| 2.15.2 | Applications | 40 |
| 2.15.3 | Costs | 40 |
| 2.15.4 | Reliability | 40 |
| 2.16 | With Waste Stabilization Ponds | 41 |
| 2.17 | With Activated Sludge Process | 41 |

| | | |
|----------|---|-----------|
| 2.18 | With Upflow Anaerobic Sludge Blanket | 42 |
| 2.19 | With Sequencing Batch Reactor | 42 |
| 2.20 | Treatment System Selection | 46 |
| 2.21 | Sustainability of Any Project | 46 |
| 2.22 | Choice of A Treatment System | 47 |
| | 2.22.1 Affordability | 47 |
| | 2.22.2 Acceptability | 47 |
| | 2.22.3 Manageability | 47 |
| 2.23 | Factors In Selection And Design Of Sewage Treatment System | 47 |
| | 2.23.1 Engineering Factors | 48 |
| | 2.23.2 Environmental Factors | 48 |
| | 2.23.3 Process Considerations | 48 |
| | 2.23.4 Cost Considerations | 49 |
| 2.24 | Economics of Treatment Technologies/ Methodology For Selection | 49 |
| | 2.24.1 Annual Cash Flow Projections | 50 |
| | 2.24.2 Net Present Value or Present worth Method | 50 |
| | 2.24.3 Capitalist Cost or Life Cycle Cost Method | 50 |
| | 2.24.4 Internal Rate of Return | 50 |
| | 2.24.5 Return on Investment Method | 50 |
| | 2.24.6 Benefit Cost Ratio | 51 |
| 3 | BACKGROUND OF THE STUDY AREA | 55 |
| 3.1 | STUDY AREA | 55 |
| 3.1.1 | LOCATION | 55 |
| 3.1.2 | DETAILS OF STUDY AREA | 55 |
| 3.1.3 | SOIL | 56 |
| 3.1.4 | ECONOMIC BASE | 56 |
| 3.1.5 | WATER SUPPLY | 56 |
| 3.2 | NEED OF SEWERAGE SYSTEM | 57 |
| 3.3 | POPULATION FORCAST AND SEWAGE | |

| | | |
|----------|---|-----------|
| | GENERATION FOR WARD 45 | 57 |
| 3.4 | ZONING OF SEWERAGE SYSTEM | 57 |
| 3.4.1 | DETAILS OF ZONE I | 57 |
| 3.4.1.1 | Sewage Generation For Zone I | 58 |
| 3.4.2 | DETAILS OF ZONE II | 60 |
| 3.4.2.1 | Sewage Generation For Zone II | 60 |
| 3.4.3 | DETAILS OF ZONE III | 62 |
| 3.4.3.1 | Sewage Generation For Zone III | 62 |
| 4 | RESULTS AND DISCUSSIONS | 64 |
| 4.1 | DATA COLLECTION AND ANALYSIS | 64 |
| 4.1.1 | DESIGN CRITERIA | 64 |
| 4.2 | TECHNOLOGY FOR ANALYSIS | 65 |
| 4.3 | LIFE CYCLE COST ANALYSIS | 67 |
| 4.4 | COMPARISON OF DEWAT & CENTRALISED COLLECTION SYSTEM | 69 |
| 4.5 | COMPARISON OF DEWAT & CENTRALISED SYSTEM WITHOUT LAND COST | 69 |
| 5 | CONCLUSIONS | 70 |
| | REFERENCES | 71 |

LIST OF FIGURES

| Fig No. | Description | Page No. |
|----------|--|----------|
| Fig 1. | Chennai Metropolitan Area | 5 |
| Fig 1.2 | Conducting Awareness programme on DEWATs to Municipal Engineers throughout Tamil Nadu | 7 |
| Fig 1.3 | Deep observation of the Municipal Engineers with the DEWATs | 8 |
| Fig 1.4 | Continuation of Brainstorming Session on DEWATs | 8 |
| Fig 2.1 | Conventional Waste Water Treatment | 12 |
| Fig 2.2 | Composition Present in the Sewage | 12 |
| Fig 2.3 | Primary or Physical Treatment Units | 13 |
| Fig 2.4 | Bar Screen Picture | 13 |
| Fig 2.5 | Grit Chamber | 14 |
| Fig 2.6 | Sedimentation Tank | 14 |
| Fig 2.7 | Salient Features of Chennai City | 17 |
| Fig 2.8 | Chennai City Sewerage Zones | 18 |
| Fig 2.9 | Koyambedu Treatment Plant | 19 |
| Fig 2.10 | Conventional Onsite Wastewater Treatment System | 21 |
| Fig 2.11 | Environmental Sanitation | 22 |
| Fig 2.12 | Biogas Digester | 24 |
| Fig 2.13 | Basic Septic Tank | 25 |
| Fig 2.13 | Anaerobic Filter | 26 |
| Fig 2.15 | Horizontal Sand Filter | 27 |
| Fig 2.16 | Horizontal Flow System | 27 |
| Fig 2.17 | Aerated Units | 31 |
| Fig 2.18 | Septic tank to RBC with Recirculation | 33 |
| Fig 2.19 | Trickling Filter | 34 |
| Fig 2.20 | Septic Tank to Trickling Filter with Recirculation | 35 |
| Fig 2.21 | Septic Tank to SBR With Recirculation | 36 |
| Fig 2.22 | Septic Tank to Trickling Filter with Recirculation | 38 |
| Fig 2.23 | Sand Filter | 39 |

LIST OF TABLES

| Table No. | Description | Page No. |
|------------------|---|-----------------|
| Table 3.1 | The collection and treatment unit location for Zone I | 59 |
| Table 3.2 | The collection and treatment unit location for Zone II | 61 |
| Table 3.3 | The collection and treatment unit location for Zone III | 63 |
| Table 4.1 | Performance Characteristics of the Technologies | 65 |
| Table 4.2 | Technology Process Comparison | 66 |
| Table: 4.3 | Ambattur Municipality Ward 45 Land Cost & O &M Details | 68 |

INTRODUCTION

1.1 PREAMBLE

Health is wealth. Good public health makes the earth, “Hale and Healthy”. Poor public health makes, “pale and sick “. Sustainable health, especially for children is not possible without good environmental sanitation. Since the earth is borrowed from our children and grand children the same should be handed over with added values or at least as such. But these issues are hindered by the problems of burgeoning population and sinking resources on one side and the LPG policies (Liberalization, Privatization and Globalization) and Industrialization on the other side.

Safe water supplies and hygienic sanitation facilities are the part and partial of the community that needs on top priority for healthy living. Every community produces wastewater (sewage). If the waste water is not treated properly it will go septic, the decomposition of organic matter it contains will lead to nuisance condition, generating malodorous gaseous. Untreated waste contains numerous pathogenic micro organisms which will cause epidemic diseases. The effect of pollution on society is recognized by most citizens and has resulted in a national commitment for the environmental clean – up. In India most of the rivers, lakes and other water bodies are polluted due to the indiscriminate discharge of untreated wastewater by the municipalities and industries.

Once appeared as perennial rivers now become lean water flow that too few days in a year and no minimum environmental flow due to various reasons such as decrease in rainfall, Global Warming, Deforestation, Climate Change, GHG emission, Ozone depletion and so on. Sustainability could not be maintained due to assimilating capacity or the carrying capacity of the rivers is also not able to meet the enormous amount of pollutant load due to anthropogenic activities. Hence it becomes mandatory, the wastewater must be treated by adopting BAT (Best Available Technology) and LCT (Least Cost Technology) into harmony leading the environment safe and sustainable.

The technology of collection and treatment of wastewater has undergone significant changes. Hence opt alternate technology to be adopted in the place of old traditional Conventional sewerage and sewage treatment aiming that simple in operation, reliable in achieving the treatment level as per the norms specified by the PCB (Pollution Control Board) also, handling 3 R's (Reduce, Reuse, Recycle) approach for various beneficial uses so as to reduce the ever increasing demand for fresh water, thereby achieving the sustainability of water resource.

While it is necessary to adopt conventional sewerage and treatment methods in metro and mega cities, it is economical to go in for low cost option wherever feasible particularly in small and medium towns. That is Decentralized STPs (DEWATs System).

1.2 RATIONAL BEHIND THE STUDY

Present scenario is a prime motive for the study. That is,

- ❖ Once appeared as perennial rivers now become lean water flow that too few days in a year and no minimum environmental flow resulting waterways into “sick or dead rivers”.
- ❖ Once freely and plenty in quantity that too easily obtained water now becomes precious, bearing prices hence usage is in calculative manner, hence cleaning by flushing out with water could not be made as such, maintaining Self cleansing velocity in the sewer is a problem. Then stale condition prevails in the sewer causing, emanating foul gases from sewage namely Methane, Hydrogen sulphide, carbon-di-oxide etc., affecting Health of the society. This also develops maintenance problem since obstruction of flow of sewage and vulnerable for pollution issues.
- ❖ Sewage contains nutrients and minerals. Hence when discharged on the surface water, eutrophication problem will occur due to growth of weeds and algal blooming known as, “red tides”. This also deplete the D.O (Dissolved Oxygen) level in the waterways, producing “Dead Zone”.

- ❖ When additional sewage from adjacent areas had been allowed with the prevailing sewerage system then chances of overflow causing issues and problems of nuisance and mosquito breeding.
- ❖ In Centralized STPs all the units are in bigger in sizes hence Investment cost is high due to land, labour & material in addition O&M cost also increases.
- ❖ In Centralized STPs Collection and transporting of sewage is made through pipe materials which bears around 60% of project cost, even though the pipe does not treat the wastewater.
- ❖ Once worshipped, purified form of Running Water bodies now becomes putrefied due to free disposal of human wastes and ultimately transmitting epidemic diseases, affecting human health and inflating the Nation's wealth.
- ❖ To avoid the OLIGOPOLYSTIC approach by the pipe manufacturers particularly D.I. Pipes and thereby delay the project period and reaping the benefit of the public.(Ex., JNNURM-Projects)

This worst, unhealthy condition calls, ethical Scientists and Environmental Engineers, to adopt the opt technology harmonizing with BAT and LCT on DEWATs system that too for the adjacent Urbanized areas with aiming of 3R_s (Reduce, Reuse and Recycle) approach for sustainable environmental and attractive aesthetic with creating awareness and transparency to the Enthusiastic public and Smart Non Governmental Organizations (N.G.O) with aiming of 3P_s (Public, Private partnership) approach for easy funding, timely execution and effective maintenance of the DEWATs system.

1.3 OBJECTIVE OF THE STUDY

- To attain the goal of “ sustainable sanitation for all” within a reasonable time frame with advanced Onsite wastewater system technologies to adjacent urbanized area where new growth is occurring and instantly impossible to extend the centralized collection system and thereby protecting the environment, improving the community health and the quality of life.

- To develop a procedure/ methodology for the selection of appropriate DEWATs for the peripheral area of Chennai and techno-economic analysis on the DEWATs technology.
- The decentralized concept is easier to plan and finance.


1.4 STUDY AREA

The study area here selected is ward number 45 of “Ambattur” Municipality which is located at the peripheral area of Chennai, the capital of Tamil Nadu. Ambattur is designated as special grade Municipality and lies north of Chennai with an extent of 40.36 sq.km,

The ward water supply is being maintained by Chennai Metropolitan Water Supply and Sewerage Board (which is responsible to promote or secure the planned development, efficient operation, maintenance and effective regulation of water supply and sewerage systems in the Chennai Metropolitan Area.) and does not possess sewerage system. Wards people are willingness to contribute the amount ,for providing Sewerage facilities to their areas at economic basis.

In view of time consideration for connecting this sector with the Chennai Sewerage System network since prior to this other wards are inline also shortage of D.I pipes and high cost involves in Construction of manholes, pumping station and other facilities also high Operation and maintenance cost thereafter, an alternative novel technology of DEWATs is chosen with public participation for up keeping these wards for hygienic at economic cost with sustainability.

CHENNAI METROPOLITAN AREA (CMA)



- The Chennai Metropolitan Area comprises the City of Chennai and its outlying urban and rural areas
- The extent of CMA excluding St.Thomas Mount cantonments is 1189 Sq.km
- The Chennai City covers 175.18 Sq.km
- The outlying areas consists of the following:
 - 1 Cantonment
 - 16 Municipalities
 - 20 Special Village Panchayats
 - 214 Villages Panchayats in 10 Panchayat Unions

Fig 1. Chennai Metropolitan Area

1.5 METHODOLOGY ADOPTED

If provision of sewerage system has been decided to this sector, then it is the duty of Scientists and Engineers to look into deep in the Technologies and their feasibility, That is, which type of DEWAT system is opt in that locality considering on the following approach. The approach adopted here is, "Globally". That is think globally and acts locally. This approach has to be analyzed on the following aspects also viz., whether the system is

- ❖ Technically feasible
- ❖ Economically viable
- ❖ Financially reasonable
- ❖ Politically agreeable
- ❖ Socially acceptable

- ❖ Environmentally compatible
- ❖ Locally reasonable
- ❖ Functionally sustainable.

Of the above, the first two approaches have strong effects since it bears considerable values on the other aspects mentioned above.

1.6 TECHNOLOGY CONSIDERED

The traditional philosophy of wastewater management is pipe it away first, then think about what comes next is not a sustainable approach for developing countries' There is another system to treat the wastewater at or near the locations where wastewater is generated. That is "on-site" sanitation system or DEWATs (Decentralized Wastewater treatment system). There are also many technologies available like Centralized STPs with their own merits and demerits.

Hence the method of, "Techno Economic analysis" has been applied in selecting the opt DEWAT system for the said peripheral area of Chennai. Comparison studies of the "off-site" conventional Centralized sewerage treatment plant with that selected DEWATs also covered in this study. In order to arrive the best DEWATs from a techno-economic point of view, broadly the following criteria's have been adopted for selection and evaluation.

- ❖ Level of the treatment.
- ❖ Locally suited Technology
- ❖ Very less power consumption.
- ❖ Treatment option should be simple to construct, easy to operate and low O&M cost
- ❖ To adapt 3R_s (Reduce, Reuse, Recycle)

1.7 ECONOMICS OF TREATMENT TECHNOLOGIES

For sustainability of selected system, economics of treatment technology is must. Since India lives in villages economics is a lives line. Whether the system is economically viable selected financial management tools are used for comparing the cost of the various Sewage Treatment Technologies namely Net Present Value (NPV), Internal Rate of Return (IRR) and Cost-Benefit Ratio (CBR) are used. Reuse of effluent becomes more cost efficient if non-

potable water demands such as landscape irrigation, toilet flush supply and cooling tower makeup are required.

1.8 AWARENESS CREATION

It is the way of to overcome barriers on implementing DEWATs option. To create awareness to the people that there are other alternative technologies available for on-site wastewater treatment system for small quantities of wastewater so that the currently unsewered areas may also be safe sewerred, thus the possibility of up keeping the hygienic facilities.

Lack of knowledge and misperception of DEWATs has to be removed. Public health officials, engineers, regulators, system designers, inspectors and developers often possess only limited knowledge of the broad range of DEWATs because these technologies are not adequately covered in university engineering curricula. DEWATs are perceived to be inadequate for meeting specified public health and water quality goals. Typically, Onsite systems are perceived as the standard septic tank and leach field. However, alternative onsite systems include other types of decentralized systems, such as mound system or sand filters.

House owners are frequently uninformed about how their conventional onsite systems are working, how to maintain them and about the potential for human and eco system risks from poorly functioning systems.

To overcome the above barriers, Education is critical efforts to encourage the acceptance and use of DEWATs . As such awareness about the DEWATs has been made among municipal engineers of various districts of Tamilnadu by conducting Brainstorming session on, “DEWAT system” and the free ideas were collected for further analysis.



Fig1.2 Conducting Awareness programme on DEWATs to Municipal Engineers throughout TamilNadu.



Fig 1.3 Deep observation of the Municipal Engineers with the DEWATs




Fig 1.4 Continuation of Brainstorming Session on DEWATs

1.9 PUBLIC, PRIVATE, PARTICIPATION (PPP)

The implementation of any project will be easy and smooth, only when there is initially a lot of conflicts arise at concept and before DPR preparation level. Hence the PPP approach is the best way of removing the problems on gray area and to implement the transparency on management, Liability and engineering fee issues and the state- of- art technology also financial limitations.

Public involvement and education are critical to successful onsite wastewater management. Engaging the public in wastewater treatment issues helps build support for funding, regulatory initiatives, and other elements of a comprehensive program. Educational activities directed at increasing general awareness and knowledge of onsite management efforts can improve the probability that simple, routine operation and maintenance tasks(e.g., inspecting for pooled effluent, pumping the tank) are carried out by system owners. Specialized training is

required for system managers responsible for operating and maintaining systems with more complex components. Even conventional, gravity-based systems require routine pumping, monitoring, and periodic inspection of sludge and scum buildup in septic tanks. Failing systems can cause public health risks and environmental damage and are expensive to repair. System owners should be made aware of the need for periodically removing tank sludge, maintaining system components.

LITERATURE REVIEW**2.1 HISTORY OF ONSITE WASTEWATER TREATMENT SYSTEMS**

King Minos installed the first known water closet with a flushing device in the Knossos Palace in Crete in 1700 BC. In the intervening 3,700 years, societies and the governments that serve them have sought to improve both the removal of human wastes from indoor areas and the treatment of that waste to reduce threats to public health and ecological resources. The Greeks, Romans, British, and French achieved Considerable progress in waste removal during the period from 800 BC to AD 1850, but removal often meant discharge to surface waters; severe contamination of lakes, rivers, streams, and coastal areas; and frequent outbreaks of diseases like cholera and typhoid fever. By the late 1800s, the Massachusetts State Board of Health and other state health agencies had documented links between disease and poorly treated sewage and recommended treatment of wastewater through intermittent sand filtration and land application of the resulting sludge. The past century has witnessed an explosion in sewage treatment technology and widespread adoption of centralized wastewater collection and treatment services in the United States and throughout the world. Although broad uses of these systems have vastly improved public health and water quality in urban areas, homes and businesses without centralized collection and treatment systems .

2.2 BACKGROUND AND USE OF ONSITE WASTEWATER TREATMENT SYSTEMS

Septic tanks for primary treatment of wastewater appeared in the late 1800s, and discharge of tank effluent into gravel-lined subsurface drains became common practice during the middle of the 20th century (Kreissl, 2000). Scientists, engineers, and manufacturers in the wastewater treatment industry have developed a wide range of alternative technologies designed to address increasing hydraulic loads and water contamination by nutrients and pathogens. These technologies can achieve significant pollutant removal rates.

With proper management oversight, alternative systems (e.g., recirculation sand filters, peat-based systems, package aeration units) can be installed in areas where soils, bedrock, fluctuating ground water levels, or lot sizes limit the use of conventional systems. Alternative technologies typically are applied to the treatment train beyond the septic tank.

The tank is designed to equalize hydraulic flows; retain oils, grease, and settled solids; and provide some minimal anaerobic digestion of settleable organic matter. Alternative treatment technologies often provide environments (e.g., sand, peat, and artificial media) that promote additional biological treatment and remove pollutants through filtration, absorption, and adsorption.

All of the alternative treatment technologies in current use require more intensive management and monitoring than conventional OWTs because of mechanical components, additional residuals generated, and process sensitivities (e.g., to wastewater strength or hydraulic loading). Replacing gravity-flow subsurface soil infiltration beds with better-performing alternative distribution technologies can require float-switched pumps and/or valves.

Specialized excavation or structures might be required to house some treatment system components, including the disinfection devices (e.g., chlorinators, ultraviolet lamps) used by some systems. In addition, it is often both efficient and effective to collect and treat septic tank effluent from clusters of individual sources through a community or cluster system driven by gravity, pressure, or vacuum. These devices also require specialized design, operation, and maintenance and enhanced management oversight.

2.3 THE CONVENTIONAL WASTEWATER MANAGEMENT APPROACH

The conventional wastewater management concept, consisting of a water-borne wastewater collection system leading to a central treatment plant, has been successfully applied over many decades in densely populated areas of industrialized countries and contributed to a great extent to the improvement of hygienic conditions in these areas.



Fig 2.1 Conventional Waste Water Treatment

2.4 SEWAGE COMPOSITION

Sewage consists of 99.9% liquid and the remaining 0.1% only solids and this causes such great nuisance in addition to that sewage also contains millions of micro organisms.




Fig 2.2 Composition Present in the Sewage

2.5 THE CONVENTIONAL TREATMENT METHOD INCLUDES

- Primary or Physical treatment
- Biological or Secondary treatment
- Tertiary or advanced treatment




Fig2.3 Primary or Physical Treatment Units

2.5.1 BAR RACKS & SCREENS:

Here removal of floating and settle able solids those are larger than the size of opening in screens.



Fig 2.4 Bar Screen Picture

2.5.2 GRIT CHAMBER

Removal of inert inorganic heavy and tough particles such as grit, sand, stones, etc. which will otherwise affect the pumps and other downstream equipments.



Fig 2.5 Grit Chamber

2.5.3 SEDIMENTATION

Removable of settle able solids and scum




Fig 2.6 Sedimentation Tank

2.6 BIOLOGICAL OR SECONDARY TREATMENT

The objective of biological treatment is to coagulate the non settle able colloidal solids and to stabilize the organic matter. The various biological processes used for sewage treatment are

- Aerobic
- Anaerobic
- Aerobic & Anaerobic in tandem
- Pond Systems
- Natural treatment systems

2.6.1 AEROBIC PROCESSES

| Suspended growth | Attached growth | Both combined |
|--------------------------|--------------------------|------------------------------|
| Activated Sludge process | Trickling Filter | Fluidized Aerobic Bioreactor |
| Sequencing Batch Reactor | Rotating Biological Disc | - |
| Aerated Lagoons | - | - |
| Extended Aeration | - | - |

2.6.2 ANAEROBIC PROCESSES

| Suspended growth | Attached growth |
|---|-------------------------------|
| Up flow Anaerobic Sludge Blanket (UASB) | Extended Bed |
| Anaerobic Baffled Reactor | Fluidized Anaerobic Bed (FAB) |

2.6.3 AEROBIC & ANAEROBIC IN TANDEM

Biofilter

2.6.4 POND SYSTEMS

- Waste stabilization Ponds

- Oxidation ponds
- Duck Weed Ponds

2.6.5 NATURAL TREATMENT SYSTEMS

- Slow rate treatment
- Rapid infiltration
- Overland flow
- Constructed Wetlands
- Aquaculture

2.7 TERTIARY OR ADVANCED TREATMENT

The need for tertiary or advanced treatment is based on a consideration of one or more of the following factors.

- The need to remove organic matter and total suspended solids beyond what can be above process to meet more stringent discharge or reuse standards
- The need to remove residual total suspended solids to condition the treated effluent for more effective disinfection.
- The Sneed to remove nutrients beyond what can be accomplished by above processes to limit the eutrophication of sensitive water bodies.
- The need to remove specific inorganic (heavy metals) and organic constituents to meet the reuse standard.

2.7.1 ADVANCED TREATMENT SYSTEMS

- Depth filtration
- Surface filtration
- Membrane filtration
- Carbon adsorption
- Reverse osmosis

- Chemical precipitation
- Chemical oxidation
- Electro dialysis
- Distillation
- Ultra filtration

2.8 THE CONVENTIONAL WASTEWATER TREATMENT SYSTEM AT CHENNAI IN TAMILNADU

Chennai is the capital of Tamil Nadu and it is fourth largest city in India. It's Geographical area is 175.18 sq.km.and the adjacent urbanized area is 7.88 sq.km. It's latitude is 13°04' minutes North and the longitude 80°15' minutes East. Its population as per 2006 census is 5.32million.Its topography is flat. Adayar and Cooum rivers are its drainage. The climate is tropical. Other details are furnished below.




Fig 2.7 Salient Features of Chennai City

Due its plain terrain the sewerage system has been formulated in Zonal basis. The entire city is divided into Five zones and is shown in the fig.,below




Fig 2.8 Chennai City Sewerage Zones

OF THE FIVE ZONES THE THIRD ZONE NAMEDLY KOYAMBEDU TREATMENT PLANT IS SHOWN HERE.






Fig 2.9 Koyambedu Treatment Plant



2.9 SCIENCE AND TECHNOLOGY

Based on today's technology options, using large lots to protect public health and the Environment is not necessarily sound science. An understanding of today's technology, coupled with good planning and a commitment to maintenance and management, is a vital step towards safely developing denser growth areas.

During the last decade, various researchers and institutions, including the World Bank, have started to consider the decentralized wastewater management approach as an alternative to conventional centralized systems, but these approaches have struggled to gain acceptance. The main arguments against decentralization of wastewater management are based on financial concerns and issues of treatment efficiency. This might be partly true, but it cannot be denied that the decentralized approach has great potential and could serve to complement existing centralized systems.

2.9.1 DECENTRALISED APPROACH

The centralized wastewater management system is nothing else than a transportation system for human excreta and industrial wastes to a central discharge place or a treatment unit. Using valuable drinking water as transport medium, these systems are wasteful not only of water but also of human waste elements that can be easily treated and reused. Centralized wastewater management systems reduce wastewater reuse opportunities and increase the risk to humans and the environment in the event of system failures. Conversely, the decentralized wastewater management concept is better suited to translate Bellagio Principles No 3 (perceiving human excreta and wastes as potential resources) and No 4 (solving sanitation issues as close as possible to the source of waste generation) into practice. Furthermore the decentralized wastewater management concept:

- Broadens the technology options and permits tailoring the solutions to the prevailing conditions;
- Minimizes the freshwater requirements for waste transportation;
- Reduces the risks associated with system failure;

- Increases wastewater reuse opportunities; and
- Permits incremental development and investment in the community wastewater system.

2.9.2 CONVENTIONAL ONSITE WASTEWATER TREATMENT SYSTEM

Onsite system has consisted primarily of a septic tank and a soil absorption field, also known as a subsurface wastewater infiltration system, or SWIS. In this manual, such systems are referred to as *conventional systems*. Septic tanks remove most settleable and floatable material and function as an anaerobic bioreactor that promotes partial digestion of retained organic matter. Septic tank effluent, which contains significant concentrations of pathogens and nutrients, has traditionally been discharged to soil, sand, or other media absorption fields (SWISs) for further treatment through biological processes, adsorption, filtration, and infiltration into underlying soils.




Fig 2.10 CONVENTIONAL ONSITE WASTEWATER TREATMENT SYSTEM

2.9.3 ABOUT DEWATS

DEWATS stands for “Decentralized Wastewater Treatment Systems”. DEWATS is rather a technical approach than merely a technology package. DEWATS applications provide treatment for both, domestic and industrial sources. Decentralized wastewater treatment

systems have enormous potential in contributing to the development of sustainable environmental sanitation concepts and are in line with the Bellagio Principles. As engineers, we are called upon to provide technologies that are reliable, easy to operate and affordable to use. This task is a difficult one that requires an interdisciplinary approach that takes into account local conditions.




Fig 2.11 Environmental sanitation

DEWATS applications provide treatment for organic wastewater flows from 1-1000 m³ per day. DEWATS applications are reliable, long lasting and tolerant towards inflow fluctuation. DEWATS applications do not need sophisticated maintenance without considering facilities for necessary chemical pre-treatment of wastewater from industries.

2.9.4 FOUR BASIC TECHNICAL TREATMENT MODULES ACCORDING TO DEMAND FOR DEWATS APPLICATIONS

The four basic technical treatment modules according to demand for DEWATS applications are:

1. Primary treatment: Sedimentation and floatation
2. Secondary anaerobic treatment in fixed-bed reactors: baffled upstream reactors or anaerobic filters.

3. Tertiary aerobic treatment in sub-surface flow filters and
4. Tertiary aerobic treatment in polishing ponds

2.9.5 DEWATS APPLICATIONS

They are designed and dimensioned in such a way that treated water meets requirements stipulated in environmental laws and regulations. DEWATS applications are based on the principle of low-maintenance since most important parts of the system work without technical energy inputs and cannot be switched off intentionally. DEWATS applications provide state-of-the-art-technology at affordable prices because all of the materials used for construction are locally available. Hence DEWATS technology is an effective, efficient and affordable wastewater treatment solution for small and medium sized enterprises (SME).

2.9.6 DEMAND OF DEWATS SYSTEM

The demand for reliable, efficient and low-cost wastewater treatment systems is increasing world wide especially in densely populated urban regions where adequate wastewater treatment systems do not exist and uncontrolled discharge of wastewater endangers environmental health and water resources. Many Governments have passed new environmental regulations stipulating that dischargers of wastewater such as small and medium enterprises and housing estates will be held responsible for wastewater pollution and must therefore treat wastewater adequately on-site before it is discharged into the environment.

2.9.7 DEWATS-MODULES FOR PHYSICAL AND BIOLOGICAL WASTEWATER TREATMENT:

1. Settler
2. Anaerobic Baffled Reactor
3. Anaerobic Filter
4. Planted Gravel Filter

2.9.8 ADVANTAGES OF DEWATS TECHNOLOGY:

- Providing treatment for domestic and industrial wastewater
- Low primary investment costs as no imports are needed
- Efficient treatment of daily wastewater flows up to 1000 m³
- Modular design of all components
- Tolerant towards inflow fluctuations
- Reliable and long-lasting construction design
- Expensive and sophisticated maintenance not required
- Low maintenance costs
- Establishing of multi-stakeholder networks to combat water pollution
- Fulfillment of discharge standards and environmental laws
- Wastewater pollution reduced by up to 90%
- Reliable and long lasting applications
- Materials/ inputs used for construction are locally available
- Minimal maintenance and long de-sludging intervals

2.9.9 DEWATS TECHNOLOGY PRINCIPLES

A combination of low- maintenance based technology.

2.9.9.1 BIOGAS DIGESTER

It is Half-ball-shaped fixed dome plant. It is suitable for thick and homogeneous substrate like sludge from aerobic treatment tanks, liquid animal excreta and excrement





Fig. 2.12 Biogas Digester

2.9.9.2 BASIC SEPTIC TANK



(C) 2005-1985 Daniel Friedman

Fig 2.13 Basic septic tank

In unsewered areas, the liquid waste from individual households is treated in septic tanks. Gas recovery is not done. The sludge disposal is done at long intervals.

Basically principled on sedimentation tank in which settled sludge is stabilized by anaerobic digestion. Here Mechanical treatment by sedimentation. Biological treatment by contact between fresh water and active sludge complete with each other in the septic tank.

Sedimentation biodigesters are optionally constructed and integrated with " Baffle Reactor". They are brick construction, fully waterproof, and air-tight plastering. Biogas produced as renewable energy source.

Retention time of the liquid is in the order of one day, Sludge is digested anaerobically in the septic tank, resulting in a reduced volume of sludge. Septic tank offers primary treatment with 40-50% removal of COD and 65% reduction of suspended solids. It requires very little land and there is no power requirement.

2.9.9.3 BAFFLED UP-FLOW REACTOR

Here treatment is done by forcing incoming wastewater to pass through active bacteria sludge in each compartment. The settler in front prevents larger solids to enter the baffle section.

2.9.9.4 ANAEROBIC FILTER REACTOR

The treatment of non-settle able and dissolved solids is done by bringing them in close contact with a surplus of active bacterial mass.




Fig 2.13 Anaerobic Filter

Anaerobic degradation of suspended and dissolved solid is based on up-flow principle. They are simple, durable, and easy to maintain. Underground construction and little permanent space required. They are effective, efficient and low cost maintenance. The BOD reduction is up to 90%.

2.9.9.5 HORIZONTAL SAND FILTER

Here continuous oxygen supply is being provided to the upper layers. Treatment by permanently soaked sand or gravel filter with water and operates partly anoxic and partly anaerobic. This technology uses Aerobic-Facultative- Anaerobic degradation of dissolved and fine suspended solids. Pathogen removal occurring with high treatment efficiency and no nuisance odor. No wastewater above ground.




Fig 2.15 Horizontal Sand Filter




Fig 2.16 Horizontal Flow System

2.9.9.6 IMPROVING TREATMENT THROUGH PERFORMANCE REQUIREMENTS

Most onsite wastewater treatment systems are of the conventional type, consisting of a septic tank and a Subsurface Wastewater Infiltration System (SWIS). Site limitations and more stringent performance requirements have led to significant improvements in the design of wastewater treatment systems. Industry has developed many new treatment technologies that can achieve high performance levels on sites with size, soil, ground water, and landscape limitations that might preclude installing conventional systems.

New technologies and improvements to existing technologies are based on defining the performance requirements of the system, characterizing wastewater flow and pollutant loads, evaluating site conditions, defining performance and design boundaries, and selecting a system

design that addresses these factors. Performance requirements can be expressed as numeric criteria (e.g., pollutant concentration or mass loading limits) or narrative criteria (e.g., no odors or visible sheen) and are based on the assimilative capacity of regional ground water or surface waters, water quality objectives, and public health goals.

Wastewater flow and pollutant content help define system design and size and can be estimated by comparing the size and type of facility with measured effluent outputs from similar, existing facilities. Site evaluations integrate detailed analyses of regional hydrology, geology, and water resources with site-specific characterization of soils, slopes, structures, poetry lines, and other site features to further define system design requirements and determine the physical placement of system components.

2.9.9.7 MOST OF THE ALTERNATIVE TREATMENT TECHNOLOGIES APPLIED TODAY TREAT WASTES AFTER THEY EXIT THE SEPTIC TANK.

The tank retains settle able solids, grease, and oils and provides an environment for partial digestion of settled organic wastes. Post-tank treatment can include aerobic (with oxygen) or anaerobic (with no or low oxygen) biological treatment in suspended or fixed-film reactors, physical/chemical treatment, soil infiltration, fixed-media filtration, and/or disinfection. The application and sizing of treatment units based on these technologies are defined by performance requirements, wastewater characteristics, and site conditions.

2.9.9.8 TOWARDS MORE COMPREHENSIVE APPROACH

The principles of the 1980 onsite system design manual have withstood the test of time, but much has changed over the past 20 years. This manual incorporates much of the earlier guide but includes new information on treatment technologies, site evaluation, design boundary characterization, and especially management program functions. The manual is organized by functional topics and is intended to be a comprehensive reference. Although this manual focuses on individual and small, clustered onsite systems, state and tribal governments and other management entities can use the information in it to construct a framework for managing new and existing large-capacity decentralized systems .

2.9.9.9 ONSITE WASTEWATER TREATMENT SYSTEMS (OWTS)

They have evolved from the pit privies used widely throughout history to installations capable of producing a disinfected effluent that is fit for human consumption. Although achieving such a level of effluent quality is seldom necessary, the ability of onsite systems to remove settle able solids, floatable grease and scum, nutrients, and pathogens from wastewater discharges defines their importance in protecting human health and environmental resources. In the modern era, the typical onsite system has consisted primarily of a septic tank and a soil absorption field, also known as a subsurface wastewater infiltration system, or SWIS .Such systems are referred to as *conventional systems*.

Septic tanks remove most settle able and floatable material and function as an anaerobic bioreactor that promotes partial digestion of retained organic matter. Septic tank effluent, which contains significant concentrations of pathogens and nutrients, has traditionally been discharged to soil, sand, or other media absorption fields (SWISs) for further treatment through biological processes, adsorption, filtration, and infiltration into underlying soils. Conventional systems work well if they are installed in areas with appropriate soils and hydraulic capacities; designed to treat the incoming waste load to meet public health, ground water, and surface water performance standards; installed properly; and maintained to ensure long-term performance.

2.10 ONSITE WASTEWATER TREATMENT SYSTEMS TECHNOLOGY BY CONTINUOUS-FLOW, SUSPENDED-GROWTH AEROBIC SYSTEMS (CFSGAS)

DESCRIPTION

The activated sludge process is an aerobic suspended-growth process that maintains a relatively high population of microorganisms (**biomass**) by recycling settled biomass back to the treatment process. The biomass converts soluble and colloidal biodegradable organic matter and some inorganic compounds into cell mass and metabolic end products. The biomass is separated from the wastewater through settling in a clarifier for recycling or wasting to sludge handling processes. Preliminary treatment to remove settle able solids and floatable materials is usually provided by a septic tank or other primary treatment device. Most onsite designs are capable of providing significant ammonia oxidation and effective removal of organic matter.

The basic system consists of a number of interrelated components

- An aeration tank or basin.

- An oxygen source and equipment to disperse atmospheric or pressurized air or oxygen into the aeration tank at a rate sufficient to always maintain positive dissolved oxygen.
- A means to appropriately mix the aeration basin and ensure suspension of the biomass (usually accomplished by the aeration system).
- A clarifier to separate the biomass from the treated effluent and collect settled biomass for recycling to the aeration basin.

Several modifications of this basic process are commercially available. These include different aeration devices; different means of sludge collection and recycling to the aerator; the use of coarse membrane filters in lieu of, or in addition to, the clarifier; and process enhancement through the addition of an inert media area on which biofilms can grow. The addition of surfaces where biota can become attached and grow increases the capacity of the system (increased organic loading possible). This last modification is the most significant enhancement and is described below. The combined fixed-film/suspended growth process is sometimes referred to as a class of treatment processes called coupled contact aeration, enhanced, or high biomass systems. To enhance performance and increase the capacity of the aeration tank, an inert support medium is added to the aeration tank. This allows a fixed film of biomass to attach and grow on the medium to augment the suspended microbial population, providing more biomass to feed on wastewater constituents. Synthetic trickling filter media, loops of fiber bundles, and a variety of different plastic surface configurations can be suspended in the aeration tank. Advantages include increased active microbial mass per unit volume, enhanced potential for nitrification, reduced suspended solids loading to the clarifier, improved solids separation characteristics, reduced sludge production, and resilience under variable influent conditions.




Fig 2.17 Aerated Units

2.10.1 COSTS

The installed costs of package plants are highly variable but are usually less than \$10,000. Operation and maintenance (O/ M) costs are primarily dependent on local power and labor costs, varying from \$400 to \$600 per year in most cases.

2.11 ONSITE WASTEWATER TREATMENT SYSTEMS TECHNOLOGY BY FIXED-FILM PROCESSES

2.11.1 DESCRIPTION

Fixed-film systems (FFS) are biological treatment processes that employ a medium such as rock, plastic, wood, or other natural or synthetic solid material that will support biomass on its surface and within its porous structure.

At least two types of fixed-film systems may be considered.

- those in which the medium is held in place and is stationary relative to fluid flow (**trickling filter**) and
- Those in which the medium is in motion relative to the wastewater (e.g., **rotating biological disk**). A third classification includes dual-process systems that encompass both fixed and suspended biomass together or in series.

2.11.2 TRICKLING FILTER (T.F)

Systems are typically constructed as beds of media through which wastewater flows. Oxygen is normally provided by natural or forced ventilation. Flow distributors or sprayers distribute the wastewater evenly onto the surface of the medium. As the wastewater moves by gravity through the medium, soluble and colloidal organic matter is metabolized by the biofilm that forms on the medium. Excess biomass sloughs from the medium and is carried with the treated wastewater to the clarifier, where the solids settle and separate from the treated effluent. At this point the treated wastewater may be discharged or recycled back to the filter medium for further treatment.

2.11.3 ROTATING BIOLOGICAL CONTACTOR (RBC)

Fixed-film biological treatment process that employs rotating disks that move within the wastewater is referred to as Rotating Biological Contactor (RBC). Developed in the late 1960s, the RBC employs a plastic medium configured as disks and mounted on a horizontal shaft. The shafts are rotated slowly (1 to 2 rpm) by mechanical or compressed air drive. For a typical aerobic RBC, approximately 40 percent of the medium is immersed in the wastewater. Anoxic or anaerobic RBCs (far less common) are fully immersed in the wastewater. Wastewater flows through the medium by simple displacement and gravity.




Fig 2.18 Septic tank to RBC with Recirculation

Biomass continuously sloughs from the disks, and some suspended biomass develops within the wastewater channels through which the disks rotate, making the addition of a secondary clarifier necessary. The rotation of the disks exposes the attached biomass to atmospheric air and wastewater. Oxygen is supplied by natural surface transfer to the biomass. Some oxygenation of the wastewater is also created by turbulence at the disk-water interface.

2.11.4 COSTS

Observed costs are highly variable depending on climate, location, onsite aesthetic requirements, and many other factors. The cost of power should be in the range of \$100 per year for RBC units and \$35 per year for trickling filters. Capital(installed) costs of \$9,000 to \$14,000 are typical. A management contract estimated at about \$100 to \$200 per year recommended.

2.12 ONSITE WASTEWATER TREATMENT SYSTEMS TECHNOLOGY BY TRICKLING FILTER PROCESSES

The first Trickling Filter(TF) was installed in England in 1893. This bed was filled with sewage from the top and the sewage is allowed to remain in contact with the media for a short time. The bed was then drained and allowed to rest before the cycle was repeated. The resting period was about 6 hrs while a complete cycle took 12 hrs. In view of low loading rate, long resting period, heavy clogging, these filters have given place to TF.

Here sewage is sprayed over the bed, becomes wet, and sewage trickles through the filter bed. The surface of the media that comes into contact with sewage develops a Zoogeal film rich in bacteria, fungi, and protozoa. This film first transfers the suspended, colloidal, and dissolved solids from sewage by simple absorption and adsorption, decomposes them, and then throws back into sewage their end products. This results in a considerable removal of BOD. The suspended solids get sloughed off and the converted SS are removed in a secondary settling tank.




Fig 2.19 Trickling Filter




Fig 2.20 Septic Tank to Trickling Filter with Recirculation

2.13 ONSITE WASTEWATER TREATMENT SYSTEMS TECHNOLOGY WITH SEQUENCING BATCH REACTOR SYSTEMS

2.13.1 DESCRIPTION

The Sequencing Batch Reactor (SBR) process is a sequential suspended growth (activated sludge) process in which all major steps occur in the same tank in sequential order. There are two major classifications of SBRs: the intermittent flow (IF) or "true batch reactor," which employs all the steps in figure 1, and the continuous flow (CF) system, which does not follow these steps. Both




Fig 2.21 Septic Tank to SBR with Recirculation

Have been used successfully at a variety of U.S. and worldwide installations. SBRs can be designed and operated to enhance removal of nitrogen, phosphorus, and ammonia, in addition to removing TSS and BOD. The intermittent flow SBR accepts influent only at specified intervals and, in general, follows the five-step sequence. There are usually two IF units in parallel. Because this system is closed to influent flow during the treatment cycle, two units may be operated in parallel, with one unit open for intake while the other runs through the remainder of the cycles. In the continuous inflow SBR, influent flows continuously during all phases of the treatment cycle. To reduce short-circuiting partition is normally added to the tank to separate the turbulent aeration zone from the quiescent area.

2.13.2 PERFORMANCE

With appropriate design and operation, SBR plants have been reported to produce high quality BOD and TSS effluents. Typical ranges of CBOD₅ (carbonaceous 5-day BOD) are from 5 to 15 mg/L. TSS ranges from 10 to 30 mg/L in well operated systems. FC removal of 1 to 2 logs can be expected. Normally, nitrification can be attained most of the time unless cold temperatures persist. The SBR systems produce a more reliable effluent quality than CFSGAS or FFS owing to the random nature of the wastewater generated from an individual home.

2.13.3 COSTS

For residential applications, typical system equipment costs are \$7,000 to \$9,000. Installation costs vary depending on site conditions; installation costs between \$1,500 and \$3,000 are typical for uncomplicated sites with good access. It should be noted that additional system components (e.g., subsurface infiltration system) will result in additional costs. Annual operation and maintenance costs include electricity use (<\$300/year), sludge removal (>\$100/year), and equipment servicing. (Some companies are providing annual service contracts for these units for \$250 to \$400.) Actual costs will vary depending on the location of the unit and local conditions.

2.14 ONSITE WASTEWATER TREATMENT SYSTEMS TECHNOLOGY WITH STABILIZATION PONDS, FWS CONSTRUCTED WETLANDS, AND OTHER AQUATIC SYSTEMS

2.14.1 DESCRIPTION

Aquatic systems are large basins filled with wastewater undergoing some combination of physical, chemical, and/or biological treatment processes that render the wastewater more acceptable for discharge to the environment. They are not widely used because they tend to be large in area, require some form of fencing to minimize human health risk, often require supplemental treatment before discharge or reuse, and are approved in only a few states. Stabilization ponds (lagoons) have many forms, but the facultative lagoon is the most widely used. Aerated lagoons are often preferred because of their smaller size requirements. Anaerobic lagoons and maturation ponds are not used in the United States for onsite application by design. In some areas, lagoons must be lined according to codes, which further limit their application. Facultative lagoons are large in size, perform best when segmented into at least three cells, obtain necessary oxygen for treatment by surface reaeration from the atmosphere, combine sedimentation of particulates with biological degradation, and produce large quantities of algae, which limits the utility of their effluent without further treatment.




Fig 2.22 Septic Tank to Trickling Filter with Recirculation

2.15 ONSITE WASTEWATER TREATMENT SYSTEMS TECHNOLOGY WITH INTERMITTENT SAND/MEDIA FILTERS

2.15.1 DESCRIPTION

The term intermittent sand filter (ISF) is used to describe a variety of packed-bed filters of sand or other granular materials available on the market. Sand filters provide advanced secondary treatment of settled wastewater or septic tank effluent. They consist of a lined (e.g., impervious PVC liner on sand bedding) excavation or structure filled with uniform washed sand that is placed over an under drain system. The wastewater is dosed onto the surface of the sand through a distribution network and allowed to percolate through the sand to the under drain system. The under drain system collects the filter effluent for further processing or discharge. Sand filters are aerobic, fixed-film bioreactors. Other treatment mechanisms that occur in sand filters include physical processes, such as straining and sedimentation, that remove suspended solids within the pores of the media.




Fig 2.23 Sand Filter

Also, chemical adsorption of pollutants onto media surfaces plays a finite role in the removal of some chemical constituents (e.g., phosphorus). Bio slimes from the growth of microorganisms develops as films on the sand particle surfaces. The microorganisms in the slimes absorb soluble and colloidal waste materials in the wastewater as it percolates over the sand surfaces. The adsorbed materials are incorporated into a new cell mass or degraded under aerobic conditions to carbon dioxide and water. Most biochemical treatment occurs within

approximately 6 inches of the filter surface. As the wastewater percolates through this layer, suspended solids and carbonaceous biochemical oxygen demand (BOD) are removed.

2.15.2 APPLICATIONS

Sand filters can be used for a broad range of applications, including single-family residences, large commercial establishments, and small communities. Sand filters are frequently used to pretreat septic tank effluent prior to subsurface infiltration onsite where the soil has insufficient unsaturated depth above ground water or bedrock to achieve adequate treatment. They are also used to meet water quality requirements (with the possible exception of fecal coli form removal) before direct discharge to surface water. Sand filters are used primarily to treat domestic wastewater,

2.15.3 COSTS

Costs of the feasible alternatives should be arrayed based on the *total cost* of each alternative. Total costs include both the capital costs incurred in planning, designing, and constructing the system and the long-term costs associated with maintaining the system over its design life (20 to 30 years in most cases); This method of cost analysis is an equitable method of comparing alternatives with higher capital costs but lower annual operating costs to other alternatives with lower capital costs but higher annual operating costs. Often, owners are deceived by systems with lower capital costs. These systems might have much higher annual operating costs, a shorter design life, and possibly higher replacement costs, resulting in much higher total costs. Systems with higher capital costs might have lower total costs because the recurring operation and maintenance costs are less. Choosing between alternatives with varying total cost options is a financing decision. In some cases, capital budgets are tighter than operating budgets. Therefore, this is a decision the prospective owner must make based on available financing options.

2.15.4 RELIABILITY

The reliability of the proposed system and the risk so the owner, the public, and the environment if malfunctions or failures occur must be considered. Potential risks include public health and environmental risks, property image, personal injury, medical expenses, fines, and

penalties. Where these or other potential risks are significant, contingency plans should be developed to manage the risks. Contingencies include storage, pump and haul (holding tank), redundant components, reserve capacity, and designation of areas for repair or replacement components (e.g., replacement leach field). These come at additional cost, so their benefit must be weighed against the potential risks.

2.16 WITH WASTE STABILIZATION PONDS

Waste Stabilization Ponds(WSP) are shallow man-made ponds into which sewage flows and from which after a retention time of several days a well-treated effluent is discharged. The oxygen requirement for the bacteria is obtained through the mutualistic relation between the pond algae and the pond bacteria. During the presence of sun light during the photosynthetic process the algae provide oxygen to the bacteria and bacteria provide the carbon dioxide required by the algae. WSP can be either single pond or a series of ponds-anaerobic, facultative and maturation. 70-95% of BOD is removed in the pond system.

2.17 WITH ACTIVATED SLUDGE PROCESS

The activated sludge process was developed around 1913-1914 by Arden and Lockett. The activated sludge process was so named because it involved the production of an activated mass of microorganisms (bacteria, fungi, protozoa, rotifers and nematodes.) capable of stabilizing a wastewater under aerobic conditions. Bacteria actually degrade the organic waste in the influent. In the aeration tank, contact time is provided for mixing and aerating the influent wastewater with the microbial suspension, generally referred to as the mixed liquor suspended solids (MLSS) or mixed liquor volatile suspended solids (MLVSS). It is a measure of the active biological mass in the aeration tank. The term **mixed liquor** implies a mixture of activated sludge and wastewater. The fraction of the suspended matter that volatilizes at 55°C is taken to be a measure of active biomass. The MLVSS commonly is taken to be 75 to 80 percent of total mixed liquor suspended solids (MLSS).

Mechanical equipment is used to provide the mixing and transfer of oxygen into the process. The mixed liquor then flows to a clarifier where the microbial suspension is settled and thickened. The settled biomass, described as Activated sludge because of the presence of active microorganisms, is returned to the aeration tank to continue biodegradation of the influent

organic material. A portion of the thickened solids is removed daily or periodically as the process produces excess biomass that would accumulate along with the non biodegradable solids contained in the influent wastewater. If the accumulated solids are not removed, they will eventually find their way to the system effluent.

An important feature of the activated sludge process is the formation of floc particles, ranging in size from 50 to 200 micrometer, which can be removed by gravity settling, leaving relatively clear liquor as the treated effluent.

2.18 WITH UPFLOW ANAEROBIC SLUDGE BLANKET

The Up flow Anaerobic Sludge Blanket Reactor(UASB), maintains a high concentration of biomass through formation of highly settle able microbial aggregates. The wastewater flows upwards through a layer of sludge. At the top of the reactor phase separation between gas-solid-liquid takes place. Any biomass leaving the reaction zone is directly recirculated from the settling zone. The process is suitable for both soluble wastes and those containing particulate matter. The process has been used for treatment of municipal wastewater at few locations and hence limited performance data and experience is available presently.

2.19 WITH SEQUENCING BATCH REACTOR

The Sequencing Batch Reactor(SBR) process utilizes a fill-and -draw reactor with complete mixing during the batch reaction step(after filling) and where the subsequent steps of aeration and clarification occur in the same tank. All SBR systems have five steps in common, which are carried out in sequence as follows;

- Fill
- React(aeration)
- Settle(sedimentation/clarification)
- Draw(decant)
- Idle

During the fill and react phase , the waste is aerated in the same fashion as an activated sludge unit. After the react phase , the Mixed Liquor Suspended Solids(MLSS) are allowed to settle. The treated supernatant is discharged during the draw phase. The idle stage, the time

between the draw and fill, may be zero or may be a few days depending on wastewater flow demand.

PERFORMANCE CHARACTERISTICS OF THE TECHNOLOGIES

| Item | WSP | UASB | ASP | SBR |
|--|-------------------------------------|--|--|---------------------------------------|
| BOD removal% | 75-85 | 75-85 | 85-92 | 98 |
| Nutrient Removal, %N | 40-50 | - | 30-40 | - |
| Nutrient Removal, %P | 20-60 | - | 30-45 | - |
| Coliform Removal, % | 60-99.9 | 99.99 | 99.99 after chlorination | 9.99 after chlorination |
| Land requirement, (ha per MLD) | 1.00 | 0.225 | 0.11 | 0.033 |
| Power requirement,(HP per MLD) | 2.5 | 3.25 | 11 | 9 |
| Sludge handling | Manual desilting once in 5-10 years | Directly dry on sludge drying beds or mechanical devices | First digest then dry on sludge drying beds or mechanical devices | Mechanical devices |
| Equipment requirement(except screening and grit removal which are require for all cases) | Nil | Nil(except gas collection and flaring; gas conversion to electricity is optional | Aerators, Recycle pumps, capers, Thickeners, Digestors,driers, Gas equipment | Aerators,PLC, Decanters, sludge pumps |
| Operational characteristics | Simplest | Simpler than ASP | Skilled operation is required | More skilled Personnel required |

TECHNOLOGY / PROCESS COMPARISON

| Description | WSP | UASB | ASP | SBR |
|-------------------------------------|---|--|--|---|
| Type of process | Aerobic suspended growth | Anaerobic suspended growth process | Aerobic suspended growth process | Aerobic suspended growth process |
| Principle of operation | Organic matter converted to new cell mass by natural process with the aid of sunlight algal growth photosynthesis | Organic matter is reduced by anaerobic bacteria present in the sludge | The organic matter is brought in contact with bacteria in suspension | Filling ,aeration, Settling and decanting carried out in a single or more tank in batches |
| Mode of oxygen supply | No external supply of oxygen is required | No oxygen supply is required | Oxygen is supplied by surface aerators | Oxygen is supplied by blowers through diffusers |
| Sludge recirculation in the reactor | Nor required | Not required | Sludge recirculation is necessary to maintain MLSS in aeration tank | Optional |
| Process variables | No monitoring natural process depends on temperature wind | Volatile fatty acids, sludge blanket levels,alkalinity,pH must be checked on daily basis | MLSS,SVI,F/M Ratio must be monitored sludge recycle and wastage should be controlled regularly | Oxygen requirement |

| Description | WSP | UASB | ASP | SBR |
|--|--|---|--|---|
| Cost for installation | Less, easy construction | Medium | Higher than UASB | High |
| Annual maintenance | Less, easy to maintain, skilled personnel not required | Slightly higher than WSP requires skilled personnel | High, requires technical and skilled personnel | Very high, high technical & skilled personnel required |
| Area requirement | Large area is required | Moderately large area required | Medium area | Small area |
| Power requirement | No power | Almost negligible power | Large power required | Large power requirement for aeration. Also power optimization |
| Total coliform content in treated sewage | 10^4 - 10^5 MPN/100ml | 10^4 - 10^5 MPN/100ml | 10^4 - 10^5 MPN/100ml | 10^3 - 10^4 MPN/100ml |
| Effluent quality | Meets the standard | Meets the standard | Very good quality | Best quality |
| Sludge production | Less | Medium | More | Medium |
| Methane production | Methane recovery is possible but no reference in India | Yes | Yes | No methane recovery |

2.20 TREATMENT SYSTEM SELECTION

Failures occur for a reason. The reason for failure should be determined before corrective actions are implemented; if not, failures can recur. The diagnostic procedure should be comprehensive, but based on deductive reasoning to avoid excessive testing and data gathering. Another example of a failure diagnosis, *Failure Analysis Chart for Troubleshooting Septic Systems* (FACTS). In addition to specific design boundary failures, failures can be caused by system age. Tanks and pipes buried in the ground begin to deteriorate after 20 or more years of use and may require repair or replacement. In addition, the treatment capabilities of soils below infiltration fields that have been in use for several decades might not be adequate for continued use. Years of treatment use can cause the interstitial spaces between soil particles to become filled with contaminants (e.g., TSS, precipitates, and biomass). Soil structure can also be affected after many years of use. Finally, changes in design and construction practices in the past 25 years have led to marked improvements in system performance and treatment capacity. These issues make consideration of system age a vital component of the overall failure investigation.

2.21 SUSTAINABILITY OF ANY PROJECT.

Special attention has to be given to the selection of appropriate technology either participatory approach. Appropriate technology must be:

- Cost-effective technology that provides adequate treatment
- Affordable in capital cost and operation and maintenance.
- Operable at a reasonable cost and with locally available labour.
- Reliable enough to consistently meet effluent quality requirements.

All the stake holders should be actively involved from the project formulation stage and technology selection process. Such a selection should be based on knowledge of capital investment, land requirement, energy consumption, treatment efficiency and reliability and operation and maintenance cost of different technological options used for treatment of wastewater.

2.22 CHOICE OF A TREATMENT SYSTEM

The choice of a treatment system depends on various other factors which can be grouped under three key words;

- Affordability
- Acceptability
- manageability

2.22.1 AFFORDABILITY

Affordability depends on the financial ability of the community to be served and the requirement of the process in terms of power and land requirements.

2.22.2 ACCEPTABILITY

Acceptability mainly depends on performance of the system. The acceptability generally depends on two groups of individuals:

1. The pollution control authorities who have to approve the treatment method proposal
2. The riparian public who have to live near the treatment facility.

2.22.3 MANAGEABILITY

This refers to both routine operations of the plant and its maintenance and repairs when needed.

2.23 FACTORS IN SELECTION AND DESIGN OF SEWAGE TREATMENT SYSTEM

The most important factors that should be borne in the mind before the selection and design of any sewage/wastewater treatment system are:(Sulabh Envis Newsletter,2007)

2.23.1 ENGINEERING FACTORS

- Design period, stage wise population to be served and expected sewage flow and fluctuations.
- Topography of the area to be served, its slope and terrain; tentative sites available for treatment plant, pumping stations and disposal works.
- Available hydraulic head in the system up to high flood level in case of disposal into a river or high tide level in case of coastal discharges.
- Groundwater depth and its seasonal fluctuations affecting construction, sewer infiltration.
- Soil bearing capacity and type of strata to be met in constructions
- On site disposal facilities, including the possibilities of segregating sullage and sewage
- And reuse or recycling of sullage water within the households.

2.23.2 ENVIRONMENTAL FACTORS

- Surface water, ground water and costal water quality where wastewater have to be disposed after treatment
- Odour and mosquito nuisance which affects land valves, public health and well being.
- Public health considerations by meeting the requirements laid down by the regularity agencies for effluent discharge standards, permissible levels of microbial and helminthic quality requirements and control of nutrients, toxic and accumulative substances in food chain.

2.23.3 PROCESS CONSIDERATIONS:

- Waste water flow and characteristics.
- Degree of treatment required.
- Performance characteristics.
- Availability of land, power requirements, equipments and skilled staff for handling and maintenance.

2.23.4 COST CONSIDERATIONS

- Capital costs for land, construction, equipments etc.
- Operating costs including staff, chemicals, fuels and electricity, transport, maintenance and repairs etc.

“Appropriate technology” can be defined as the technology that is affordable and operable by the user and that reliably provides the requirement treatment. Other criteria are that the technology be financially sustainable by the local community and use a holistic approach. “Sustainability and Waste water treatment” looks at wastewater treatment with a focus on environmental and cost appropriateness.

Choosing technologies for domestic waste disposal is a complex process involving many factors. To arrive at an appropriate technology for given community the cost-effective technology that provides adequate treatment and that the local community has the finances and skilled labour force to operate and maintain. Selecting the most appropriate technology for a given community requires an analysis for each community based on local factors and needs. The main factors in choosing a domestic wastewater treatment technology are water availability, presence of a collection system, housing or population density, availability of skilled management and operating personnel, land availability, availability and cost of power, receiving water requirements, hydrologic conditions and climate, and availability of opportunities for effluent reuse.

2.24 ECONOMICS OF TREATMENT TECHNOLOGIES/ METHODOLOGY FOR SELECTION

The following financial management tools are used for comparing the costs of various Sewage Treatment Technologies using net present value (NPV), internal rate of return(IRR), and benefit-cost ratio(BCR) calculations.

2.24.1 Annual Cash Flow Projections

Cash flows are the expenditures made and revenues received during the lifetime of a technology. By computing annual expenditures and revenues, a year-by-year cash flow projection is established.

2.24.2 Net Present Value or Present worth Method


This method uses compound interest factors to compound or discount all cash flows. Sewage Treatment technologies are then ranked by comparing the equivalent values at time zero of each alternative using the same interest rate and equipment lifetime. Net present value (NPV) is calculated as the difference between benefits and the discounted costs. The technology with the highest present worth is the best technology from an economic standpoint.

2.24.3 Capitalist Cost or Life Cycle Cost Method

In this method, the present worth of a technology assuming an infinite life is compound, i.e., the capitalized cost is the initial cost plus the present value of an infinitely lived technology. The technology with the lowest capitalized cost is the best technology from an economic standpoint.

2.24.4 Internal rate of return

The internal rate of return (IRR) is the discount rate which equalizes the present values of costs/expenditures and revenues, i.e., the value at which the $NPV=0$



2.24.5 Return on Investment Method

The return on investment (ROI) is the ratio of annual profits to original investment. This may be used to compare the savings from Sewage Treatment technologies in relation to unknown

costs. This method does not account for the time value of money and other factors. The technology with the highest ROI is the best technology from an economic standpoint

2.24.6 Benefit cost ratio

It is the ratio of the total present value of benefits to the total present value of expenditures of any project. It should be greater than one. The benefit cost ratio (BCR) is calculated as:

$$\text{BCR} = \frac{\text{Present value of benefits}}{\text{Present value of expenditures}}$$

The technology with higher the Benefit cost ratio is the best technology from an economic standpoint.

COST CALCULATIONS

Land Area required;

| | | |
|------------------------|---------------------------------------|----------------------|
| Land required for SBR | $= (55 \times 25) - (7 \times 5)$ | $= 1340 \text{ m}^2$ |
| Land required for ISF | $= 60 \times 50$ | $= 3000 \text{ m}^2$ |
| Land required for WSP | $= (80 \times 86.5) - (22 \times 38)$ | $= 6084 \text{ m}^2$ |
| Land required for MASP | $= 50 \times 40$ | $= 2000 \text{ m}^2$ |

Land cost;

| | | |
|--------------------------------|-----------------------|--------------------------|
| Cost of land (1m^2) | $= \text{Rs.}15000$ | |
| Land cost for SBR | $= 1340 \times 15000$ | $= 201.00 \text{ lakhs}$ |
| Land cost for ISF | $= 3000 \times 15000$ | $= 450.00 \text{ lakhs}$ |
| Land cost for WSP | $= 6084 \times 15000$ | $= 912.60 \text{ lakhs}$ |
| Land cost for MASP | $= 2000 \times 15000$ | $= 300.00 \text{ lakhs}$ |

Energy cost for SBR;

| | | |
|--|----------------------------------|----------------------------------|
| Energy required for 3 HP pump (1No) | $= 3 \times 0.746 \times 12$ | $= 26.86 \text{ kW}$ |
| Energy required for Blower | $= 15 \times 4 \times 2$ | $= 120.00\text{kW}$ |
| Energy required for effluent pump | $= 10 \times 0.746 \times 2$ | $= 14.92 \text{ kW}$ |
| Energy required for sludge disposal | $= 1 \times 0.746 \times 2$ | $= 1.49 \text{ kW}$ |
| Energy required for lighting | $= 0.240 \times 12$ | $= 2.88 \text{ kW}$ |
| Total Energy required for SBR (1 day) | | $= 166.15\text{kW}$ |
| Current Energy cost for 1 kW | | $= \text{Rs.}3.5$ |
| Energy cost for 1 year | $= 166.15 \times 365 \times 3.5$ | $= \text{Rs.}2.12 \text{ lakhs}$ |

Energy cost for ISF;

| | | |
|---------------------------------------|---------------------------------------|-----------------------------------|
| Energy required for 3 HP pumps(2 Nos) | $= 2 \times 3 \times 0.746 \times 24$ | $= 107.42 \text{ kW}$ |
| Energy required for lighting | | $= 2.88 \text{ kW}$ |
| Total Energy required for ISF (1 day) | | $= 110.3 \text{ kW}$ |
| Current Energy cost for 1 kW | | $= \text{Rs.}3.5$ |
| Energy cost for 1 year | $= 110.3 \times 365 \times 3.5$ | $= \text{Rs.}1.409 \text{ lakhs}$ |

Energy cost for WSP;

| | | |
|---------------------------------------|---------------------------------------|------------------|
| Energy required for 1 HP pump(2 Nos) | = $2 \times 1 \times 0.746 \times 24$ | = 35.81kW |
| Energy required for lighting | | = 2.88 kW |
| Total Energy required for WSP (1 day) | | = 38.69 kW |
| Current Energy cost for 1 kW | | = Rs.3.5 |
| Energy cost for 1 year | = $38.69 \times 365 \times 3.5$ | = Rs.0.494 lakhs |

Energy cost for MASP;

| | | |
|--|-----------------------------------|-----------------|
| Energy required for 25HP pump | = $25 \times 0.746 \times 24$ | = 447.6 kW |
| Energy required for 5HP pump | = $5 \times 0.746 \times 20$ | = 74.6 kW |
| Energy required for 15 HP pump | = $15 \times 0.746 \times 4$ | = 44.76kW |
| Lighting etc., | = $16 \times 60 \times 12 / 1000$ | = 11.52 kW |
| Total Energy required for MASP (1 day) | | = 578.48kW |
| Energy cost for 1 year | = $578.48 \times 365 \times 3.5$ | = Rs.2.11 lakhs |

BACKGROUND OF THE STUDY AREA

3.1 STUDY AREA

The study area here selected is ward number 45 of “Ambattur” Municipality which is one among the 16 municipalities in Chennai Metropolitan Area (CMA) located in Thiruvellore District. Ambattur is designated as special grade Municipality and lies north of Chennai with an extent of 40.36 sq.km, bearing 52 numbers of wards and 2526 number of streets to the total length of 554.64 KM housing 70212 numbers of buildings of which 63991 residential building 1610 industrial building 4570 commercial and 41 institutions. This municipality itself possessing 75 own buildings. Ambattur is famous for its Industrial area.

3.1.1 LOCATION

The terrain of the Municipality has a gentle slope west to east ranging from +5.82m to +18m (MSL). On the North, the Municipality is bounded by Madavaram Municipality, on the East Chennai City and in the South by Nolambur and Nerkundram Village Panchayat and in the west by Thiruverkadu Municipality and Avadi Municipality. There are two lakes namely Korattur Eri and Ambattur Lake within the Municipality. RedHills lake also forms part of this Local Body.

3.1.2 DETAILS OF STUDY AREA

Of the 52 wards, 13 wards are falls under unsewered area. From the unsewered 13 wards, ward number 45 has been selected as study area since this area is very adjacent to Chennai City, apart from that, Chennai Metropolitan Water Supply and Sewerage Board(which is responsible to promote or secure the planned development, efficient operation, maintenance and effective regulation of water supply and sewerage systems in the Chennai Metropolitan

Area.) maintain this area for water supply. The area is low lying area and almost well developed, the provision of sewer system is must in order to upkeep the environment safe and sustainability.

The area is a mixture of residential, markets and industrial sector having 39 streets to the total length of 8273 meters with population of 5047 as per 2001 census. Of the 5047 population 2571 are male & 2476 female and the projected population is worked out to 10700. It does not possess sewerage system.

3.1.3 SOIL

Generally it is observed that the top soil upto 1.5 m is brownish silty sand further clay mixed with sand and clay upto 3m. From 3m to 6m it is found to be fine to medium sand and in some locations black soft clay / loose silty clay.

3.1.4 ECONOMIC BASE

Ambattur is famous for its industrial area. Apart from big and medium size industries like T.I Group, LOCAS- TVS Group Industries, BRITANIA food Industries, SIDCO Industries also there. People living in this area are working and business oriented. Production, products selling, exporting are good revenue to this Ambattur Municipality.

3.1.5 WATER SUPPLY

The ward water supply is being maintained by Chennai Metropolitan Water Supply and Sewerage Board (which is responsible to promote or secure the planned development, efficient operation, maintenance and effective regulation of water supply and sewerage systems in the Chennai Metropolitan Area.), Water is being supplied to this Ward at the rate of 110 lpcd.

3.2 NEED OF SEWERAGE SYSTEM

The area has not been provided with sewerage system. People are very eager in Sewerage system and willing to contribute the amount, for providing Sewerage facilities to their areas. Since the area has been developed to its capacity and the area is low lying and is not ease with economic cost to include the area into the Chennai City Sewerage net work. Hence the only solution to go for DEWAT system for upkeeping the area for hygienic at economic cost with sustainability.

3.3 POPULATION FORCAST AND SEWAGE GENERATION FOR WARD 45

From the town planning it has been obtained that the population decade growth is 30%. As per 2001 Census records this ward population is 5047.

Base population that is present population (2008) is $5047 + [0.7 \times (30 / 100) \times 5047] = 6107$

Projected Population at 2038 is $[3.7 \times (30 / 100) \times 5047] + 5047 = 10649 \approx 10650$

Sewage generation is 80% of water supplied.

Water supply is 110 lpcd.

Accordingly Sewage Generation is $0.9 \times 100 \times 10650 = 958500$ say 1mld.

3.4 ZONING OF SEWERAGE SYSTEM

According to the nature of topography and the level, the Ward has been divided into three (3) Zones. The details of the Zones are given below.

3.4.1 DETAILS OF ZONE I

Zone I represents the Northern part of ward 45. This Zone contains 11 streets to a total length of 3280m and 388 houses with a population of 1900. The full details of Zone I of ward 45 are shown in the table

All the houses in this Zone already have septic tank without dispersion trenches. Hence frequent removal of waste water is being carried out by mobile sewage lorries. There is also

frequent occurring of water pollution and local wells are also polluted. Hence for safe and hygienic with sustainable environment, this Zone must be provided sewerage system. At present this ward could not be connected to the Chennai city sewerage network system provision of DEWAT system is finalized.

Among the DEWAT system, Septic Tank (ST) with Sequencing Batch Reactor (SBR) has been selected for treatment of waste water for this Zone. The details of sewage generation are worked out below.

3.4.1.1 Sewage Generation For Zone I

Population in the year 2001 for Zone I = 1900.

Base population (2008) = $(0.7 \times 0.3 \times 1900) + 1900 = 2299$


Projected population (2038) = $(3.7 \times 0.3 \times 1900) + 1900 = 4009$

Sewage Generation = $0.9 \times 100 \times 4009 = 360810 \approx 3.61$ lakh litres

Say 4 lakh litres

Now designed for 4 lakh litres for easy of comparison of Techno Economic of DEWAT system.


The collection and treatment unit location for this Zone is shown in the fig below:




- ZONE - I
- ZONE - II
- ZONE - III
- TRUNK MAINS
- STREET SEWER

SCALE : 1 CM = 30 M

ZONE-I



ZONE-II



ZONE-III

TITLE: PROVIDING DEWAT SYSTEM TO
WARD No : 45 OF AMBATTUR MUNICIPALITY

Table 3.1 The collection and treatment unit location for Zone I

| S.No | Name of the street | Nature of Road | Road | | No of Houses | Population |
|------|---------------------------|----------------|-------------|-----------|--------------|-------------|
| | | | Length (m) | Width (m) | | |
| 1 | Magathma Gandhi Main Road | BT | 850 | 6 | 140 | 700 |
| 2 | V.O.C Street | BT | 250 | 5 | 18 | 90 |
| 3 | Sardar Patel Street | BT | 155 | 5 | 20 | 100 |
| 4 | Thiruvalluvar street | BT | 160 | 4 | 15 | 75 |
| 5 | Dr.Radhakrishnan Street | BT | 190 | 4 | 14 | 70 |
| 6 | Jawaharlal Nehru Street | BT | 210 | 5 | 32 | 160 |
| 7 | Rajaji Street | BT | 230 | 5 | 31 | 115 |
| 8 | Thilagar Street | BT | 195 | 4 | 17 | 85 |
| 9 | Kamber Street | BT | 350 | 4 | 16 | 80 |
| 10 | Nethaji Street | BT | 280 | 5 | 31 | 155 |
| 11 | Kamarajar Street | BT | 410 | 5 | 54 | 270 |
| | | Total | 3280 | | 388 | 1900 |

3.4.2 DETAILS OF ZONE II

Zone II represents the central part of ward 45. This Zone contains 17 streets to a total length of 3240m and 355 houses with a population of 2068. The full details of Zone II of ward 45 are shown in the table

As in the Zone I, all the houses in this Zone II too have septic tank without dispersion trenches. Hence frequent removal of waste water is being carried out by mobile sewage lorries. There is also frequent occurring of water pollution and local wells are also polluted. Hence for safe and hygienic with sustainable environment, this Zone must be provided sewerage system. At present this ward could not be connected to the Chennai city sewerage network system provision of DEWAT system is finalized.

Among the DEWAT system, Septic Tank (ST) with Intermittent Sand Filter (ISF) has been selected for treatment of waste water for this Zone. The details of sewage generation is worked out below.

3.4.2.1 Sewage Generation For Zone II

| | |
|---|---|
| Population in the year 2001 for Zone II | = 2068 |
| Base population (2008) | = $(0.7 \times 0.3 \times 2068) + 2068 = 2502$ |
| Projected population (2038) | = $(3.7 \times 0.3 \times 2068) + 2068 = 4364$ |
| Sewage generation | = $0.9 \times 100 \times 4364 = 392760 \approx 4$ lakh litres |

The collection and treatment unit location for this Zone is shown in the fig below

The Flow Chart for the Zone II treatment is shown below

Table 3.2 The collection and treatment unit location for Zone II

| S.No | Name of the Street | Nature of Road | Road | | No of Houses | Population |
|------|------------------------------|----------------|------------|-----------|--------------|------------|
| | | | Length (m) | Width (m) | | |
| 1 | Kattabomman Street | BT | 260 | 4 | 16 | 80 |
| 2 | Tr-Vi-Ka Street | BT | 190 | 5 | 24 | 120 |
| 3 | Rajendra Prasad Street | BT | 220 | 5 | 22 | 110 |
| 4 | Manickavasagar Street | BT | 260 | 5 | 20 | 100 |
| 5 | Rajarajacholan Street | BT | 250 | 5 | 24 | 120 |
| 6 | Vivekanandhar Street | BT | 180 | 3 | 16 | 80 |
| 7 | Thiruvalluvar Street | BT | 220 | 4 | 22 | 110 |
| 8 | Bharathiyar Street | WBM | 190 | 4 | 21 | 120 |
| 9 | Vasantham Street | WBM | 185 | 5 | 16 | 120 |
| 10 | Thendral Street | WBM | 260 | 5 | 43 | 315 |
| 11 | Kurinji Street | WBM | 195 | 5 | 20 | 125 |
| 12 | Pillayar Koil Street | WBM | 160 | 5 | 23 | 115 |
| 13 | 1 Cross Street | WBM | 200 | 5 | 9 | 120 |
| 14 | 2 nd Cross Street | WBM | 90 | 5 | 6 | 96 |

| | | | | | | |
|----|-------------------------------|--------------|-------------|---|------------|-------------|
| 15 | 3 rd Cross Street | WBM | 100 | 5 | 12 | 75 |
| 16 | Mullai Street | WBM | 180 | 5 | 25 | 142 |
| 17 | Mullai 1 st Street | WBM | 100 | 5 | 16 | 120 |
| | | Total | 3240 | | 335 | 2068 |

3.4.3 DETAILS OF ZONE III

Zone III represents the Southern part of ward 45. This Zone contains 11 streets to a total length of 1753m and 232 houses with a population of 1079. The full details of Zone III of ward 45 are shown in the table

Here also all the houses in this Zone already have septic tank without dispersion trenches. Hence frequent removal of waste water is being carried out by mobile sewage lorries. There is also frequent occurring of water pollution and local wells are also polluted. Hence for safe and hygienic with sustainable environment, this Zone must be provided sewerage system. At present this ward could not be connected to the Chennai city sewerage network system provision of DEWAT system is finalized.

Among the DEWAT system, Septic Tank (ST) with Waste Stabilization Pond (WSP) has been selected for treatment of waste water for this Zone. The details of sewage generation is worked out below.

3.4.3.1 Sewage Generation For Zone III

Population in the year 2001 for Zone III = 1079

Base population (2008) = $(0.7 \times 0.3 \times 1079) + 1079 = 1305$

Projected population (2038) = $(3.7 \times 0.3 \times 1079) + 1079 = 2277$


Sewage generation = $0.9 \times 100 \times 2277 = 204930 \approx 2.0$ lakh litres

The collection and treatment unit location for this Zone is shown in the fig below







The Flow Chart for the Zone III treatment is shown below:

Table 3.3 The collection and treatment unit location for Zone III

| S.No | Name of the Street | Nature of Road | Road | | No of Houses | Population |
|------|--------------------------------------|----------------|-------------|-----------|--------------|-------------|
| | | | Length (m) | Width (m) | | |
| 1 | Amman Koil Street | BT | 190 | 5 | 22 | 105 |
| 2 | Anna 1 st Street | BT | 133 | 4 | 12 | 60 |
| 3 | Anna 2 nd Street | BT | 120 | 4 | 10 | 50 |
| 4 | Ambedkar Street | BT | 135 | 4 | 22 | 150 |
| 5 | Jawahar Street | BT | 230 | 4 | 24 | 104 |
| 6 | V.O.C Street | BT | 130 | 4 | 24 | 110 |
| 7 | Gandhi Street | BT | 180 | 4 | 14 | 70 |
| 8 | Kumaran Nagar 1 st Street | WBM | 175 | 6 | 24 | 100 |
| 9 | Kumaran Nagar 2 nd Street | WBM | 160 | 6 | 31 | 95 |
| 10 | Kumaran Nagar 3 rd Street | WBM | 120 | 6 | 24 | 110 |
| 11 | Kumaran Nagar 4 th Street | WBM | 180 | 6 | 25 | 125 |
| | | Total | 1753 | | 232 | 1079 |



LEGEND

-  - ZONE - I
-  - ZONE - II
-  - ZONE - III
-  - TRUNK MAINS
-  - MAIN SEWER
-  - STREET SEWER

SCALE : 1 CM = 30

TITLE: PROVIDING DEWAT SYSTEM TO
WARD No : 45 OF AMBATTUR MUNICIPALITY

RESULT AND DISCUSSION

4.1 DATA COLLECTION AND ANALYSIS

Data collection is an important function for any work, based on which one can do further analysis from which good decision can be drawn. Hence intensive care has been taken in collecting the data from various authentic authorities.

4.1.1 DESIGN CRITERIA

For the selection and design criteria for any STPs, the following data's are very important and as such they have been collected from Ambattur Municipalities.

- Population
- Quantity of water supply and wastewater generation.
- Wastewater characteristics such as BOD, COD, TSS, TDS, Heavy water, Faecal coliform, Nitrate, Sulphate, etc.
- Quality of land
- Level of Treatment
- Effluent disposal to land or water bodies
- Drainage pattern and slope
- Wind direction
- Temperature
- Rainfall details
- Type of soil and geology
- Ground water Table level
- Climatic conditions
- Location details
- Industries

Most of the data are secondary in nature and obtained from the Municipality and other Government departments.

4.2 TECHNOLOGY FOR ANALYSIS

The following DEWATs have been considered and analyses were made among them along with Centralised treatment system also.


DEWATs considered

- For Zone I – SBR
- For Zone II – ISF
- For Zone III- WSP


For centralized treatment system, Modified Activated Sludge Process (MASP) has been adopted.

Table 4.1 Performance Characteristics of the Technologies


| SI No | Description | SBR | ISF | WSP | MASP |
|-------|--------------------------------------|--------------------------------|--------|----------|----------------------------|
| 1 | BOD Removal % | 96 | 93 | 92 | 92 |
| 2 | Land Requirement, (hectare / 0.4mld) | 0.134 | 0.300 | 0.880 | 0.200/mld |
| 3 | Power Requirement, (kW per 0.4 mld) | 166.15 | 110.30 | 2.5 | 567.0 |
| 4 | Operational Characteristics | More skilled personal required | Simple | Simplest | Skilled operation required |





GENERAL ARRANGEMENT OF STP (SB REACTOR)
FOR ZONE - I - WARD 45, AMBATTUR MUNICIPALITY



FLOW DIAGRAM OF SBR TREATMENT PLANT
 FOR ZONE - I - WARD 45, AMBATTUR MUNICIPALITY




SCHMATIC DIAGRAM OF SAND FILTER TREATMENT PLANT
FOR ZONE - II - WARD 45, AMBATTUR MUNICIPALITY.



GENERAL ARRANGEMENT OF SAND FILTER
FOR ZONE - II - WARD 45 AMRATTUR MUNICIPALIT

PLAN




FLOW DIAGRAM OF 0.2 MID WASTE STABILISATION PONDS

FOR ZONE III, WARD NO.45

AMBATTUR MUNICIPALITY

50

40



LAYOUT OF 1 Md CAPACITY
MODIFIED ACTIVATED SLUDGE
TREATMENT PLANT FOR WARD NO:46
AMBATTUR MUNICIPALITY

Table 4.2 Technology Process Comparison

| SI No | Description | SBR | ISF | WSP | MASP |
|-------|-------------------------------|--|---|--|--|
| 1 | Types of process | Aerobic suspended growth | Aerobic attached growth | Aerobic suspended growth process | Aerobic suspended growth |
| 2 | Peaceful of operation | Filling, aeration decanting and settling carried out in a single or more tank in batches | Organic matter is reduced by the fixed film biological Filter | Organic matter converted to new cell mass by natural process with the aid of sunlight algal growth photo | The organic matter is brought in contact with bacteria in suspension |
| 3 | Mode of O ₂ supply | O ₂ is supplied by blowers through diffusers | No external supply of O ₂ is required | No external supply of O ₂ is required | O ₂ is Supplied by surface aerator |
| 4 | Cost for installation | High | Slightly higher than WSP | Less, Easy construction | High |
| 5 | Annual Maintenance | Very high, High technical & skilled personnel required | Higher than the WSP, More skilled personnel not required | Less, easy to maintain, Skilled personnel not Required | High, Requires technical and skilled personnel required |
| 6 | Area Required | Small area required | Area required higher than the SBR, but lesser than WSP | Large area is required | Medium area |
| 7 | Power Requirement | Larger power Requirement for aeration. Also, power optimization | Less power | Less power | Large Power required |

| | | is conducted by PLC | | | |
|----|--|------------------------|---------|---|---------------------|
| 8 | Total Coliform content in treated sewage | - | - | 99% | - |
| 9 | Effluent Quality | Very good quality | Good | Best | Very good quality |
| 10 | Expandability | Easy | Limited | Higher loads possible by producing aeration | Limited |
| 11 | Moving Parts | High | Nil | Nil | High |
| 12 | - | - | - | Less | Moderately sensible |

4.3 LIFE CYCLE COST ANALYSIS

The design of DEWATs for each Zone as said above has been made. The estimate for each system has been prepared with current schedule of rate year 2008-09 of Chennai Metropolitan Water Supply and Sewerage Board (CMWSSB), Tamilnadu water supply and Drainage Board (TWAD Board). The cost of construction for Zone I that is 0.4 mld capacity of SBR, for Zone II that is 0.4 mld capacity of ISF and for Zone III that is 2.0 mld capacity of WSP has been tabulated. For comparison purpose, separate construction cost for 0.4 mld WSP has been prepared. Since the proportional rate techniques could not be adopted due to non proportional varying size of unit and materials etc.


The annual operation and Maintenance charge were calculated based on the Energy cost, Manpower cost, Repair & Maintenance cost. Careful (accurate attention is needed in the calculation of Annual Maintenance cost as it is highly sensitive in technology selection in the Life Cycle Cost analysis. The Life Cycle Cost for both DEWATs & Centralized technology has been calculated by the following method.

Life Cycle Cost for 30 years = Capital cost including land cost + Present worth of Annual maintenance cost for 30 years at the rate of 10%

For calculating the present worth Annual maintenance cost for 30 years @ 10% the annuity factor has been calculated as 0.10607. By dividing the annual maintenance cost by the annuity

factor, the capitalized cost of O & M is obtained. With this amount the capital cost is added, the total cost will be arrived; with this total cost land cost is added for getting Life cycle Cost.


The Life Cycle Cost for each technology for various land cost has been worked out and tabulated in the Table No-----, With the tabulated values the Life Cycle Cost Vs Land cost has been plotted and the graph has been drawn. From the Graph, it is noted that, with out land cost, the WSP found out opt technology for DEWAT. Next lowest is ISF and the high cost technology is SBR. When land cost is considered SBR is opt technology and high cost is WSP, and the intermittent is ISF.



The O&M cost for each technology has been worked out and the component cost has been shown in the bar chart.

Table: 4.3 Ambattur Municipality Ward 45 Land Cost & O &M Details

| Sl.No. | Treatment System | Land Required | Project Cost | O&M Cost | Capitalised Cost of O&M | Total Cost | Land Cost @500 | Land Cost @1000 | Land Cost @1500 | Land Cost @2000 |
|--------|------------------|---------------|--------------|----------|-------------------------|------------|----------------|-----------------|-----------------|-----------------|
| | | ha | Lakhs | Lakhs | Lakhs | Lakhs | Lakhs | Lakhs | Lakhs | Lakhs |
| 1 | SBR | 0.134 | 26.88 | 5.00 | 47.14 | 74.02 | 141.02 | 208.02 | 275.02 | 342.02 |
| 2 | ISF | 0.300 | 23.23 | 3.88 | 36.58 | 59.81 | 209.80 | 359.80 | 509.80 | 659.80 |
| 3 | WSP | 0.880 | 19.6 | 2.23 | 21.02 | 40.62 | 480.62 | 920.62 | 1360.62 | 1800.62 |
| 4 | MASP | 0.200 | 56.51 | 16.90 | 159.33 | 215.84 | 315.84 | 415.84 | 515.84 | 615.84 |



4.4 Comparison of DEWAT & Centralized Collection System

Considering DEWAT collection system for all the three Zones, small bore pipes that are capable of carrying the sewage has been used and cost has been worked out as 21.90 lakhs. Whereas Centralized conventional cost is 141 lakhs i.e 6.5 times higher than the DEWATs system which clearly indicate the DEWATs system adopt less pipe cost where as in Centralized collection system, pipe cost is almost 60% of the total cost of the project. Actually the pipe never treat the wastewater.

4.5 Comparison of DEWAT & Centralized System with out Land Cost

For comparison purpose, all the three Zone DEWAT system has been considered as one that is 0.4 mld+0.4 mld+0.2mld totaling to 1mld and this is compared with the Centralized MASP 1mld capacity. As such it is noted that without land cost, DEWAT systems capital and collection system is worked as 87.01 lakhs [capital cost(26.88+23.23+15.00) + collection cost(21.90)] where as for Centralized 1mld MASP is worked out 197.51 [capital cos(56.51)+ collection cost(141.0)], which is 2.3 times higher than the DEWAT system.

CONCLUSIONS

In providing sewerage facility for ward 45 of Ambattur Municipality which is adjacent to Chennai Mega City area, 3 (Three) DEWATS Technology namely Sequential Batch Reactor (SBR), Intermittent Sand Filter (ISF) and Waste Stabilization Pond (WSP) have been analysed. From the analysis the following conclusion arrived.

1. In view of adjacent area of Chennai Mega City, the land cost also going very high. Hence the compact technology, occupying less space of Sequential Batch Reactor. Also level of treatment in the SBR also high, the effluent can be directly sold out to adjacent industries where the demand is high, since Ambattur is famous for Industrial area.
2. Even though the traditional DEWATS system namely, Waste Stabilisation Pond (WSP) treatment performance is better, but in view of high land cost the technology is not recommended for adjacent Chennai City area. If the land is available with the municipality or at subsidized rate then this technology WSp can be considered for the adjacent Chennai area.
3. Intermittent Sand Filter (ISF), technology requires cost wise lies midway is between the two technologies namely WSP and SBR. Due to not compact size and treatment level also not to that of SBR this technology also not recommended to the adjacent Chennai City area.
4. The benefits of smaller dia pipes and not land in-depth getting also reaping the benefit of 3 R's (Reduce, Reuse and Recycle) and thereby attaining the goal of "Sustainable sanitation for all", the DEWATS system is opt. Hence, for the ward 45 of Ambattur Municipality the technology SBR is strongly recommended.
5. From the, 'Life Cycle Cost analysis verses Land Cost Curve', it is concluded that at one point the technologies namely ISF and MASP is coinciding. Hence Careful analysis of land cost has to make. Since it bears a high sensitive factor is deciding the best technology that is opt for adjacent area of Chennai City.

REFERENCES

- [1] Metcalf & Eddy, 'Wastewater Engineering Treatment and Reuse', Fourth edition ,Tata McGraw-Hill Publishing Company Limited ,New Delhi *PP* 1044-1098
- [2] Ambattur municipality Chennai Metropolitan Area (CMA), 'Detailed Report for Under Ground Sewerage System'(2007)*PP* 7-30
- [3] Bremen Overseas Research and Development Association'DEWATS-Decentralized Wastewater Treatment Systems'(2007)*PP*4-5
- [4] Stone Environmental Inc Technology Choices for Developers and Subdividers in Non Sewered Areas NA 17022336 (2004) *PP* 105-109
- [5] Eaway,Aquatic Research Centre ,'Decentralized Wastewater Treatment (DEWAT) Gray Water Management In Low And Middle-Income Countries Review Of Different Systems For Households Or Neighborhoods' New Publication 116:*PP* 50-55
- [6] Dale Galassie, M.A., M.S.Executive Director(2005) Environmental Health Services,'Individual Sewage Disposal Program' *PP* 847-984
- [7] J.Bones et all ,'Institute of Water Supply and Environmental Protection', Cracow University of Technology, Poland Pergamon Wat.Sa,Tech.vol.40,No.4-5,*PP* 451-458
- [8] R.Annadurai and Dr.A.Navaneetha Gopalakrishnan, Centre for Environmental Studies,Anna University,Technial News letter,June2007 *PP*36
- [9] Machenzie L.Davis, David A.Cornwell, 'Introduction to Environmental Engineering' second Edition,McGraw-Hill,Inc.New Delhi *PP* 310-413
- [10] K.Balasubramanian Executive Engineer, Chennai MetroWater, TamilNadu (2006) Project Report on 'Performance Evaluation of Septic Tank in use and Suggesting improvements *PP* 1-28
- [11] CPHEEO, 1993, 'Manual on sewerage and Sewage treatment', Ministry of Urban Development, New Delhi.
- [12] Arceivala, S.J. and Asolekar, S.R.(2007), Wastewater Treatment for Pollution Control and Reuse, Tata McGraw-Hill New Delhi.
- [13] Manual for Training programme on Design and Construction of Sewerage Systems, 2004, Centre for Environmental Studies, Anna University, Chennai, TamilNadu.

- [14] Li Xian- wen, 1995, Technical Economic Analysis of Stabilization Ponds, Water Science and Technology, vol. 31, No.12, *PP 103-110*.
- [15] Hernandez- Sancho, F. and Sala-Garrido,R.,(2006), Economic and Technical efficiency of wastewater plants; A basic requisite to the feasibility of water reuse projects. Integrated Urban Water Resources Management, *PP 219-230*.
- [16] Arthur,J.P., 1983, Notes on the Design and Operation of Waste Stabilization Ponds in warm climates of Developing Countries, Technical paper No.7, Washington,Dc: The World Bank.
- [17] Design Manual for Waste Stabilization Ponds in India,(1997), issued by National River Conservation Directorate, Ministry of Environment and Forest, Government of India.
- [18] Tripathi, R.K., Vidyarthi, A.K.,Jain, R.K, 1996, Development of Generalized Cost function and Economic selection criteria for domestic wastewater treatment system, Journal of the Institution of Engineers(India), vol,77, August, *PP 1-6*.
- [19] Srinivasan, S.V. Ravindranath, E, Rajamani, S. Life cycle consideration for Selection Of Wastewater Treatment Alternatives, Department Of Environmental Technology, Central Leather Research Institute, Adayar,Chennai, TamilNadu, India.
- [20] Pannirselvam.R., Navaneetha Gopalakrishnan,A., (2005), principal of Environmental Science and Engineering, SGPS Publisers,Chennai TamilNadu, India.
- [21] Pannirselvam.R.,(2004) Environmental Engineering, Volume II Sewerage and Sewage treatment SGPS Publisers,Chennai-600 088 TamilNadu, India.
- [22] Pannirselvam.R.,(2007) Design Hand Book for Public Health Engineers, SGPS Publisers,Chennai-600 088 TamilNadu, India.
- [23] Refresher course on Execution of Sewerage Schemes, TWAD Board, Training Centre, Chennai, TamilNadu, India.
- [24] Kannan.S, (2007), 'Selection and Appropriate STP Technology For A Town In Tamilnadu'-Dissertation Work,AHEC,IIT, Roorkee,-247 667 India.
- [25] P.N. Khanna,(1994), 'Indian Practical Civil Engineers', Hand Book. New Delhi, India.
- [26] U.S. Environmental Protection Agency, Response to Congress on, 'Use of Decentralized Wastewater Treatment System', EPA 832-R-97-001B Washinton, DC.Office of Wastewater Management, April 1997.

- [27] U.S Environmental Protection Agency ,'Onsite Wastewater Treatment System Manual',EPA 625-R-00-008,Cincinnati,OH:U.S EPA Publication Clearing House, 2002.<http://cfpub.epa.gov/own/septic/guidelines.cfm#7489>
- [28] U.S Environmental Protection Agency ,'Voluntary National Guide Lines for Management of Onsite and cluster (Decentralized) Wastewater Treatment Systems',EPA 832-B-03-001,Cincinnati,OH:U.S.EPA Publication Clearing House March.2003
- [29] Burks,B.D ,and M.M.Minnis,Onsite Wastewater Treatment System
- [30] Crites,R, and G.Tchobanoglous,'Small and Decentralized Wastewater Management System'.Boston: WCB/McGraw –Hill Companies,Inc.,1998
- [31] G.Tchobanoglous, and F.L.Burton, Wastewater Engg: Treatment, Disposal and Reuse, 3rd Ed.New York: McGraw-Hill Companies,Inc.,1991
- [32] Viessman.W.,Jr. and M.J.Hammer.,' Water supply and Pollution Control',6th Ed 1998,Addison-Wesley,Inc.,Meno Park,CA
- [33] The Environmental Understanding Septic Tank Systems, Environment Health Guide,Health Department of Western Australia 6/1999
- [34] Septic tank-Wikipedia; the free encyclopedia. [http://en.wikipedia.org/wiki/septic tank](http://en.wikipedia.org/wiki/septic_tank).
- [35] Standard Schedule of Rates for the Year 2008-2009,Chennai Metropolitan Water Supply and Sewerage Board.
- [36] Er.M.Muthupandia,Former Chief Engineer,TWAD Board(2007),Alternative Technology Options for Underground Sewerage Schemes Strategy and Action Plan-News Letter June:2004
- [37] Chennai Metropolitan Water Supply And Sewerage Board, 'Standard Schedule of Rates for the year 2008-2009'.
- [38] Kazmi.A.A, Dept,of Civil Engineering Indian Institute of Technology Roorkee, (Uttaranchal),(2005), 'Detailed Project Report for GangaNager Colonies Sewage Treatment Plant (Sequencing Batch Reactor)', MEERUT,
- [39] American Public Health Association (APHA), American Water Works Association (AWWA), Water Environment Federation, 1995. International Standard Methods for the Examination of Water and Wastewater, 19th Edition, Washington D.C.
- [40] Chennai Metropolitan Water Supply and Sewerage Board (CMWSSB), 'Sewage Treatment Plants Project Report 2006-2007

- [41] Suresh Kumar,D.(2007), 'Resource Recovery From Sewage Treatment plants (STPs)' dissertation Work, AHEC, IIT Roorkee, India.
- [42] Kurian Joseph, Technical article (2006) 'Decentralized Wastewater treatment Systems',Everthing About Water, October, 2006.
- [43] Extensive Wastewater Treatment processes, Adapted to Small and Meadium Sized Communities, May 1991.Europian Commission.
- [44] U.S. Environmental Protection Agency, 'Decentralized Wastewater Treatment Systems', January 21st, 2007. Web site: [http://C%3A/Documents% 2520 and % 2520 Settings/Administrator/ Desktop/ dwwts/htm](http://C%3A/Documents%202520and%202520Settings/Administrator/Desktop/dwwts/htm)
- [45] Anish R. Jantrania,Mark A.Gross, 'Advanced Onsite Wastewater Systems Technologies', Taylor & Francis Group, Boca Raton London New York.
- [46] H.Subramaniam, (2004), 'The filtration spectrum', Everything about Water, July-August 2004, *PP 18-22*.
- [47] Pitchai R, Govindan V.S,(1988), 'Biological Processes in Pollution Control', Centre for Environmental Studies, College of Engineering,Guindy campus, Anna University, Chennai TamilNadu, India.
- [48] Public Health and Sanitation, 'For sanitary Inspectors' and Para Medical Workers part I & II, Educational Complex at Mumbai, The All India Institute Of Local Self- Government, Anderi (West), Mumbai.
- [49] Ghatbandhe,S.,(2007), 'Technologies in Removing Pollutants from Wastewater', Everyman's science vol. XLII No. I, April-May 2007 *PP 19-24*.
- [50] Rao Bhamidimarri,(1988), 'Alternative Waste Treatment Systems', published by Elsevier Applied Science, London and New York.
- [51] Booz Allen Hamilton, Rocky Mountain Institute, 'Valuing Decentralised Wastewater Technologies: A Catalog Of benefits, Costs and Economic Analysis Techniques, Snowmass Co, USA.2004.
- [52] [http://www.ci. Austin.tx.us/wri/fact.htm](http://www.ci.Austin.tx.us/wri/fact.htm).
- [53] <http://www.estd.wvu.edu/nsfc/NSFC.SFarchives.htm>
- [54] <http://www.wastewater.net>
- [55] <http://www.gtz.de/gate/gateid.afp>
- [56] <http://www.anaerob.com>

[57] Sanitation Connection, 'Wastewater Treatment Technology', (2001,2002), site developed by IRC and WEDC on behalf of the core group. This comprises IWA, UNEP(GPA), WSP, WSCC and WHO.

[58] [http://www.neiwppc.org/technology exchange: onsite/Decentralized treatment](http://www.neiwppc.org/technology%20exchange%20onsite/Decentralized%20treatment).

[Annexures]

| |
|--|
| SEWAGE TREATMENT PLANT |
| for Zone I- WARD 45 -AMBATTUR MUNICIPALITY |
| Design of Sequential Batch Reactor (SBR) - 0.4 MLD CAPACITY |

Input data

Population

Ward 45 has been divided in to 3 zones based in topography
 Zine I comprise of 11 streets , with a present population of 2299
 Arithmetic increase method of population projection is adopted.
 A decadal growth rate of 30% is proposed to be adopted.
 Population as per 2001 census 1900

| | |
|--------------------------------|------------|
| Present Population (year 2008) | population |
| Assume Base year 2008 | |
| Ultimate Design year 2038 | 4009 |

Sewage generation

| | | |
|---|-----|-------------|
| Per capita water supply | 110 | lpcd |
| Sewage generation (ignoring infiltration) =80% of WS.=88 lpcd | 88 | |
| | | Say 90 lpcd |
| Total ultimate sewage generated in the zone=0.3608 mld | 0.4 | mld |

Wastewater characteristics

| | | | |
|----------------------|---|------|--------------------------|
| BOD | = | 250 | mg/L (g/m ³) |
| COD | = | 450 | mg/L (g/m ³) |
| TSS | = | 300 | mg/L (g/m ³) |
| VSS | = | 220 | mg/L (g/m ³) |
| bCOD/BOD ratio | = | 1.60 | |
| Effluent BOD desired | < | 10 | mg/L |

Final disposal will be through reuse for watering of lawns and gardens and industrial floor eashing

Design Criteria

| | | | |
|--|---|-------------|----------------------|
| Parameter | = | value | |
| BOD loading rate, F/M (kg BOD/kg MLVSS) | = | 0.04 - 0.10 | |
| Oxygen requirement at 20°C (kg/ kg of BOD applied) | = | 2.0 - 3.0 | |
| MLSS (mg/L) | = | 2000 - 5000 | |
| Detention time | = | 15 - 40 | h |
| Volumetric loading, kg BOD/d/m ³ | = | 0.1 - 0.30 | |
| Ultimate flow | = | 400 | m ³ / day |

DESIGN

2 Design assumptions

| | | | |
|----------------------------------|---|-----|--------------------------|
| Total liquid depth when full | = | 4 | m |
| Decant depth = 30% of tank depth | = | 1.2 | m |
| SVI | = | 150 | mL/g |
| bCOD = 1.6* BOD | = | 400 | mg/L (g/m ³) |
| inert TSS = TSS - VSS | = | 80 | mg/L (g/m ³) |

3 Design of Sequencing Batch Reactor

SBR operating cycle

Assumption based on ult av flow

| | | | |
|---|---|-----|---|
| Aeration time, ta | = | 2 | h |
| settling time, ts | = | 0.5 | h |
| decant time, td | = | 0.5 | h |
| idle time, ti | = | 0 | h |
| Filling time tf = ta + ts + td | = | 3 | h |
| Total cycle time, Tc = tf+ ta+ ts + td + ti | = | 6 | h |

| | | | |
|--|---|--------|--------------------------|
| Total number of cycles /day | = | 4 | |
| Fill volume, Vf = Flow/8 | = | 100 | m ³ /fill |
| Mass of volume at full volume = Mass of settled solids | | | |
| Vt* X = Vs* Xs | | | |
| MLSS conc in settled volume, Xs =10 ⁶ /SVI | = | 6666.7 | mg/L (g/m ³) |
| MLSS conc at full volume, X (assumed) | = | 3500 | mg/L (g/m ³) |
| settled fraction of solids = X / Xs | = | 0.525 | |
| Provide 20% liquid above the sludge blanket | = | | |
| Vs/Vt = 1.2 (X/Xs) | = | 0.63 | |
| (Vf/Vt) + (Vs/Vt) =1 | | | |
| Vf/Vt = 1 -- (Vs/Vt) | = | 0.37 | |

Selected Vs/Vt of 0.37 is acceptable , nearer to 0.3

Overall Hydraulic detention time

| | | | |
|---|---|--------|------------------|
| Decant depth | = | 1.2 | m |
| Volume of tank, $V_t = V_f/0.3$ | = | 333.33 | m^3 |
| Overall detention time | = | 20 | h |
| Aeration time | = | 2 | h |
| Decant volume = fill volume | = | 100 | m^3 |
| Decant time | = | 30 | min |
| Rate of decant | = | 3.333 | m^3/min |
| Adopt 110 OD PVC pipes, velocity = 1.07 m/s | = | | |

4 Blower design

| | | | |
|---|---|--------|------------------------|
| BOD load = (BOD*flow)/1000 | = | 100 | kg/d |
| Oxygen required = 2.5kg/kg of BOD | = | 250 | kg/d |
| Aeration time = aeration time* number of cycle | = | 8 | h |
| Average oxygen transfer rate | = | 12.500 | kg/h |
| Oxygen demand will be higher initially; Transfer rate should be multiplied by 1.5. Actual oxygen rate (AOR) | = | 18.750 | kg/h |
| Assume depth of tank | = | 4 | m |
| Actual Oxygen transfer rate (AOR) / Standard Oxygen transfer rate (SOR) with fine bubble aeration | = | 0.33 | |
| Standard Oxygen transfer rate (SOR) | = | 56.818 | kg/h |
| | = | 0.947 | kg/min |
| Efficiency of fine bubble oxygen transfer/ 30 cm | = | 2 | % |
| Position of diffuser above the tank floor | = | 0.3 | m |
| Depth of submergence = depth of tank - 0.3 | = | 3.7 | m |
| Oxygen transfer efficiency (OTE) | = | 24.667 | % |
| O ₂ contents of air pr m ³ | = | 0.277 | kg/min |
| Oxygen transfer | = | 0.068 | kg O ₂ /min |
| Air required = SOR/ Oxygen transfer | = | 0.231 | m^3/sec |

$$\text{Power requirement of blower} = P_w = \frac{wRT_i}{(29.7ne)[(p_2/p_1)^{0.283} - 1]}$$

Where

| | | |
|---|---------|-------------------|
| w = weight of flow of air, kg/s | 0.2987 | kg/m ³ |
| R = engineering gas constant for air = 8.314 kJ/k mol K | 8.314 | |
| T _i = absolute inlet temperature, K | 295.000 | |
| p ₁ = absolute inlet pressure, atm | 15 | m |
| p ₂ = absolute outlet pressure, atm | 10 | m |
| n = 0.283 | 0.283 | |
| e = efficiency, (0.7 to 0.90) | 0.7 | |
| Power requirement of blower = P _w | = | 15.138 kW |
| | | 16.000 kW |

Provide two blowers, each of 100 kW power rating**5 Dimensions of the SBR**

| | | | |
|-------------------------------------|---|--------|-------|
| Volume of each of aeration tank V | = | 333.33 | |
| Assume depth of tank | = | 4 | m |
| Surface area of each tank = V/depth | = | 83.333 | m^2 |
| Assume L:B ratio of 2:1 | | | |
| Breath of tank = Sq. root[Area/2] | = | 6.45 | m |
| | | 6.50 | m |
| Length of the tank = 2* breath | = | 13.00 | m |

Provide Aeration tanks of overall dimensions 13.0m x 6.50m x 4.3m**6 Collection Well for Raw Sewage**

| | | | |
|--|---|-------|----------------|
| Depth of incoming sewer at collection well | = | 2 | m |
| Ultimate flow | = | 400 | m^3/d |
| Detention time | = | 30 | min |
| Volume of storage | = | 8.333 | m^3 |
| Adopt a depth of storage | = | 2 | m |
| Cross section al area of well | = | 4.167 | m^2 |
| Diameter of the collection well | = | 2.30 | m |
| | | 2.00 | m |

Provide extra for pump and bottom clearance for the submersible pump

| | | | |
|-----------------------------|---|---|---|
| Total depth of well from GL | = | 1 | m |
| | = | 6 | m |

Provide a collection well of 2m internal dia and 6m total depth

7 Collection Well for Treated Effluent

| | | | |
|--|---|--------|-------------------|
| Quantity of effluent | = | 400 | m ³ /d |
| Total decant time/cycle | = | 0.5 | h |
| Total Decant time | = | 2 | h |
| Volume required for 15 minutes storage | = | 50.0 | m ³ |
| Adopt a depth of storage | = | 3.5 | m |
| Cross section al area of well | = | 14.286 | m ² |
| | | 15.890 | |
| Diameter of the collection well | = | 4.26 | m |
| Provide extra for pump and bottom clearance for the submersible pump | = | 1 | m |
| Total depth of well from GL | = | | m |

Provide a collection well of 4.50m internal dia and 5.00m total depth

8 Design of Pumps

0.5

a. Sewage Pumps (for pumping to aeration tank)

| | | | |
|--|---|---------|-------------------|
| Ultimate peak flow to be handled | = | 400 | m ³ /d |
| Number cycles of operation | = | 4 | |
| Volume of sewage to be pumped per cycle | = | 100 | m ³ |
| Duration of pumping for fill | = | 3 | h |
| Rate of pumping | = | 0.00926 | m ³ /s |
| Total head for pumping $H = 3.5 + 1.5 + 2 = 7.0\text{m}$ | = | 7 | m |
| Power requirement for pumps, $HP = wQH/(0.735 \cdot e)$ | | | |
| Assume efficiency, e | | 60 | % |
| Power required | = | 1.442 | HP |
| Provide | = | 1.500 | HP |

Provide 1.5HP non-clog submersible pumps- 2 N0s(one stand by)

b. Effluent Pumps (for pumping effluent for disposal)

| | | | |
|--|---|---------|-------------------|
| Volume of effluent to be pumped per day | = | 400 | m ³ |
| Duration of pumping | = | 2 | h |
| Rate of pumping | = | 0.05556 | m ³ /s |
| Total head for pumping $H = 3.5 + 1.8 + 1.7 = 7.0\text{m}$ | = | 7 | m |
| Power requirement for pumps, $HP = wQH/(0.735 \cdot e)$ | | | |
| Assume efficiency, e | | 60 | % |
| Power required | = | 8.520 | HP |
| Provide | = | 10.00 | HP |

Provide 10 HP non-clog submersible pumps- 2 N0s(one stand by)

c. Sludge withdrawl pumps

| | | | |
|---|---|---------|-------------------|
| Volume of sludge to be withdrawn = 1% of flow against normal 2% | = | 4 | m ³ |
| Duration of pumping | = | 30 | min |
| Rate of pumping | = | 0.00222 | m ³ /s |
| Total head for pumping | = | 5 | m |
| Power requirement for pumps, $HP = 1.2 \cdot wQH/(0.735 \cdot e)$ | | | |
| Assume efficiency, e | | 60 | % |
| Power required | = | 0.252 | HP |
| Provide | = | 1.0 | HP |

Provide 1HP non-clog submersible sludge pumps- 2 N0s(one stand by)

9 Sludge Drying Beds

| | | | |
|------------------------------------|---|-----|---------------------|
| Sludge wasted per day | = | 4 | m ³ /day |
| Sludge drying period | = | 7 | days |
| Sludge application | = | 0.2 | m |
| Surface area of sludge drying beds | = | 20 | m ² |

Size of SDBs = 4m x 2.0m

Provide 4Nos of drying beds each of size 4m x 2.0m

Summary of Design

| Sl.No. | Name of unit | Dimension | No. of Units |
|--------|---|------------------------|--------------|
| 1 | Raw Sewage Collection Well | 2.6m dia x 3.0m depth | 1No |
| 2 | Effluent Collection Well | 3.0m dia x 2.80m depth | 1No. |
| 3 | Sequencing Batch Reactors | 4m x 2m x 4.3m | 2 Nos |
| 4 | Blowers | 9 kW | 2Nos |
| 5 | Pumps | | |
| | a) Raw sewage pumps | 0.5 HP | 2 Nos |
| | b) Effluent pumps | 0.75 HP | 2 Nos |
| | c) Sludge pumps | 0.5 HP | 2 Nos |
| 6 | Sludge Drying Beds | 6.5m x 2.0m | 8 Nos |
| 7 | Blower cum Electrical room & Store room | 7m x 5m | 1 No. |

**ESTIMATE FOR STP FOR ZONE - II , WARD 45, AMBATTUR MUNICIPALITY
0.4 MLD CAPACITY SEQUENTIAL BATCH REACTOR (SBR)**

| Sl. No. | Description of work | No. | L (m) | B (m) | D (m) | Quantity | Unit | Rate (Rs.) | Amount (Rs.) |
|---------|---|-----|---------------------------|-------|-------|----------|------|------------|--------------|
| 1 | Earth work excavation & depositing on bank with an initial lead of 10 m & lift of 2 m for depths in hard stiff clay, stiff black cotton, hard red earth mixed with small sized boulders & hard gravelly etc all complete as per standard specification and as directed by Departmental Engineer. (Civil works) | | | | | | | | |
| i | Raw sewage Collection Well | 1 | 4.10 | 4.10 | 4.40 | 73.96 | | | |
| ii | Aeration Tank | 1 | 74.00 | 7.50 | 2.40 | 1332.00 | | | |
| iii | Sludge well | 1 | 120.79 | 1.90 | 3.40 | 780.27 | | | |
| iv | Sludge drying beds | 4 | 4.90 | 8.90 | 2.40 | 418.66 | | | |
| v | Sludge drying Beds channel (central portion) | 4 | 4.90 | 0.50 | 0.50 | 4.90 | | | |
| vi | Effluent well | 1 | 3.141*6.1 ² /4 | | 3.20 | 93.50 | | | |
| | | | | | | 2703.29 | cum | 28.75 | 77719.66 |
| 2 | Providing and laying base concrete in foundation using Plain Cement Concrete 1:3:6 including consolidation and levelling etc as per standard specifications | | | | | | | | |
| i | Raw sewage Collection Well | 1 | 4.10 | 4.10 | 0.10 | 1.68 | | | |
| ii | Aeration Tank | 1 | 74.00 | 7.50 | 0.10 | 55.50 | | | |
| iii | Sludge well | 1 | 120.79 | 1.90 | 0.10 | 22.95 | | | |
| iv | Sludge drying beds | 4 | 4.90 | 8.90 | 0.10 | 17.44 | | | |
| v | Sludge drying Beds channel (central portion) | 4 | 4.90 | 0.50 | 0.10 | 0.98 | | | |
| vi | Effluent well | 1 | 3.90 | | | 3.90 | | | |
| | | | | | | 102.45 | cum | 2110.00 | 216169.58 |
| 3 | Supplying & laying Reinforced Cement Concrete of M25 grade using machine crushed hard broken granite stone jelly 20 mm for RCC works in all types of foundations, floor slabs of all shapes (Excluding cost of providing centering & fabrication of reinforcement which shall be measured & paid under separate items) including curing, complying with standard specifications as directed by the Departmental Engineer using sulphate resisting cement. | | | | | | | | |
| | Raw Sewage Collection Well | | | | | | | | |
| | side walls all around | 1 | 8.79 | 0.30 | 4.50 | 11.87 | | | |
| | base slab | 1 | 3.14 | 0.30 | 4.50 | 4.24 | | | |
| | beam for base slab | 1 | 0.79 | 2.60 | 0.15 | 0.31 | | | |
| | aeration tank | | | | | | | | |
| | side walls allround | 1 | 40.60 | 0.40 | 4.30 | 69.83 | | | |
| | base slab | 1 | 13.40 | 6.80 | 0.30 | 27.34 | | | |
| | beam for fixing aerators | 2 | 6.40 | 0.45 | 0.45 | 2.59 | | | |
| | Sludge well | | | | | | | | |
| | side wall | 1 | 5.34 | 0.20 | 4.80 | 5.13 | | | |
| | base slab | 1 | 1.49 | 1.90 | 0.30 | 0.85 | | | |
| | Drying bed | | | | | | | | |
| | side wall | 8 | 16.60 | 0.15 | 2.00 | 39.84 | | | |

| Sl. No. | Description of work | No. | L (m) | B (m) | D (m) | Quantity | Unit | Rate (Rs.) | Amount (Rs.) |
|---------|--|-----|-------|-------|--------|----------|------|------------|--------------|
| | base | 8 | 6.80 | 2.30 | 0.15 | 18.77 | | | |
| | Effluent well | | | | | | | | |
| | side wall | 1 | 15.56 | 0.45 | 4.80 | 33.61 | | | |
| | base slab | 1 | 2.44 | 3.10 | 0.30 | 2.27 | | | |
| | | | | | | 216.64 | cum | 3539.00 | 766673.41 |
| 4 | Supplying, fabricating & placing in position MS or deformed steel bars for all RCC items of work including cost of steel transporting, straightening, cutting, bending, cranking, binding etc. including cost of binding wire charids, laps to fix the reinforcement in all positions, all labour & materials complete complying with standard specifications & drawings as directed by the Departmental Engineer. | 1 | 75 | | 216.64 | 16,248 | Kg | 51.00 | 828631.19 |
| 5 | Supplying & erecting centering for sides & walls including supports & strutting for plain surfaces with all cross bracings using 25 mm thick boards suitable purlined over silver oak (country wood) joists of size 10 x 6.5 cm spaced at about 90 cm centre to centre & supported by causerina props 10 to 13 cm diameter spaced at about 75 cm centre to centre etc. complete complying with standard specifications. Centering for RCC works below GL (wall). | | | | | | | | |
| | Raw Sewage Collection Well | | | | | | | | |
| | side walls all around | 2 | 8.79 | 4.50 | | 79.15 | | | |
| | base slab | 1 | 8.17 | 0.30 | | 2.45 | | | |
| | aeration tank | | | | | | | | |
| | side walls allround | 2 | 40.60 | | 4.10 | 332.92 | | | |
| | base slab | 1 | 42.20 | 0.30 | | 12.66 | | | |
| | beam for fixing aerators | 2 | 6.50 | 1.25 | | 16.25 | | | |
| | Sludge well | | | | | | | | |
| | side wall | 2 | 5.34 | | 4.00 | 42.72 | | | |
| | Drying bed | | | | | | | | |
| | side wall | 16 | 16.00 | | 2.00 | 512.00 | | | |
| | base | 8 | 7.30 | 2.80 | 0.15 | 24.53 | | | |
| | Effluent well | | | | | | | | |
| | side wall | 2 | 15.56 | | 4.30 | 133.82 | | | |
| | | | | | | 1156.50 | sqm | 428.00 | 494980.79 |
| 6 | Supplying and installation of following machineries including all electrical works and labour charges etc complete as per standard specifications and as directed by Engineer-in-charge | | | | | | | | |
| | Machinery | | | | | | | | |
| | Bar screen | 1 | | | | 1 | no. | 5000.00 | 5000.00 |
| | Blower 100 KW | 2 | | | | 2 | nos. | 25000.00 | 50000.00 |

| SI. No. | Description of work | No. | L (m) | B (m) | D (m) | Quantity | Unit | Rate (Rs.) | Amount (Rs.) |
|---------|---|-----|-------|-------|-------|----------|------|------------|--------------|
| | Raw sewage Pump 1.5 HP | 2 | | | | 2 | no. | 10000.00 | 20000.00 |
| | sludge well pump 1.0 HP | 2 | | | | 2 | no. | 8000.00 | 16000.00 |
| | effluent pump (10 HP) | 2 | | | | 2 | no. | 60000.00 | 120000.00 |
| 7 | Earth work excavation & depositing on bank with an initial lead of 10 m & lift of 2 m for depths in hard stiff clay, stiff black cotton, hard red earth mixed with small sized boulders & hard gravely soil as directed by the Departmental Engineer. (Pipeline works) | | | | | | | | |
| | Collection Well to Aeration tank | 1 | 10 | 0.80 | 1.00 | 8 | | | |
| | Aeration tank to effluent well | 1 | 10 | 0.80 | 1.00 | 8 | | | |
| | Aeration to Sludge well | 1 | 15 | 0.80 | 1.00 | 12 | | | |
| | Sludge well to sludge drying beds | 1 | 35 | 0.80 | 1.00 | 28 | | | |
| | Effluent well to surplus course | 1 | 25 | 0.90 | 2.00 | 45 | | | |
| | | | | | | 101 | cum | 28.75 | 2903.75 |
| 8 | Supply of 200 mm diameter of RCC pipes NP 3 class with sulphate resistance cement with inner lining of high alumina cement as per IS:783 with epoxy coating outside of the spigot portion and poly solution coating inside the socket portion including lowering into trenches, laying to proper grade and alignment, cutting the pipes true to axis & jointing the pipes & specials with rubber rings including cost of lubricant, testing the pipe to the required pressure including barricading, provision of danger lights, arranging for watch & ward etc., complete as per specifications. | | | | | | | | |
| | Collection Well to Aeration tank | 1 | 12 | | | 12 | | | |
| | Aeration tank to effluent well | 1 | 18 | | | 18 | | | |
| | Aeration to Sludge well | 1 | 20 | | | 20 | | | |
| | Sludge well to sludge drying beds | 1 | 35 | | | 35 | | | |
| | Effluent well to surplus course | 1 | 25 | | | 25 | | | |
| | Net quantity | | | | | 110 | m | 304.00 | 33440.00 |
| 9 | Supply and installation of following size of CI Double Flanged Sluice Valves (PN 1.0) with cap and conforming to IS:14846, to site, including flanged tail pieces and other specials as required, loading, unloading, transportation charges & stacking at site etc all complete as per standard specifications and as directed by the Engineer-in-charge | | | | | | | | |
| | sluice valves 200 mm | 4 | | | | 4 | nos. | 10128.00 | 40512.00 |
| | Sluice valve at Sludge drying beds 100mm | 4 | | | | 4 | nos. | 4100.00 | 16400.00 |
| | Total | | | | | | | | 2688430.37 |
| | | | | | | | Say | | 26.88 Lakhs |

| DESIGN OF DECENTALISED WASTE WATER TREATMENT FOR | | | |
|--|--------------|----------------------|--|
| Zone II-Ward 45- Ambattur municipality | | | |
| INTERMITTANT SAND FILTER (ISF) | | | |
| 1 Population | | | |
| Ward 45 has been divided in to 3 zones based in topography | | | |
| Zine II comprise of 17 streets , with a present population of 2052 | | | |
| Arithmetic increase method of population projection is adopted. | | | |
| A decadal growth rate of 30% is proposed to be adopted. | | | |
| Population as per 2001 census | 2068 | Projected population | |
| Present Population (year 2008) | | | |
| Assume Base year | 2008 | 2502 | |
| Ultimate Design year | 2038 | 4364 | |
| 2 Sewage generation | | | |
| Per capita water supply | 110 lpcd | | |
| Sewage generation (ignoring infiltration) =80% of WS.=88 lpcd | | | |
| | | Say 90 lpcd | |
| Total ultimate sewage generated in the zone=0.3927 mld | | 0.4 mld | |
| 3 Total sewage to be treated | | | |
| | | 400 m3 | |
| sewage is passing through septic tanks (interceptors) and only solid free effluent is collected for treatment. | | | |
| Since septic tanks provide 24 hours detention ,peak flow will be twice the average flow. | | | |
| 4 Collection sump | | | |
| Average flow | | 278 lpm | |
| Capacity of collection sump assuming 60 min. storage | | 17 m3 | |
| Provide 2 sumps to meet the peak | | | |
| Assuming a depth.of 3 m | area of well | 5.56 m2 | |
| Dia. of well | | 2.68 m | |
| | Say | 3.00 m | |
| Total depth=0.5+2+3=5.5m | | | |
| 5 Intermittant sand filter | | | |
| No. of dose per day | | 4 nos. | |
| Sewage is dosed in two beds alternatively once in 4 hours | | | |
| Rate of feed per dose | | 67 m3 | |
| Surface loading per sq.m per dose | | 0.2 m3 | |
| Surface area of sand filter required | | 333 m2 | |
| Adpot 2 Nos filter | 20x9m , | Area provided | |
| | | 360 m2 | |
| Free board=0.15m | | | |
| Distribution pipe 0.20m | | | |
| Depth of water=0.10m | | | |
| Gravel (40 mm size)media=0.60 | | | |
| Sand media=0.30m | | | |
| Gravel(20mm size) support=0.15m | | | |
| Under drains =0.20m | | | |
| Overall Depth of filter=1.7m, Provide 0.7m above ground. | | | |
| 5 Treated effluent sump | | | |
| Assuming 60 min. storage , provide 3m dia and 2.5m depth | | | |
| depth of effluent pipe =1.0m | | | |
| Overall depth of sump =3.0+1.0+0.5=4.50m below ground | | | |
| 6 Polishing pond-Maturation pond | | | |
| BOD of sand filter effluent | | 50 mg/l | |

**Estimate for STP for Zone-I, Ward - 45, Ambattur Municipality
0.4 MLD CAPACITY - INTERMITTANT SAND FILTER (ISF)**

| Sl.No. | Description of item | No. | L (m) | B (m) | D (m) | Quantity | Unit | Rate (Rs) | Amount (Rs) |
|--------|--|-------------------------|-------|-------|-------|----------|------|-----------|-------------|
| | COLLECTION WELL - 3.0 m dia | | | | | | | | - |
| 1 | Earth work excavation above water level in sandy or clayey soil for wells including levelling the site with initial lead of 10 m | | | | | | | | |
| | First depth of 2m | $2 \times \pi/4$ | 3.30 | 3.3 | 2.00 | 17.11 | cum | 28.75 | 491.80 |
| 2 | Sinking of well below water level including all incidental charges using special tools and plants such as air compressor, helmet etc, complete and including baling out water | | | | | | | | |
| | For 3.0 m dia well | | | | | | | | |
| | First depth 2m | 2x1 | | | | 2.00 | m | 1,030.00 | 2,060.00 |
| | second depth 2 m | 2x1 | | | | 1.80 | m | 2,041.00 | 3,673.80 |
| 3 | Supplying & laying Reinforced Cement Concrete of M20 grade using machine crushed hard broken granite stone jelly 20 mm for RCC Kerbs of all shapes (Excluding cost of providing centering & fabrication of reinforcement which shall be measured & paid under separate items) including curing, complying with standard specifications as directed by the Departmental Engineer using sulphate resisting cement. | | | | | | | | |
| | RCC Kerb | $2 \times \pi$ | 3.30 | 0.3 | 0.30 | 0.23 | cum | 3,539.00 | 825.55 |
| 4 | Supplying & laying Reinforced Cement Concrete of M20 grade using machine crushed hard broken granite stone jelly 20 mm for RCC works in Well Sinking of all shapes (Excluding cost of providing centering & fabrication of reinforcement which shall be measured & paid under separate items) including curing, complying with standard specifications as directed by the Departmental Engineer using sulphate resisting cement. | | | | | | | | |
| | RCC Well sinking | $2 \times \pi$ | 3.30 | 3.3 | 5.50 | 47.04 | cum | 3,539.00 | 166,479.60 |
| 5 | Supplying & erecting centering for sides & walls including supports with all cross bracings using 25 mm thick boards suitable purlined over silver oak (country wood) joists of size 10 x 6.5 cm spaced at about 90 cm centre to centre & supported by causerina props 10 to 13 cm diameter spaced at about 75 cm centre to centre etc. complete complying with standard specifications. Centering for RCC works. | | | | | | | | |
| | | $2 \times 2 \times \pi$ | 3.30 | | 5.50 | 28.51 | sqm | 513.60 | 14,642.75 |

| Sl.No. | Description of item | No. | L (m) | B (m) | D (m) | Quantity | Unit | Rate (Rs) | Amount (Rs) |
|--------|--|-------|-------|-------|-------|---------------|------------|-----------|-------------------|
| 6 | Supplying, fabricating & placing in position MS or deformed steel bars for all RCC items of work including cost of steel transporting, straightening, cutting, bending, cranking, binding etc. including cost of binding wire charids, laps to fix the reinforcement in all positions, all labour & materials complete complying with standard specifications & drawings as directed by the Departmental Engineer. | | | | | | | | |
| | steel at 75 Kg/cum of Concrete | | | | | 3545.60 | KG | 51.00 | 180,825.70 |
| 7 | Providing Pumping Machinaries and electrical items including installation | | | | | | | | |
| | 3 Hp Pumpset | 2 x 1 | | | | 2.00 | | 14,721.00 | 29,442.00 |
| | Sub total A | | | | | | | | 398,441.20 |
| | SAND FILTER - 3.0 m dia | | | | | | | | |
| 1 | Earth work excavation and depositing on bank with initial lead of 10 m and initial lift of 2 m in hard stiff clay, stiff black cotton, hard red earth, shales murrum, gravel, stony earth and earth mixed with small size of boulders as directed by the Engineer.- 1 cu.m | | | | | | | | |
| | For filter area | 2 | 20.90 | 9.90 | 1.25 | 517.28 | cum | | |
| | For Distribution Chamber | 1 | 2.4 | 1.9 | 1 | 4.56 | cum | | |
| | | | | | | 521.84 | cum | 28.75 | 15,002.80 |
| 2 | Providing & laying PCC 1:4:8 with 40 mm HBG as levelling course including curing etc all complete as per standard specification as directed by the Engineer. | | | | | | | | |
| | For filter area | 2 | 20.90 | 9.90 | 0.10 | 41.38 | cum | | |
| | For Distribution Chamber | 1 | 2.4 | 1.9 | 0.1 | 0.46 | cum | | |
| | | | | | | 41.84 | cum | 1,872.00 | 78,320.75 |
| 3 | Supplying & laying Reinforced Cement Concrete of M20 grade using machine crushed hard broken granite stone jelly 20 mm for RCC works of all shapes (Excluding cost of providing centering & fabrication of reinforcement which shall be measured & paid under seperate items) including curing, complying with standard specifications as directed by the Departmental Engineer using sulphate resisting cement. | | | | | | | | |
| | Filter | | | | | | | | |
| | For side wall | 2 | 58.60 | 0.15 | 1.700 | 29.89 | cum | | |
| | For Base slab | 2 | 20.30 | 9.30 | 0.150 | 56.64 | cum | | |
| | Distribution Chamber | | | | | | | | |
| | For Base slab | 1 | 1.9 | 1.3 | 0.15 | 0.37 | cum | | |
| | For side wall | 1 | 5.60 | 0.15 | 2.45 | 2.06 | cum | | |
| | | | | | | 88.95 | cum | 3,539.00 | 314,799.40 |
| 4 | Refilling with suitable excavated earth available in layers of 150 mm thick, watering, ramming & consolidation as directed by the Engineer. | | | | | | | | |
| | Filter | 2 | 60.4 | 0.3 | 1.15 | 41.68 | cum | | |
| | Distribution Chamber | 1 | 7.4 | 0.3 | 0.9 | 2.00 | cum | | |
| | | | | | | 43.67 | cum | 10.10 | 441.15 |

| Sl.No. | Description of item | No. | L (m) | B (m) | D (m) | Quantity | Unit | Rate (Rs) | Amount (Rs) |
|--------|--|-------------|-------|-------|-------|----------|------|-----------|---------------------|
| 5 | Supplying & erecting centering for sides & walls including supports with all cross bracings using 25 mm thick boards suitable purlined over silver oak (country wood) joists of size 10 x 6.5 cm spaced at about 90 cm centre to centre & supported by causerina props 10 to 13 cm diameter, spaced at about 75 cm centre to centre etc. complete complying with standard specifications. Centering for RCC works. | | | | | | | | |
| | Filter | | | | | | | | |
| | Side walls | 2 x 2 | 58.8 | | 1.7 | 399.84 | sqm | | |
| | Base slab | 2 | 59.2 | | 0.15 | 17.76 | sqm | | |
| | Distribution chamber | | | | | | | | |
| | Side walls | 1 | 5.6 | | 2.45 | 27.44 | sqm | | |
| | Base Slab | 1 | 6.4 | | 0.15 | 1.92 | sqm | | |
| | | | | | | 446.96 | sqm | 428.00 | 191,298.90 |
| 6 | Supplying, fabricating & placing in position MS or deformed steel bars for all RCC items of work including cost of steel transporting, straightening, cutting, bending, cranking, binding etc. including cost of binding wire charids, laps to fix the reinforcement in all positions, all labour & materials complete complying with standard specifications & drawings as directed by the Departmental Engineer. | | | | | | | | |
| | Steel at 75 Kg/cum of Concrete | | | | | 6671.36 | Kg | 51.00 | 340,239.50 |
| 7 | Suppling Filter Media and laying | | | | | | | | |
| | HBG 40 mm | 2 | 20 | 9 | 0.6 | 216 | cum | 560.00 | 120,960.00 |
| | HBG 20 mm | 2 | 20 | 9 | 0.6 | 216 | cum | 780.00 | 168,480.00 |
| | Sand | 2 | 20 | 9 | 0.15 | 54 | cum | 348.00 | 18,792.00 |
| 8 | Providing Under Drains | | | | | | | | |
| | 200 mm perforated PVC Pipe | 2 x 3 | 12 | | | 72 | m | 310.00 | 22,320.00 |
| | 200 mm Plain PVC Pipe | 2 x 3 | 1 | | | 6 | m | 281.50 | 1,689.00 |
| | Effluent pipe PVC Plan 300 mm | 2 x 1 | 40 | | | 80 | m | 708.00 | 56,640.00 |
| 9 | Providing Distribution pipes | | | | | | | | |
| | 200 mm perforated | 2 x 2 | 21 | | | 84 | m | 281.50 | 23,646.00 |
| 10 | Providing CI Sluice for filter | 1 x 2 | | | | 2 | Nos | 8,340.00 | 16,680.00 |
| | Sub Total B | | | | | | | | 1,369,309.50 |
| | EFFLUENT WELL - 3.0 m dia | | | | | | | | |
| 1 | Ear work excavation above water level in sandy or clayey soil for wells including levelling the site with initial lead of 10 m | | | | | | | | |
| | First depth of 2m | 2 x $\pi/4$ | 3.30 | 3.3 | 2.00 | 17.11 | cum | 28.00 | 479.00 |
| 2 | Sinking of well below water level including all incidental charges using special tools and plants such as air compressor, helmet etc, complete and including baling out water | | | | | | | | |
| | For 3.0 m dia well | | | | | | | | |
| | First depth 2m | 2x1 | | | | 2.00 | cum | 1,030.00 | 2,060.00 |

| Sl.No. | Description of item | No. | L (m) | B (m) | D (m) | Quantity | Unit | Rate (Rs) | Amount (Rs) |
|------------------------|--|---------|-------|-------|-------|----------|------|-----------|-------------------|
| 3 | Supplying & laying Reinforced Cement Concrete of M20 grade using machine crushed hard broken granite stone jelly 20 mm for RCC Kerbs of all shapes (Excluding cost of providing centering & fabrication of reinforcement which shall be measured & paid under separate items) including curing, complying with standard specifications as directed by the Departmental Engineer using sulphate resisting cement. | | | | | | | | |
| | RCC Kerb | 2 x π | 3.30 | 0.3 | 0.30 | 0.23 | cum | 2,756.00 | 642.90 |
| 4 | Supplying & laying Reinforced Cement Concrete of M20 grade using machine crushed hard broken granite stone jelly 20 mm for RCC works in Well Sinking of all shapes (Excluding cost of providing centering & fabrication of reinforcement which shall be measured & paid under separate items) including curing, complying with standard specifications as directed by the Departmental Engineer using sulphate resisting cement. | | | | | | | | |
| | RCC Well sinking | 2 x π | 3.30 | 3.3 | 4.50 | 38.49 | cum | 2,756.00 | 106,074.15 |
| 5 | Supplying & erecting centering for sides & walls including supports with all cross bracings using 25 mm thick boards suitable purlined over silver oak (country wood) joists of size 10 x 6.5 cm spaced at about 90 cm centre to centre & supported by causerina props 10 to 13 cm diameter spaced at about 75 cm centre to centre etc. complete complying with standard specifications. Centering for RCC works. | | | | | | | | |
| | | 2x2 x π | 3.30 | | 4.50 | 23.33 | sqm | 428.00 | 9,983.70 |
| 6 | Supplying, fabricating & placing in position MS or deformed steel bars for all RCC items of work including cost of steel transporting, straightening, cutting, bending, cranking, binding etc. including cost of binding wire charids, laps to fix the reinforcement in all positions, all labour & materials complete complying with standard specifications & drawings as directed by the Departmental Engineer. | | | | | | | | |
| | steel at 75 Kg/cum of Concrete | | | | | 2904.13 | KG | 51.00 | 148,110.55 |
| 7 | Providing Pumping Machinaries and electrical items including installation | | | | | | | | |
| | 3 Hp Pumpset | 2 x 1 | | | | 2.00 | No. | 14,721.00 | 29,442.00 |
| | Sub Total C | | | | | | | | 296,792.30 |
| MATURATION POND | | | | | | | | | |
| 1 | Eart work excavation above water level in sandy or clayey soil for wells including levelling the site with initial lead of 10 m | 2 | 33.05 | 16.05 | 1.05 | 1113.95 | Cum | 28.75 | 32026.10 |
| 2 | Forming of Bund | 2 | 33.75 | 16.75 | 2.38 | 2690.89 | Cum | | - |
| 3 | Gravel 150 mm thick | 2 | 101 | 2.48 | 0.15 | 75.14 | Cum | 97.00 | 7,289.00 |

| Sl.No. | Description of item | No. | L (m) | B (m) | D (m) | Quantity | Unit | Rate (Rs) | Amount (Rs) |
|--------|---|-----|-------|-------|-------|----------|------|-----------|---------------------|
| 4 | Supplying and fixing Precast cement Slab | 2 | 101 | 2.48 | 0.075 | 37.57 | Cum | 2,059.20 | 77,368.30 |
| 5 | Supplying and seeding of grass @ 50 mm c | 2 | 109 | 2.37 | | 516.66 | sqm | 10.10 | 5,218.30 |
| 6 | Inlet Arrangement | | | | | | | | 136,555.30 |
| | Sub Total D | | | | | | | | 258,457.00 |
| | Grand Total (Sub Totals - A+B+C+D) | | | | | | | | 2,323,000.00 |
| | | | | | | | Say | | 23.23 Lakhs |

| Design of Decentralised Waste Water Treatment System (Stabilisation Pond) - 0.2 mld capacity for Treating Septic Tank Effluent from Zone III-Ward 45 Ambattur Municipality | | |
|---|--------------------|------------|
| Population | | |
| Ward 45 has been divided in to 3 zones based in topography | | |
| Zine III comprise of 11 streets , with a present population of 1305 | | |
| Arithmetic increase method of population projection is adopted. | | |
| A decadal growth rate of 30% is proposed to be adopted. | | |
| Population as per 2001 census 1079 | | |
| Present Population (year 2008) | | |
| Assume Base year -2008 proj.population 1305 | | |
| Ultimate Design year -2038 Proj.population - 2277 | | |
| Sewage generation | | |
| Per capita water supply | 110 | lpcd |
| Sewage generation (ignoring infiltration) =80% of WS.=88 lpcd | 90 | lpcd |
| Total ultimate sewage generated in the zone | 0.20493 | mld |
| say | 0.20 | mld |
| The effluent from Septic Tank is directly fed in to Facultative Pond | | |
| BOD of incoming sewage | 250 | mg/l |
| Mean temperature | 30 | °C |
| Fecal coliform | 80x10 ⁵ | MPN/100 ml |
| Design of Anaerobic pond | | |
| Area of Pond = $Q \times t / D$ | | |
| Where Q = Flow in m ³ | = 200.00 | cum |
| t = Retention period in days | 5 | days |
| D = Depth in metres. | 3 | m |
| Area of Pond | = 333.333 | sqm |
| Provide 2 ponds of size 20 x9 x 3m - area | | |
| Area of Pond | = 360 | sqm |
| Actual retention time | = 5.40 | days |
| BOD reduction in anaerobic pond | = 56.00 | % |
| BOD of effluent | = 110 | mg/l |
| Quantity of effluent = $Q - 0.001Ae$ | = 196.40 | cum |
| Where Q = Flow in m ³ | | |
| A = Area of Pond in Sq.m | | |
| e = Evaporation in mm (10mm) | | |
| 2. Design of Facultative Pond | | |
| Retention time (Assumed) | = 5 | days |
| Influent BOD | = 110 | mg/l |
| Area of Pond = $Q \times (L_i - L_e) / 18 \times D \times (1.05)^{T-20}$ | | |
| Where Q = Flow in m ³ | = 196 | cum |
| T = Mean temperature | = 30 | °C |
| L _i = BOD of Influent | = 110 | mg/l |

| | | | |
|---|---|------------------|-----------|
| L_e = BOD of effluent (% reduction Assumed) | = | 60 | mg/l |
| Depth of Pond, D in metres | = | 1.5 | m |
| Area of Pond | = | 223.28 | sqm |
| Organic Loading = $10Q L_i / A$ | = | 967.56 | kg/ha.day |
| Permissible Organic loading = 20T-120 | = | 480 | kg/ha.day |
| As the organic loading rate is greater than the permissible organic loading rate the area of the pond has to be increased | | | |
| Provide 2 ponds of size 25 x 10 x 1.5m | | | |
| Area provided | = | 500 | sq.m |
| Now the organic loading rate = $10Q L_i / A$ | = | 432.08 | kg/ha.day |
| | < | 480 | kg/ha.day |
| Hence OK | | | |
| Actual Retention time, V/Q | = | 3.82 | days |
| BOD of Effluent, $L_e = L_i / (1 + (0.3 \times (1.05)^{T-20} \times t))$ | = | 38.38 | mg/l |
| Quantity of effluent = $Q - 0.001Ae$ | = | 191.40 | cum |
| Where Q = Flow in m^3 | | | |
| A = Area of Pond in Sq.m | | | |
| e = Evaporation in mm (10mm) | | | |
| 3. Design of Maturation Pond | | | |
| Retention time (Assumed) | = | 3 | days |
| Depth of Pond | = | 1.5 | m |
| Area of Pond = $Q \times t / D$ | = | 382.8 | |
| Where Q = Flow in m^3 | = | 191.40 | cum |
| t = Retention period in days | | | |
| D = Depth in metres. | | | |
| Area of Pond | = | 382.80 | sqm |
| Provide 2 ponds of size 20 x 10x 1.5m | | | |
| Area of Pond | = | 400 | sqm |
| Actual retention time | = | 3.13 | days |
| Check for Bacterial Quality | | | |
| Fecal Coliform in raw sewerage (Assumed), N_i | = | 80×10^5 | MPN/100ml |
| Rate Constant, $K_{b(T)} = 2.6 \times (1.19)^{T-20}$ | = | 14.81 | |
| Fecal Coliform in treated sewerage, N_e | | | |
| $= N_i / (1 + K_b \times t_{an}) (1 + K_b \times t_{fac}) (1 + K_b \times t_m)$ | = | 36.22 | MPN/100ml |
| | < | 100 | MPN/100ml |
| Hence OK | | | |
| Actual Retention time, V/Q | = | 3.13 | days |
| BOD of Effluent, $L_e = L_i / (1 + (0.3 \times (1.05)^{T-20} \times t))$ | = | 15.16 | mg/l |
| | < | 20.00 | mg/l |
| Hence OK | | | |

**Abstract Estimate for 0.2 Mld Waste Stabilisation Pond Treatment Plant at Ward No.45
Ambattur Municipality**

| Sl. No. | Description of item | Quantity | Unit | Rate (Rs.) | Amount (Rs.) |
|---------|--|----------|------|------------|--------------|
| 1 | Earth work excavation & depositing on bank with an initial lead of 30 m & lift of 2 m for depths in hard stiff clay, stiff black cotton, hard red earth mixed with small sized boulders & hard gravely etc all complete as per standarad specification and as directed by Engineer. | 2,116 | cum | 28.75 | 60,835.00 |
| | (As per Data Bank - Lead Charges) | | | | |
| 2 | Spreading the available earth in layers of 25cm thick including watering upto Optimum moisture content, consolidation by power roller (Forming bund above GL from suitable excavated earth & laid in layers, watering, ramming & consolidation by rollers as per standard specifications as directed by the Departmental Engineer. | 2,276 | cum | 30.60 | 69,645.60 |
| | (As per Data Bank - Lead Charges) | | | | |
| 3 | Supplying & laying of gravel 150 mm thick below precast slab, levelling the layer, watering and consolidation etc all complete as per standard specification and as directed by the Departmental Engineer. | 429 | cum | 185.40 | 79,536.60 |
| | (As per Data Bank - Lead Charges) | | | | |
| 4 | Supplying and seeding of grass at 50 mm c/c including preparation of earth with sweet earth, 150 mm thick, watering and maintaining the lawn upto 6 months etc all complete as directed by the Engineer. | 2,791 | sqm | 48.05 | 134,107.55 |
| | (As per Data Bank - Lead Charges) | | | | |
| 5 | Supplying and fixing in position RCC precast slabs of 450 x 450 x 50 mm over the bed of gravel to proper level etc all complete as directed by Engineer | 1,854 | sqm | 151.58 | 281,029.35 |
| | (As per Data Bank - Lead Charges) | | | | |
| 6 | Construction of toe wall etc all complete as per standard specification or as directed by the Engineer. | | | | |
| a) | Earth work excavation & depositing on bank with an initial lead of 30 m & lift of 2 m for depths in hard stiff clay, stiff black cotton, hard red earth mixed with small sized boulders & hard gravely etc all complete as per standarad specification and as directed by Engineer. | 68.29 | cum | 28.75 | 1,963.00 |
| b) | Providing and laying base concrete in foundation using Plain Cement Concrete 1:3:6 including consolidation and levelling etc as per standard specifications | 20.70 | cum | 2,110.00 | 43,666.55 |
| c) | Construction of brick masonry with class II bricks in CM 1:6 in foundation including curing etc all complete as per standard specifications. | 25.46 | cum | 2,371.00 | 60,368.00 |
| d) | Plastering with C.M 1:4, 12 mm thick including necessary scaffolding, watering the surface etc all complete as per standard specification. | 332.08 | sqm | 64.00 | 21,255.00 |
| | (As per Data Bank - Lead Charges) | | | | |

| Sl. No. | Description of item | Quantity | Unit | Rate (Rs.) | Amount (Rs.) |
|-------------------|---|----------|------|------------|------------------|
| 7 | Supplying & laying reinforced cement concrete of M 25 grade using machine crushed hard broken granite stone jelly 20 mm for RCC works in all types of foundations, floor slabs of all shapes (Excluding cost of providing centering & fabrication of reinforcements which shall be measured & paid under separate items) including curing, complying with standard specifications as directed by the Departmental Engineer using sulphate resisting cement. | 53.73 | cum | 3,258.00 | 175,053.00 |
| | (As per Data Bank - Lead Charges) | | | | |
| 8 | Supplying & erecting centering for sides & walls of outlet chamber including supports & strutting for plain surfaces with all cross bracings using 25 mm thick boards suitable purlined over silver oak (country wood) joists of size 10 x 6.5 cm spaced at about 90 cm centre to centre & supported by causerina props 10 to 13 cm diameter spaced at about 75 cm c/c etc. complete complying with standard specifications. Centering for RCC works below GL (wall). | 160.07 | sqm | 428.00 | 68,510.00 |
| 9 | Supplying, fabricating & placing in position MS or deformed steel bars for all RCC items of work including cost of steel transporting, straightening, cutting, bending, cranking, binding etc. including cost of binding wire charids, laps to fix the reinforcement in all positions, all labour & materials complete complying with standard specifications & drawings as directed by the Departmental Engineer. | 2,160.44 | kg | 51.00 | 110,182.00 |
| 10 | Supply of NP 3 class RCC pipes as per IS:783, lowering into trenches, laying to proper grade and alignment, cutting the pipes true to axis & jointing the pipes & specials with cement mortar joints including cost of jointing material, testing the pipe to the required pressure as directed by the Departmental Engineer including barricading, provision of danger lights, arranging for watch & ward etc., complete as per specifications at different depths. | | | | |
| | 350 mm diameter | 600 | m | 616.50 | 369,900.00 |
| 15 | Supplying, delivery, spreading & fixing of LDPE sheet in all the Anaerobic, Facultative & Maturation ponds for avoiding the seepage / infiltration including transportation and labour charges etc complete as per standard specification and as directed by Engineer-in-charge. | 1,660 | sqm | 100.00 | 166,000.00 |
| 16 | Effluent Pump | | LS | | 4,900 |
| Total Cost | | | | | 1,646,952 |

Say Rs.16.50 Lakhs

**Detailed Estimate for 0.2 Mld Waste Stabilisation Pond Treatment Plant at Ward NO.45
Ambattur Municipality**

| Sl. No. | Description of item | No. | L (m) | B (m) | D (m) | Quantity | Unit |
|---------|---|-----|--------|-------|-------|-----------------|------------|
| 1 | Earth work excavation & depositing on bank with an initial lead of 30 m & lift of 2 m for depths in hard stiff clay, stiff black cotton, hard red earth mixed with small sized boulders & hard gravelly etc all complete as per standard specification and as directed by Engineer. | 1 | | | | 2,116 | cum |
| 2 | Spreading the available earth in layers of 25cm thick including watering upto Optimum moisture content, consolidation by power roller (Forming bund above GL from suitable excavated earth & laid in layers, watering, ramming & consolidation by rollers as per standard specifications as directed by the Departmental Engineer. | 1 | | | | 2,276 | cum |
| 3 | Supplying & laying of gravel 150 mm thick below precast slab, levelling the layer, watering and consolidation etc all complete as per standard specification and as directed by the Departmental Engineer. | | | | | | |
| | Anaerobic ponds | | | | | | |
| | Sides | 2 | 64.00 | 4.95 | 0.15 | 95.04 | |
| | Top of bund | 2 | 84.00 | 1.50 | 0.15 | 37.80 | |
| | Facultative ponds | | | | | | |
| | Sides | 2 | 86.00 | 2.83 | 0.15 | 73.01 | |
| | Top of bund | 2 | 92.00 | 1.50 | 0.15 | 41.40 | |
| | Maturation ponds | | | | | | |
| | Sides | 4 | 74.00 | 2.48 | 0.15 | 110.11 | |
| | Top of bund | 4 | 80.00 | 1.50 | 0.15 | 72.00 | |
| | Net quantity | | | | | 429.00 | cum |
| 4 | Supplying and seeding of grass at 50 mm c/c including preparation of earth with sweet earth, 150 mm thick, watering and maintaining the lawn upto 6 months etc all complete as directed by the Engineer. | | | | | | |
| | Anaerobic ponds | | | | | | |
| | sides | 2 | 79.00 | 3.53 | | 557.74 | |
| | bottom | 2 | 92.00 | 1.00 | | 184.00 | |
| | Facultative ponds | | | | | | |
| | sides | 2 | 100.10 | 3.29 | | 658.66 | |
| | bottom | 2 | 112.20 | 1.00 | | 224.40 | |
| | Maturation ponds | | | | | | |
| | sides | 4 | 84.20 | 2.37 | | 798.22 | |
| | bottom | 4 | 92.20 | 1.00 | | 368.80 | |
| | Net quantity | | | | | 2,791.00 | Sqm |
| 5 | Supplying and fixing in position RCC precast slabs of 450 x 450 x 50 mm over the bed of gravel to proper level etc all complete as directed by Engineer | | | | | | |
| | Anaerobic ponds | 2 | 64.00 | 4.95 | | 633.60 | |
| | Facultative ponds | 2 | 86.00 | 2.83 | | 486.76 | |
| | Maturation ponds | 4 | 74.00 | 2.48 | | 734.08 | |
| | Net quantity | | | | | 1,854.00 | Sqm |

| Sl. No. | Description of item | No. | L (m) | B (m) | D (m) | Quantity | Unit |
|---------|---|-----|--------|-------|-------|---------------|------------|
| 6 | Construction of toe wall etc all complete as per standard specification or as directed by the Engineer. | | | | | | |
| | Anaerobic ponds | 2 | 56.16 | | | 112.32 | |
| | Facultative ponds | 2 | 68.16 | | | 136.32 | |
| | Maturation ponds | 4 | 58.16 | | | 232.64 | |
| | Net quantity | | | | | 481.28 | Rmt |
| a) | Earth work excavation & depositing on bank with an initial lead of 30 m & lift of 2 m for depths in hard stiff clay, stiff black cotton, hard red earth mixed with small sized boulders & hard gravelly etc all complete as per standard specification and as directed by Engineer. | 1 | 481.28 | 0.43 | 0.33 | 68.29 | cum |
| b) | Providing and laying base concrete in foundation using Plain Cement Concrete 1:3:6 including consolidation and levelling etc as per standard specifications | 1 | 481.28 | 0.43 | 0.10 | 20.70 | cum |
| c) | Construction of brick masonry with class II bricks in CM 1:6 in foundation including curing etc all complete as per standard specifications. | 1 | 481.28 | 0.23 | 0.23 | 25.46 | cum |
| d) | Plastering with C.M 1:4, 12 mm thick including necessary scaffolding, watering the surface etc all complete as per standard specification. | 1 | 481.28 | 0.69 | | 332.08 | sqm |
| 7 | Supplying & laying reinforced cement concrete of M 25 grade using machine crushed hard broken granite stone jelly 20 mm for RCC works in all types of foundations, floor slabs of all shapes (Excluding cost of providing centering & fabrication of reinforcements which shall be measured & paid under separate items) including curing, complying with standard specifications as directed by the Departmental Engineer using sulphate resisting cement. | | | | | | |
| a | RCC for inlet chamber | | | | | | |
| | Columns | 12 | 0.23 | 0.23 | 2.00 | 1.27 | |
| | Base slab | 2 | 7.45 | 2.30 | 0.20 | 6.85 | |
| | Vertical walls | 2 | 18.90 | 1.10 | 0.15 | 6.24 | |
| | Partition wall | 2 | 2.00 | 1.10 | 0.15 | 0.66 | |
| | Foundation | 12 | 1.20 | 1.20 | 0.50 | 8.64 | |

| Sl. No. | Description of item | No. | L (m) | B (m) | D (m) | Quantity | Unit |
|---------|---|-------|--------|-------|-------|-----------------|--------------|
| b | Refer Enclosure | | | | | 30.07 | |
| | Total | | | | | 53.73 | 24cum |
| 8 | Supplying & erecting centering for sides & walls of outlet chamber including supports & strutting for plain surfaces with all cross bracings using 25 mm thick boards suitable purlined over silver oak (country wood) joists of size 10 x 6.5 cm spaced at about 90 cm centre to centre & supported by causerina props 10 to 13 cm diameter spaced at about 75 cm c/c etc. complete complying with standard specifications. Centering for RCC works below GL (wall). | | | | | | |
| | Columns | 12 | 0.69 | 2.00 | | 16.56 | |
| | Base slab | 2 | 7.45 | 2.30 | | 34.27 | |
| | Vertical walls | 4 | 18.90 | 1.10 | | 83.16 | |
| | Partition wall | 4 | 2.00 | 1.10 | | 8.80 | |
| | Foundation | 12 | 1.20 | 1.20 | | 17.28 | |
| | Total | | | | | 160.07 | sqm |
| 9 | Supplying, fabricating & placing in position MS or deformed steel bars for all RCC items of work including cost of steel transporting, straightening, cutting, bending, cranking, binding etc. including cost of binding wire charids, laps to fix the reinforcement in all positions, all labour & materials complete complying with standard specifications & drawings as directed by the Departmental Engineer. | | | | | | |
| | Walls | 16.81 | 100.00 | | | 1,680.66 | |
| | Floors | 6.85 | 70.00 | | | 479.78 | |
| | Total | | | | | 2,160.44 | Kg |
| 10 | Supply of NP 3 class RCC pipes as per IS:783, lowering into trenches, laying to proper grade and alignment, cutting the pipes true to axis & jointing the pipes & specials with cement mortar joints including cost of jointing material, testing the pipe to the required pressure as directed by the Departmental Engineer including barricading, provision of danger lights, arranging for watch & ward etc., complete as per specifications at different depths. | | | | | | |
| | 350 mm diameter | 1 | 600 | | | 600 | Rmt |
| 11 | Supplying, delivery, spreading & fixing of LDPE sheet in all the Anaerobic, Facultative & Maturation ponds for avoiding the seepage / infiltration including transportation and labour charges etc complete as per standard specification and as directed by Engineer-in-charge. | | | | | | |
| | Anaerobic Pond | 2 | 20 | 9 | | 360 | |
| | Facultative Pond | 2 | 25 | 10 | | 500 | |
| | Maturation Pond | 4 | 20 | 10 | | 800 | |
| | Net quantity | | | | | 1,660 | sqm |

RCC Estimation for STP

| Description of Item | CL | W | H | Volume |
|--------------------------------|-----------|----------|----------|---------------|
| <i>Anerobic Pond</i> | | | | |
| Wall A | 1.80 | 0.15 | 2.00 | 0.540 |
| Wall B | 1.50 | 0.15 | 1.00 | 0.225 |
| Wall C | 1.50 | 0.08 | 0.30 | 0.036 |
| | | | | 0.801 |
| <i>Wing Walls</i> | | | | |
| abb'c'a' | 0.50 | 0.15 | 1.72 | 0.129 |
| bb'c | 0.22 | 0.15 | 0.22 | 0.004 |
| b'c'dd'f'c | 1.50 | 0.15 | 1.50 | 0.338 |
| ded' | 1.50 | 0.15 | 1.50 | 0.169 |
| f'd'ef | 2.20 | 0.15 | 2.20 | 0.363 |
| | | | | 1.002 |
| For 2 Wing Walls | | | | 2.004 |
| <i>Flooring (Slab)</i> | | | | |
| a'c'f | 1.80 | 1.80 | 0.15 | 0.486 |
| ff | 3.11 | 1.80 | 0.15 | 0.840 |
| fg | 0.15 | 1.80 | 0.30 | 0.081 |
| | | | | 1.407 |
| Grand Total | | | | 4.211 |
| <i>Maturation Pond</i> | | | | |
| Item | CL | W | H | Volume |
| Wall A | 1.80 | 0.15 | 2.00 | 0.540 |
| Wall B | 1.50 | 0.15 | 0.85 | 0.191 |
| Wall C | 1.50 | 0.15 | 0.50 | 0.113 |
| | | | | 0.844 |
| <i>Wing Walls</i> | | | | |
| abkij | 0.50 | 0.15 | 1.75 | 0.131 |
| bck | 0.50 | 0.15 | 0.50 | 0.019 |
| kcdhgi | 1.58 | 0.15 | 1.25 | 0.296 |
| deh | 0.75 | 0.15 | 0.75 | 0.042 |
| efgh | 0.75 | 0.15 | 0.50 | 0.056 |
| | | | | 0.545 |
| For 2 Wing Walls | | | | 1.089 |
| <i>Flooring (Slab)</i> | | | | |
| Flooring | 1.90 | 1.80 | 0.15 | 0.513 |
| Projection | 0.15 | 1.80 | 0.15 | 0.041 |
| | | | | 0.554 |
| Grand Total | | | | 2.487 |
| <i>Facultative Pond</i> | | | | |
| Item | CL | W | H | Volume |
| Wall A | 1.80 | 0.15 | 2.50 | 0.675 |
| Wall B | 1.50 | 0.15 | 1.00 | 0.225 |
| Wall C | 1.50 | 0.08 | 0.80 | 0.096 |
| | | | | 0.996 |
| <i>Wing Walls</i> | | | | |
| abjik | 0.50 | 0.15 | 2.15 | 0.161 |
| bcj | 0.70 | 0.15 | 0.70 | 0.037 |
| dgjj | 1.55 | 0.15 | 1.45 | 0.337 |
| deh | 0.95 | 0.15 | 0.95 | 0.068 |
| efgh | 0.95 | 0.15 | 0.50 | 0.071 |
| | | | | 0.674 |
| For 2 Wing Walls | | | | 1.348 |
| <i>Flooring (Slab)</i> | | | | |
| Flooring | 2.15 | 1.80 | 0.15 | 0.581 |

| Description of Item | CL | W | H | Volume |
|-------------------------|-----------|----------|----------|---------------|
| Grand Total | | | | 2.925 |
| Reinforcement | | | | |
| slabs @ 70 kg/cum | 7.3494 | 70 | | 514.458 |
| Wall @ 100 kg/cum | 22.7185 | 100 | | 2271.852 |
| | 30.0679 | | | 2786.31 |
| Centring | | | | |
| Wall A | 1.80 | - | 2.00 | 3.600 |
| Wall B | 1.50 | - | 1.00 | 1.500 |
| Wall C | 1.50 | - | 0.30 | 0.450 |
| | | | | 5.550 |
| Wing Walls | | | | |
| abb'c'a' | 0.50 | - | 1.72 | 0.860 |
| bb'c | 0.22 | - | 0.22 | 0.048 |
| b'c'dd'fc | 1.50 | - | 1.50 | 2.250 |
| ded' | 1.50 | - | 1.50 | 2.250 |
| fd'ef | 2.20 | - | 2.20 | 4.840 |
| | | | | 10.248 |
| For 2 Wing Walls | | | | 20.497 |
| Flooring (Slab) | | | | |
| a'c'f | 1.80 | 1.80 | - | 3.240 |
| ff | 3.11 | 1.80 | - | 5.598 |
| fg | - | 1.80 | 0.30 | 0.540 |
| | | | | 9.378 |
| Grand Total | | | | 35.425 |
| Maturation Pond | | | | |
| Item | CL | W | H | Volume |
| Wall A | 1.80 | - | 2.00 | 3.600 |
| Wall B | 1.50 | - | 0.85 | 1.275 |
| Wall C | 1.50 | - | 0.50 | 0.750 |
| | | | | 5.625 |
| Wing Walls | | | | |
| abkij | 0.50 | - | 1.75 | 0.875 |
| bck | 0.50 | - | 0.50 | 0.250 |
| kcdhgi | 1.58 | - | 1.25 | 1.975 |
| deh | 0.75 | - | 0.75 | 0.563 |
| efgh | 0.75 | - | 0.50 | 0.375 |
| | | | | 4.038 |
| For 2 Wing Walls | | | | 8.075 |
| Flooring (Slab) | | | | |
| Flooring | 1.90 | 1.80 | - | 3.420 |
| Projection | 0.15 | 1.80 | - | 0.270 |
| | | | | 3.690 |
| Grand Total | | | | 17.390 |
| Facultative Pond | | | | |
| Item | CL | W | H | Volume |
| Wall A | 1.80 | - | 2.50 | 4.500 |
| Wall B | 1.50 | - | 1.00 | 1.500 |
| Wall C | 1.50 | - | 0.80 | 1.200 |
| | | | | 7.200 |
| Wing Walls | | | | |
| abjik | 0.50 | - | 2.15 | 1.075 |
| bcj | 0.70 | - | 0.70 | 0.490 |
| dgij | 1.55 | - | 1.45 | 2.248 |
| deh | 0.95 | - | 0.95 | 0.903 |
| efgh | 0.95 | - | 0.50 | 0.475 |
| | | | | 5.190 |

| Description of Item | CL | W | H | Volume |
|------------------------|------|------|---|---------------|
| For 2 Wing Walls | | | | 10.380 |
| <i>Flooring (Slab)</i> | | | | |
| Flooring | 2.15 | 1.80 | - | 3.870 |
| Total | | | | 21.450 |

226.2096

Summary

| Component | East Zone | West Zone | Total | RCC (cum) | Total RCC (cum) |
|---------------------------|-----------|-----------|-------|-----------|-----------------|
| Anerobic Pond | 1 | 1 | 2 | 4.211 | 8.423 |
| Maturation Pond | 2 | 2 | 4 | 2.487 | 9.947 |
| Facultative Pond | 2 | 2 | 4 | 2.925 | 11.699 |
| TOTAL RCC QUANTITY | | | | | 30.07 |

Earthwork & Refilling Quantity for new STP

| Sl. No. | Description | Height (m) | Bottom Width (m) | Top Width (m) | Area (sqm) | Length (m) | Volume | Total |
|---------|-----------------------------------|------------|------------------|---------------|------------|------------|-----------|-----------|
| | Bunds | | | | | | | |
| 1 | Point A | 1.49 | 5.21 | 1.50 | 5.00 | | | |
| 2 | Point B | 1.41 | 5.03 | 1.50 | 4.60 | | | |
| 3 | Point C | 0.78 | 3.45 | 1.50 | 1.93 | | | |
| | | | | | 3.84 | 114 | 438.26 | |
| 4 | Point D | 1.90 | 6.25 | 1.50 | 7.36 | | | |
| 5 | Point E | 1.05 | 4.11 | 1.50 | 2.95 | | | |
| 6 | Point F | 1.19 | 4.46 | 1.50 | 3.55 | | | |
| | | | | | 3.94 | 297 | 1,170.18 | |
| 7 | Point G | 1.40 | 5.00 | 1.50 | 4.55 | | | |
| | | | | | 4.05 | 93 | 376.47 | |
| 8 | Point H | 1.43 | 5.06 | 1.50 | 4.69 | | | |
| 9 | Point I | 1.97 | 6.41 | 1.50 | 7.79 | | | |
| | | | | | 5.50 | 298 | 1,639.00 | |
| 10 | Point J | 1.06 | 4.15 | 1.50 | 2.99 | | | |
| 11 | Point K | 0.79 | 3.48 | 1.50 | 1.97 | | | |
| | | | | | 3.31 | 297 | 983.07 | |
| 12 | Point L | 1.59 | 5.48 | 1.50 | 5.55 | | | |
| 13 | Point M | 1.34 | 4.84 | 1.50 | 4.25 | | | |
| | | | | | 5.85 | 300 | 1,755.00 | |
| 14 | Point N | 0.89 | 3.71 | 1.50 | 2.32 | | | |
| | | | | | 3.27 | 252 | 824.04 | |
| 15 | Point O | 1.26 | 4.64 | 1.50 | 3.87 | | | |
| | | | | | 3.57 | 252 | 899.64 | |
| A | Total Earth from Existing Bunds | | | | | | 8,085.66 | 8086 cum |
| 16 | Silt in Inlet Zone | | | | | | 12,316.50 | |
| 17 | Silt in West Zone | | | | | | 16,417.50 | |
| 18 | Silt in East Zone | | | | | | 8,250.00 | |
| B | Total Silt | | | | | | 36,984.00 | 36984 cum |
| | For New Treatment Plant | | | | | | | |
| | WEST ZONE | | | | | | | |
| a | Anerobic Pond | 1.90 | 6.25 | 1.50 | 7.36 | 253.00 | 1,862.08 | |
| | Bottom Filling | | | | | | 367.78 | |
| b | Facultative Pond | 1.75 | 5.88 | 1.50 | 6.45 | 727.50 | 4,692.38 | |
| c | FP-Central Bund | 2.00 | 6.50 | 1.50 | 8.00 | 199.25 | 1,594.00 | |
| | Bottom Filling | | | | | | 7,435.16 | |
| d | Maturation Pond | 1.15 | 4.38 | 1.50 | 3.38 | 574.00 | 1,940.12 | |
| e | MP-Central Bund | 1.75 | 5.88 | 1.50 | 6.45 | 169.00 | 1,090.05 | |
| C | Bottom Cutting | | | | | | 2,656.80 | 2657 cum |
| | Total Earth for Bunds and Filling | | | | | | 18,983.92 | 18984 cum |
| | EAST ZONE | | | | | | | |
| f | Anerobic Pond | 1.75 | 5.88 | 1.50 | 6.45 | 214.00 | 1,380.30 | |
| | Bottom Filling | | | | | | 194.59 | |
| g | Facultative Pond | 1.65 | 5.63 | 1.50 | 5.88 | 601.50 | 3,536.82 | |
| h | FP-Central Bund | 2.00 | 6.50 | 1.50 | 8.00 | 164.25 | 1,314.00 | |
| | Bottom Filling | | | | | | 1,494.23 | |
| D | Cutting New Area | | | | | | 1,276.35 | |
| E | Cutting Triangle Area | | | | | | 9.56 | |
| I | Maturation Pond | 1 | 4 | 1.5 | 2.75 | 474 | 1,303.50 | |
| j | MP-Central Bund | 1.75 | 5.875 | 1.5 | 6.453 | 139 | 896.98 | |
| F | Bottom Cutting | | | | | | 2,653.20 | |
| G | Cutting New Area | | | | | | 2,690.81 | |
| H | Cutting Triangle Area | | | | | | 43.02 | |
| | Total Earth for Bunds and Filling | | | | | | 9,925.38 | 9929 cum |
| | Earth from Cutting | | | | | | 6,867.52 | 6868 cum |

| Sl. No. | Description | Height (m) | Bottom Width (m) | Top Width (m) | Area (sqm) | Length (m) | Volume | Total |
|---------|---|------------|------------------|---------------|------------|------------|-----------|-----------|
| | Filling Area in Inlet | | | | | | 17,365.14 | |
| | Filling Area in between Facultative Ponds | | | | | | 2,653.74 | |
| | Filling behind M Pond | | | | | | 1,902.05 | |
| | Total Filling in Existing STP | | | | | | 21,920.93 | 21921 cum |
| | Summary | | | | | | | |
| | Total Earthwork in cutting | | | | | | | |
| | (A + B + C + D + E + F + G + H) | | | | | | | |
| | Total bund making | | | | | | | |
| | (a + b + c + d + e + f + g + h + i + j) | | | | | | | |

**Design of Sewage Treatment Plant (Waste Stabilisation Pond) - for Ward 45
Ambattur Municipality - 0.4 Mld**

| | | |
|------------------------|---|---------------------------------|
| Total Flow, Q | = | 400000 litres |
| | = | 400 cum |
| BOD of incoming sewage | = | 250 mg/l |
| Mean Temperature | = | 30 C |
| Fecal Coliform | = | 80 x 10 ⁵ MPN/ 100ml |

1. Design of Anaerobic Pond

| | | |
|----------------------------------|---|-------------|
| Retention time (Assumed) | = | 5 days |
| Depth of Pond | = | 3 m |
| Area of Pond = Q x t / D | | |
| Where Q = Flow in m ³ | = | 400.00 cum |
| t = Retention period in days | | |
| D = Depth in metres. | | |
| Area of Pond | = | 666.667 sqm |

Provide 2 ponds of size 26 x 13 x 3m

| | | |
|----------------------------------|---|------------|
| Area of Pond | = | 676 sqm |
| Actual retention time | = | 5.07 days |
| BOD reduction in anaerobic pond | = | 56.00 % |
| BOD of effluent | = | 110 mg/l |
| Quantity of effluent = Q-0.001Ae | = | 393.24 cum |
| Where Q = Flow in m ³ | | |
| A = Area of Pond in Sq.m | | |
| e = Evaporation in mm (10mm) | | |

2. Design of Facultative Pond

| | | |
|--|---|------------------|
| Retention time (Assumed) | = | 5 days |
| Influent BOD | = | 110 mg/l |
| Area of Pond = $Q \times (L_i - L_e) / 18 \times D \times (1.05)^{T-20}$ | | |
| Where Q = Flow in m ³ | = | 393.24 cum |
| T = Mean temperature | = | 30 °C |
| L _i = BOD of Influent | = | 110 mg/l |
| L _e = BOD of effluent (Assumed) | = | 60 mg/l |
| Depth of Pond, D in metres | = | 1.5 m |
| Area of Pond | = | 447.07 sqm |
| Organic Loading = 10Q L _i / A | = | 967.56 kg/ha.day |
| Permissible Organic loading = 20T-120 | = | 480 kg/ha.day |

As the organic loading rate is greater than the permissible organic loading rate the area of the pond as to be increased

Provide 2 ponds of size 30 x 15 x 1.5m

| | | |
|---|---|------------------|
| Area provided | = | 900 sq.m |
| Now the organic loading rate = 10Q L _i / A | = | 480.63 kg/ha.day |
| | < | 480 kg/ha.day |

Hence OK

| | | |
|---|---|----------------------------|
| Actual Retention time, V/Q | = | 3.43 days |
| BOD of Effluent, $L_e = L_i / 1 + (0.3 \times (1.05)^{T-20} \times t)$ | = | 41.08 mg/l |
| Quantity of effluent = $Q \times 0.001 A e$ | = | 384.24 cum |
| Where Q = Flow in m^3 | | |
| A = Area of Pond in Sq.m | | |
| e = Evaporation in mm (10mm) | | |
| 3. Design of Maturation Pond | | |
| Retention time (Assumed) | = | 3.5 days |
| Depth of Pond | = | 1.5 m |
| Area of Pond = $Q \times t / D$ | = | 896.56 |
| Where Q = Flow in m^3 | = | 384.24 cum |
| t = Retention period in days | | |
| D = Depth in metres. | | |
| Area of Pond | = | 896.56 sqm |
| Provide 2 x 2 ponds of size 30 x 15x 1.5m | | |
| Area of Pond | = | 900 sqm |
| Actual retention time | = | 3.51 days |
| Check for Bacterial Quality | | |
| Fecal Coliform in raw sewerage (Assumed), N_i | = | 80×10^5 MPN/100ml |
| Rate Constant, $K_{b(T)} = 2.6 \times (1.19)^{T-20}$ | = | 14.81 |
| Fecal Coliform in treated sewerage, N_e | | |
| $= N_i / (1 + K_b \times t_{an}) (1 + K_b \times t_{fac}) (1 + K_b \times t_m)^2$ | = | 0.72 MPN/100ml |
| | < | 100 MPN/100ml |
| Hence OK | | |
| Actual Retention time, V/Q | = | 3.51 days |
| BOD of Effluent, $L_e = L_i / (1 + (0.3 \times (1.05)^{T-20} \times t)^2)$ | = | 5.57 mg/l |
| | < | 20.00 mg/l |
| Hence OK | | |

**Abstract Estimate for 0.4 Mld Waste Stabilisation Pond Treatment Plant at Ward No.45
Ambattur Municipality**

| Sl. No. | Description of item | Quantity | Unit | Rate (Rs.) | Amount (Rs.) |
|---------|--|----------|------|------------|--------------|
| 1 | Earth work excavation & depositing on bank with an initial lead of 30 m & lift of 2 m for depths in hard stiff clay, stiff black cotton, hard red earth mixed with small sized boulders & hard gravely etc all complete as per standarad specification and as directed by Engineer. | 4,397 | cum | 28.75 | 126,413.75 |
| | (As per Data Bank - Lead Charges) | | | | |
| 2 | Spreading the available earth in layers of 25cm thick including watering upto Optimum moisture content, consolidation by power roller (Forming bund above GL from suitable excavated earth & laid in layers, watering, ramming & consolidation by rollers as per standard specifications as directed by the Departmental Engineer. | 3,014 | cum | 30.60 | 92,228.40 |
| | (As per Data Bank - Lead Charges) | | | | |
| 3 | Supplying & laying of gravel 150 mm thick below precast slab, levelling the layer, watering and consolidation etc all complete as per standard specification and as directed by the Departmental Engineer. | 563 | cum | 185.40 | 104,380.20 |
| | (As per Data Bank - Lead Charges) | | | | |
| 4 | Supplying and seeding of grass at 50 mm c/c including preparation of earth with sweet earth, 150 mm thick, watering and maintaining the lawn upto 6 months etc all complete as directed by the Engineer. | 3,936 | sqm | 48.05 | 189,124.80 |
| | (As per Data Bank - Lead Charges) | | | | |
| 5 | Supplying and fixing in position RCC precast slabs of 450 x 450 x 50 mm over the bed of gravel to proper level etc all complete as directed by Engineer | 2,427 | sqm | 151.58 | 367,884.70 |
| | (As per Data Bank - Lead Charges) | | | | |
| 6 | Construction of toe wall etc all complete as per standard specification or as directed by the Engineer. | | | | |
| a) | Earth work excavation & depositing on bank with an initial lead of 30 m & lift of 2 m for depths in hard stiff clay, stiff black cotton, hard red earth mixed with small sized boulders & hard gravely etc all complete as per standarad specification and as directed by Engineer. | 96.67 | cum | 28.75 | 2,779.00 |
| b) | Providing and laying base concrete in foundation using Plain Cement Concrete 1:3:6 including consolidation and levelling etc as per standard specifications | 29.30 | cum | 2,110.00 | 61,812.55 |
| c) | Construction of brick masonry with class II bricks in CM 1:6 in foundation including curing etc all complete as per standard specifications. | 36.04 | cum | 2,371.00 | 85,456.00 |
| d) | Plastering with C.M 1:4, 12 mm thick including necessary scaffolding, watering the surface etc all complete as per standard specification. | 470.08 | sqm | 64.00 | 30,090.00 |
| | (As per Data Bank - Lead Charges) | | | | |

| Sl. No. | Description of item | Quantity | Unit | Rate (Rs.) | Amount (Rs.) |
|-------------------|---|----------|------|------------|------------------|
| 7 | Supplying & laying reinforced cement concrete of M 25 grade using machine crushed hard broken granite stone jelly 20 mm for RCC works in all types of foundations, floor slabs of all shapes (Excluding cost of providing centering & fabrication of reinforcements which shall be measured & paid under separate items) including curing, complying with standard specifications as directed by the Departmental Engineer using sulphate resisting cement. | 53.73 | cum | 3,258.00 | 175,053.00 |
| | (As per Data Bank - Lead Charges) | | | | |
| 8 | Supplying & erecting centering for sides & walls of outlet chamber including supports & strutting for plain surfaces with all cross bracings using 25 mm thick boards suitable purlined over silver oak (country wood) joists of size 10 x 6.5 cm spaced at about 90 cm centre to centre & supported by causerina props 10 to 13 cm diameter spaced at about 75 cm c/c etc. complete complying with standard specifications. Centering for RCC works below GL (wall). | 160.07 | sqm | 428.00 | 68,510.00 |
| 9 | Supplying, fabricating & placing in position MS or deformed steel bars for all RCC items of work including cost of steel transporting, straightening, cutting, bending, cranking, binding etc. including cost of binding wire charids, laps to fix the reinforcement in all positions, all labour & materials complete complying with standard specifications & drawings as directed by the Departmental Engineer. | 2,160.44 | kg | 51.00 | 110,182.00 |
| 10 | Supply of NP 3 class RCC pipes as per IS:783, lowering into trenches, laying to proper grade and alignment, cutting the pipes true to axis & jointing the pipes & specials with cement mortar joints including cost of jointing material, testing the pipe to the required pressure as directed by the Departmental Engineer including barricading, provision of danger lights, arranging for watch & ward etc., complete as per specifications at different depths. | | | | |
| | 350 mm diameter | 600 | m | 616.50 | 369,900.00 |
| 15 | Supplying, delivery, spreading & fixing of LDPE sheet in all the Anaerobic, Facultative & Maturation ponds for avoiding the seepage / infiltration including transportation and labour charges etc complete as per standard specification and as directed by Engineer-in-charge. | 1,660 | sqm | 100.00 | 166,000.00 |
| 16 | Effluent Pump | | LS | | 10,000 |
| Total Cost | | | | | 1,959,814 |

Say Rs.19.60 Lakhs

**Detailed Estimate for 0.4 Mld Waste Stabilisation Pond Treatment Plant at Ward NO.45
Ambattur Municipality**

| Sl. No. | Description of item | No. | L (m) | B (m) | D (m) | Quantity | Unit |
|---------|---|-----|--------|-------|-------|-----------------|------------|
| 1 | Earth work excavation & depositing on bank with an initial lead of 30 m & lift of 2 m for depths in hard stiff clay, stiff black cotton, hard red earth mixed with small sized boulders & hard gravelly etc all complete as per standard specification and as directed by Engineer. | 1 | | | | 4,397 | cum |
| 2 | Spreading the available earth in layers of 25cm thick including watering upto Optimum moisture content, consolidation by power roller (Forming bund above GL from suitable excavated earth & laid in layers, watering, ramming & consolidation by rollers as per standard specifications as directed by the Departmental Engineer. | 1 | | | | 3,014 | cum |
| 3 | Supplying & laying of gravel 150 mm thick below precast slab, levelling the layer, watering and consolidation etc all complete as per standard specification and as directed by the Departmental Engineer. | | | | | | |
| | Anaerobic ponds | | | | | | |
| | Sides | 2 | 92.00 | 4.95 | 0.15 | 136.62 | |
| | Top of bund | 2 | 112.00 | 1.50 | 0.15 | 50.40 | |
| | Facultative ponds | | | | | | |
| | Sides | 2 | 98.00 | 2.83 | 0.15 | 83.20 | |
| | Top of bund | 2 | 112.00 | 1.50 | 0.15 | 50.40 | |
| | Maturation ponds | | | | | | |
| | Sides | 4 | 97.00 | 2.48 | 0.15 | 144.34 | |
| | Top of bund | 4 | 110.00 | 1.50 | 0.15 | 99.00 | |
| | Net quantity | | | | | 563.00 | cum |
| 4 | Supplying and seeding of grass at 50 mm c/c including preparation of earth with sweet earth, 150 mm thick, watering and maintaining the lawn upto 6 months etc all complete as directed by the Engineer. | | | | | | |
| | Anaerobic ponds | | | | | | |
| | sides | 2 | 127.00 | 3.53 | | 896.62 | |
| | bottom | 2 | 140.00 | 1.00 | | 280.00 | |
| | Facultative ponds | | | | | | |
| | sides | 2 | 126.10 | 3.29 | | 829.74 | |
| | bottom | 2 | 138.30 | 1.00 | | 276.60 | |
| | Maturation ponds | | | | | | |
| | sides | 4 | 120.20 | 2.37 | | 1,139.50 | |
| | bottom | 4 | 128.40 | 1.00 | | 513.60 | |
| | Net quantity | | | | | 3,936.00 | Sqm |
| 5 | Supplying and fixing in position RCC precast slabs of 450 x 450 x 50 mm over the bed of gravel to proper level etc all complete as directed by Engineer | | | | | | |
| | Anaerobic ponds | 2 | 92.00 | 4.95 | | 910.80 | |
| | Facultative ponds | 2 | 98.00 | 2.83 | | 554.68 | |
| | Maturation ponds | 4 | 97.00 | 2.48 | | 962.24 | |
| | Net quantity | | | | | 2,427.00 | Sqm |

| Sl. No. | Description of item | No. | L (m) | B (m) | D (m) | Quantity | Unit |
|---------|--|-----|--------|-------|-------|---------------|------------|
| 6 | Construction of toe wall etc all complete as per standard specification or as directed by the Engineer. | | | | | | |
| | Anaerobic ponds | 2 | 76.16 | | | 152.32 | |
| | Facultative ponds | 2 | 88.16 | | | 176.32 | |
| | Maturation ponds | 4 | 88.16 | | | 352.64 | |
| | Net quantity | | | | | 681.28 | Rmt |
| a) | Earth work excavation & depositing on bank with an initial lead of 30 m & lift of 2 m for depths in hard stiff clay, stiff black cotton, hard red earth mixed with small sized boulders & hard gravelly etc all complete as per standard specification and as directed by Engineer. | 1 | 681.28 | 0.43 | 0.33 | 96.67 | cum |
| b) | Providing and laying base concrete in foundation using Plain Cement Concrete 1:3:6 including consolidation and levelling etc as per standard specifications | 1 | 681.28 | 0.43 | 0.10 | 29.30 | cum |
| c) | Construction of brick masonry with class II bricks in CM 1:6 in foundation including curing etc all complete as per standard specifications. | 1 | 681.28 | 0.23 | 0.23 | 36.04 | cum |
| d) | Plastering with C.M 1:4, 12 mm thick including necessary scaffolding, watering the surface etc all complete as per standard specification. | 1 | 681.28 | 0.69 | | 470.08 | sqm |
| 7 | Supplying & laying reinforced cement concrete of M 25 grade using machine crushed hard broken granite stone jelly 20 mm for RCC works in all types of foundations, floor slabs of all shapes (Excluding cost of providing centering & fabrication of reinforcements which shall be measured & paid under separate items) including curing, complying with standard specifications as directed by the Departmental Engineer using sulphate resisting cement. | | | | | | |
| a | RCC for inlet chamber | | | | | | |
| | Columns | 12 | 0.23 | 0.23 | 2.00 | 1.27 | |
| | Base slab | 2 | 7.45 | 2.30 | 0.20 | 6.85 | |
| | Vertical walls | 2 | 18.90 | 1.10 | 0.15 | 6.24 | |
| | Partition wall | 2 | 2.00 | 1.10 | 0.15 | 0.66 | |
| | Foundation | 12 | 1.20 | 1.20 | 0.50 | 8.64 | |

| Sl. No. | Description of item | No. | L (m) | B (m) | D (m) | Quantity | Unit |
|---------|---|-------|--------|-------|-------|-----------------|--------------|
| b | Refer Enclosure | | | | | 30.07 | |
| | Total | | | | | 53.73 | 24cum |
| 8 | Supplying & erecting centering for sides & walls of outlet chamber including supports & strutting for plain surfaces with all cross bracings using 25 mm thick boards suitable purlined over silver oak (country wood) joists of size 10 x 6.5 cm spaced at about 90 cm centre to centre & supported by causerina props 10 to 13 cm diameter spaced at about 75 cm c/c etc. complete complying with standard specifications. Centering for RCC works below GL (wall). | | | | | | |
| | Columns | 12 | 0.69 | 2.00 | | 16.56 | |
| | Base slab | 2 | 7.45 | 2.30 | | 34.27 | |
| | Vertical walls | 4 | 18.90 | 1.10 | | 83.16 | |
| | Partition wall | 4 | 2.00 | 1.10 | | 8.80 | |
| | Foundation | 12 | 1.20 | 1.20 | | 17.28 | |
| | Total | | | | | 160.07 | sqm |
| 9 | Supplying, fabricating & placing in position MS or deformed steel bars for all RCC items of work including cost of steel transporting, straightening, cutting, bending, cranking, binding etc. including cost of binding wire charids, laps to fix the reinforcement in all positions, all labour & materials complete complying with standard specifications & drawings as directed by the Departmental Engineer. | | | | | | |
| | Walls | 16.81 | 100.00 | | | 1,680.66 | |
| | Floors | 6.85 | 70.00 | | | 479.78 | |
| | Total | | | | | 2,160.44 | Kg |
| 10 | Supply of NP 3 class RCC pipes as per IS:783, lowering into trenches, laying to proper grade and alignment, cutting the pipes true to axis & jointing the pipes & specials with cement mortar joints including cost of jointing material, testing the pipe to the required pressure as directed by the Departmental Engineer including barricading, provision of danger lights, arranging for watch & ward etc., complete as per specifications at different depths. | | | | | | |
| | 350 mm diameter | 1 | 600 | | | 600 | Rmt |
| 11 | Supplying, delivery, spreading & fixing of LDPE sheet in all the Anaerobic, Facultative & Maturation ponds for avoiding the seepage / infiltration including transportation and labour charges etc complete as per standard specification and as directed by Engineer-in-charge. | | | | | | |
| | Anaerobic Pond | 2 | 20 | 9 | | 360 | |
| | Facultative Pond | 2 | 25 | 10 | | 500 | |
| | Maturation Pond | 4 | 20 | 10 | | 800 | |
| | Net quantity | | | | | 1,660 | sqm |

RCC Estimation for STP

| Description of Item | CL | W | H | Volume |
|-------------------------|-----------|----------|----------|---------------|
| Anerobic Pond | | | | |
| Wall A | 1.80 | 0.15 | 2.00 | 0.540 |
| Wall B | 1.50 | 0.15 | 1.00 | 0.225 |
| Wall C | 1.50 | 0.08 | 0.30 | 0.036 |
| | | | | 0.801 |
| Wing Walls | | | | |
| abb'c'a' | 0.50 | 0.15 | 1.72 | 0.129 |
| bb'c | 0.22 | 0.15 | 0.22 | 0.004 |
| b'c'dd'f'c | 1.50 | 0.15 | 1.50 | 0.338 |
| ded' | 1.50 | 0.15 | 1.50 | 0.169 |
| f'd'ef | 2.20 | 0.15 | 2.20 | 0.363 |
| | | | | 1.002 |
| For 2 Wing Walls | | | | 2.004 |
| Flooring (Slab) | | | | |
| a'c'f | 1.80 | 1.80 | 0.15 | 0.486 |
| ff | 3.11 | 1.80 | 0.15 | 0.840 |
| fg | 0.15 | 1.80 | 0.30 | 0.081 |
| | | | | 1.407 |
| Grand Total | | | | 4.211 |
| Maturation Pond | | | | |
| Item | CL | W | H | Volume |
| Wall A | 1.80 | 0.15 | 2.00 | 0.540 |
| Wall B | 1.50 | 0.15 | 0.85 | 0.191 |
| Wall C | 1.50 | 0.15 | 0.50 | 0.113 |
| | | | | 0.844 |
| Wing Walls | | | | |
| abkij | 0.50 | 0.15 | 1.75 | 0.131 |
| bck | 0.50 | 0.15 | 0.50 | 0.019 |
| kcdhgi | 1.58 | 0.15 | 1.25 | 0.296 |
| deh | 0.75 | 0.15 | 0.75 | 0.042 |
| efgh | 0.75 | 0.15 | 0.50 | 0.056 |
| | | | | 0.545 |
| For 2 Wing Walls | | | | 1.089 |
| Flooring (Slab) | | | | |
| Flooring | 1.90 | 1.80 | 0.15 | 0.513 |
| Projection | 0.15 | 1.80 | 0.15 | 0.041 |
| | | | | 0.554 |
| Grand Total | | | | 2.487 |
| Facultative Pond | | | | |
| Item | CL | W | H | Volume |
| Wall A | 1.80 | 0.15 | 2.50 | 0.675 |
| Wall B | 1.50 | 0.15 | 1.00 | 0.225 |
| Wall C | 1.50 | 0.08 | 0.80 | 0.096 |
| | | | | 0.996 |
| Wing Walls | | | | |
| abjik | 0.50 | 0.15 | 2.15 | 0.161 |
| bcj | 0.70 | 0.15 | 0.70 | 0.037 |
| dgij | 1.55 | 0.15 | 1.45 | 0.337 |
| deh | 0.95 | 0.15 | 0.95 | 0.068 |
| efgh | 0.95 | 0.15 | 0.50 | 0.071 |
| | | | | 0.674 |
| For 2 Wing Walls | | | | 1.348 |
| Flooring (Slab) | | | | |
| Flooring | 2.15 | 1.80 | 0.15 | 0.581 |

| Description of Item | CL | W | H | Volume |
|-------------------------|-----------|----------|----------|----------------|
| Grand Total | | | | 2.925 |
| Reinforcement | | | | |
| slabs @ 70 kg/cum | 7.3494 | 70 | | 514.458 |
| Wall @ 100 kg/cum | 22.7185 | 100 | | 2271.852 |
| | 30.0679 | | | 2786.31 |
| Centring | | | | |
| Wall A | 1.80 | - | 2.00 | 3.600 |
| Wall B | 1.50 | - | 1.00 | 1.500 |
| Wall C | 1.50 | - | 0.30 | 0.450 |
| | | | | 5.550 |
| Wing Walls | | | | |
| abb'c'a' | 0.50 | - | 1.72 | 0.860 |
| bb'c | 0.22 | - | 0.22 | 0.048 |
| b'c'dd'f'c | 1.50 | - | 1.50 | 2.250 |
| ded' | 1.50 | - | 1.50 | 2.250 |
| f'd'ef | 2.20 | - | 2.20 | 4.840 |
| | | | | 10.248 |
| For 2 Wing Walls | | | | 20.497 |
| Flooring (Slab) | | | | |
| a'c'f | 1.80 | 1.80 | - | 3.240 |
| ff | 3.11 | 1.80 | - | 5.598 |
| fg | - | 1.80 | 0.30 | 0.540 |
| | | | | 9.378 |
| Grand Total | | | | 35.425 |
| Maturation Pond | | | | |
| Item | CL | W | H | Volume |
| Wall A | 1.80 | - | 2.00 | 3.600 |
| Wall B | 1.50 | - | 0.85 | 1.275 |
| Wall C | 1.50 | - | 0.50 | 0.750 |
| | | | | 5.625 |
| Wing Walls | | | | |
| abkij | 0.50 | - | 1.75 | 0.875 |
| bck | 0.50 | - | 0.50 | 0.250 |
| kcdhgi | 1.58 | - | 1.25 | 1.975 |
| deh | 0.75 | - | 0.75 | 0.563 |
| efgh | 0.75 | - | 0.50 | 0.375 |
| | | | | 4.038 |
| For 2 Wing Walls | | | | 8.075 |
| Flooring (Slab) | | | | |
| Flooring | 1.90 | 1.80 | - | 3.420 |
| Projection | 0.15 | 1.80 | - | 0.270 |
| | | | | 3.690 |
| Grand Total | | | | 17.390 |
| Facultative Pond | | | | |
| Item | CL | W | H | Volume |
| Wall A | 1.80 | - | 2.50 | 4.500 |
| Wall B | 1.50 | - | 1.00 | 1.500 |
| Wall C | 1.50 | - | 0.80 | 1.200 |
| | | | | 7.200 |
| Wing Walls | | | | |
| abjik | 0.50 | - | 2.15 | 1.075 |
| bcj | 0.70 | - | 0.70 | 0.490 |
| dgij | 1.55 | - | 1.45 | 2.248 |
| deh | 0.95 | - | 0.95 | 0.903 |
| efgh | 0.95 | - | 0.50 | 0.475 |

| Description of Item | CL | W | H | Volume |
|------------------------|------|------|---|---------------|
| | | | | 5.190 |
| For 2 Wing Walls | | | | 10.380 |
| | | | | |
| Flooring (Slab) | | | | |
| Flooring | 2.15 | 1.80 | - | 3.870 |
| | | | | |
| Total | | | | 21.450 |

226.2096

Summary

| Component | East Zone | West Zone | Total | RCC (cum) | Total RCC (cum) |
|-------------------------|-----------|-----------|-------|-----------|-----------------|
| Anerobic Pond | 1 | 1 | 2 | 4.211 | 8.423 |
| Maturation Pond | 2 | 2 | 4 | 2.487 | 9.947 |
| Facultative Pond | 2 | 2 | 4 | 2.925 | 11.699 |

TOTAL RCC QUANTITY

30.07

Earthwork & Refilling Quantity for new STP

| Sl. No. | Description | Height (m) | Bottom Width (m) | Top Width (m) | Area (sqm) | Length (m) | Volume | Total |
|--------------------------------|-----------------------------------|------------|------------------|---------------|------------|------------|-----------|-----------|
| Bunds | | | | | | | | |
| 1 | Point A | 1.49 | 5.21 | 1.50 | 5.00 | | | |
| 2 | Point B | 1.41 | 5.03 | 1.50 | 4.60 | | | |
| 3 | Point C | 0.78 | 3.45 | 1.50 | 1.93 | | | |
| | | | | | 3.84 | 114 | 438.26 | |
| 4 | Point D | 1.90 | 6.25 | 1.50 | 7.36 | | | |
| 5 | Point E | 1.05 | 4.11 | 1.50 | 2.95 | | | |
| 6 | Point F | 1.19 | 4.46 | 1.50 | 3.55 | | | |
| | | | | | 3.94 | 297 | 1,170.18 | |
| 7 | Point G | 1.40 | 5.00 | 1.50 | 4.55 | | | |
| | | | | | 4.05 | 93 | 376.47 | |
| 8 | Point H | 1.43 | 5.06 | 1.50 | 4.69 | | | |
| 9 | Point I | 1.97 | 6.41 | 1.50 | 7.79 | | | |
| | | | | | 5.50 | 298 | 1,639.00 | |
| 10 | Point J | 1.06 | 4.15 | 1.50 | 2.99 | | | |
| 11 | Point K | 0.79 | 3.48 | 1.50 | 1.97 | | | |
| | | | | | 3.31 | 297 | 983.07 | |
| 12 | Point L | 1.59 | 5.48 | 1.50 | 5.55 | | | |
| 13 | Point M | 1.34 | 4.84 | 1.50 | 4.25 | | | |
| | | | | | 5.85 | 300 | 1,755.00 | |
| 14 | Point N | 0.89 | 3.71 | 1.50 | 2.32 | | | |
| | | | | | 3.27 | 252 | 824.04 | |
| 15 | Point O | 1.26 | 4.64 | 1.50 | 3.87 | | | |
| | | | | | 3.57 | 252 | 899.64 | |
| A | Total Earth from Existing Bunds | | | | | | 8,085.66 | 8086 cum |
| 16 | Silt in Inlet Zone | | | | | | 12,316.50 | |
| 17 | Silt in West Zone | | | | | | 16,417.50 | |
| 18 | Silt in East Zone | | | | | | 8,250.00 | |
| B | Total Silt | | | | | | 36,984.00 | 36984 cum |
| For New Treatment Plant | | | | | | | | |
| WEST ZONE | | | | | | | | |
| a | Anerobic Pond | 1.90 | 6.25 | 1.50 | 7.36 | 253.00 | 1,862.08 | |
| | Bottom Filling | | | | | | 367.78 | |
| b | Facultative Pond | 1.75 | 5.88 | 1.50 | 6.45 | 727.50 | 4,692.38 | |
| c | FP-Central Bund | 2.00 | 6.50 | 1.50 | 8.00 | 199.25 | 1,594.00 | |
| | Bottom Filling | | | | | | 7,435.16 | |
| d | Maturation Pond | 1.15 | 4.38 | 1.50 | 3.38 | 574.00 | 1,940.12 | |
| e | MP-Central Bund | 1.75 | 5.88 | 1.50 | 6.45 | 169.00 | 1,090.05 | |
| C | Bottom Cutting | | | | | | 2,656.80 | 2657 cum |
| | Total Earth for Bunds and Filling | | | | | | 18,983.92 | 18984 cum |
| EAST ZONE | | | | | | | | |
| f | Anerobic Pond | 1.75 | 5.88 | 1.50 | 6.45 | 214.00 | 1,380.30 | |
| | Bottom Filling | | | | | | 194.59 | |
| g | Facultative Pond | 1.65 | 5.63 | 1.50 | 5.88 | 601.50 | 3,536.82 | |
| h | FP-Central Bund | 2.00 | 6.50 | 1.50 | 8.00 | 164.25 | 1,314.00 | |
| | Bottom Filling | | | | | | 1,494.23 | |
| D | Cutting New Area | | | | | | 1,276.35 | |
| E | Cutting Triangle Area | | | | | | 9.56 | |
| I | Maturation Pond | 1 | 4 | 1.5 | 2.75 | 474 | 1,303.50 | |
| j | MP-Central Bund | 1.75 | 5.875 | 1.5 | 6.453 | 139 | 896.98 | |
| F | Bottom Cutting | | | | | | 2,653.20 | |
| G | Cutting New Area | | | | | | 2,690.81 | |
| H | Cutting Triangle Area | | | | | | 43.02 | |
| | Total Earth for Bunds and Filling | | | | | | 9,925.38 | 9929 cum |
| | Earth from Cutting | | | | | | 6,867.52 | 6868 cum |

| Sl. No. | Description | Height (m) | Bottom Width (m) | Top Width (m) | Area (sqm) | Length (m) | Volume | Total |
|---------|---|------------|------------------|---------------|------------|------------|-----------|-----------|
| | Filling Area in Inlet | | | | | | 17,365.14 | |
| | Filling Area in between Facultative Ponds | | | | | | 2,653.74 | |
| | Filling behind M Pond | | | | | | 1,902.05 | |
| | Total Filling in Existing STP | | | | | | 21,920.93 | 21921 cum |
| | Summary | | | | | | | |
| | Total Earthwork in cutting | | | | | | | |
| | (A + B + C + D + E + F + G + H) | | | | | | | |
| | Total bund making | | | | | | | |
| | (a + b + c + d + e + f + g + h + i + j) | | | | | | | |

**WASTE WATER TREATMENT PLANT FOR WARD 45
AMBATTUR MUNICIPALITY (Conventional system)**

**DESIGN OF MODIFIED ACTIVATED SLUDGE SEWAGE TREATMENT PLANT
1 MLD CAPACITY**

Population & Sewagw generation

Ward 45 has 39 streets.

Population as per 2001 census - 5047

Rate of decadal growth 30%

| | Projected population | |
|--|----------------------|----------|
| Base year 2008 - | 6106 | |
| Ultimate design year - | 10650 | |
| Percapita water supply | | 110 lpcd |
| Sewage generation @80% of water supply ignoring infiltration | | 88 lpcd |
| | Say | 90 lpcd |
| Total sewage generated = 0.9585 mld | Say | 1.0 mld |

| | | |
|------------------------|---|----------------------------|
| Average sewage flow | = | 1000 m ³ / day |
| | = | 41.67 m ³ / h |
| | = | 0.694 m ³ / min |
| | = | 0.012 m ³ / s |
| Peak flow | = | 3000 m ³ / d |
| | = | 125.00 m ³ / h |
| | = | 2.083 m ³ / min |
| | = | 0.035 m ³ / s |
| BOD of influent sewage | = | 250 mg/l |

I. Pre Treatment Units

(a). Stilling Chamber

| | |
|---------------------|----------------------|
| No. of Units | 1 |
| Detention time | 10 min |
| Volume | 21 m ³ |
| Liquid Depth | 2.00 m |
| Area of the Chamber | 10.42 m ² |
| Dimensions | 4.00 x 3.0 x 2.50 m |

(b). Screen Chamber

| | |
|---|----------------------|
| No. of Units | 1 No. |
| Velocity in approach channel at peak flow | 0.60 m/s |
| Velocity in approach channel at average flow | 0.30 m/s |
| Velocity through screen at peak flow | 0.90 m/s |
| Cross sectional area of approach channel = 0.035 / 0.60 | 0.058 m ² |
| Cross sectional area of screen 0.041 / 0.9 | 0.039 m ² |
| Water depth U/S of screen | 0.50 m |
| Water depth D/S of screen | 0.35 m |
| Width of the channel | 0.138 (or) 0.15m |
| Adopting screen with 12mm bars @ 25mm clear space | |
| Cross area of screen (0.046 x (3.7 / 2.5)) | 0.057 m ² |

| | |
|---|-------------|
| Velocity above screen at peak flow $0.9 \times 2.5/3.7$ | 0.608 m/sec |
| Head loss through the screen $0.0729 (0.9^2 - 0.608^2)$ | 0.0321 m |
| If the screen openings are half plugged velocity through screen is doubled. | |
| Head loss = $0.0729 (1.8^2 - 0.608^2)$ | 0.21 m |
| Width of the channel | 0.15 m |
| Water depth u/s screen | 0.50 m |
| Water depth d/s screen | 0.468 m |
| Assuming an inclination of the screen to horizontal as 60° , the Gross area of screen needed would be $(2 / (\sqrt{3})) * 0.057$ | 0.0659 |
| Dimensions | |
| Length | 1.50 m |
| Width | 0.15 m |
| Depth of water | 0.50 m |
| Free Board | 0.50 m |
| Total Depth | 1.00 m |

(c). Grit Chamber With Parshall Flume

| | |
|---------------------|------------|
| No. of Units | 1 |
| Horizontal velocity | 0.30 m/sec |
| Maximum flow | 40.51 lps |
| Minimum flow | 11.57 lps |

From Table 11.2 of CPHEEO manual upto 5 Mld throat width (W) = 0.075 m

Determination of Z

$$d_{\min} / d_{\max} = 1 / 3.5 = \frac{1.1 (11.57/2264 \times 0.075)^{2/3} - Z}{1.1 (40.51/2264 \times 0.075)^{2/3} - Z}$$

$$1.1 (11.57/2264 \times 0.075)^{2/3}$$

$$1.1 (40.51/2264 \times 0.075)^{2/3}$$

$$1/3.5 = 0.1835 - Z / 0.3847 - Z$$

$$Z = 0.10302 = 0.2577$$

$$d_{\min} = 1.1 (11.57/2264 \times 0.075)^{2/3} - Z = 0.1835 - 0.10302 = 0.081 \text{ m}$$

$$d_{\max} = 1.1 (40.51/2264 \times 0.075)^{2/3} - Z = 0.3847 - 0.10302 = 0.2817 \text{ m}$$

Width of the Grit Chamber

$$b = Q_{\max} / 1000 \times d_{\max} \times V_{\max} = Q_{\min} / 1000 \times d_{\min} \times V_{\min}$$

$$40.51 / 1000 \times 0.2871 \times 0.3 = 11.57 / 1000 \times 0.081 \times 0.3 = 0.4703$$

The ideal over flow rate is $1300 \text{ m}^3/\text{d}/\text{m}^2$

for the lowest Temperature of 18°C , over flow is 1.24×1300

Applying correction factor of 0.666,

| | |
|--|---|
| Over flow rate | = 10.75 (or) say 1000 m ³ /d/π |
| Q/A | = 1000 m ³ /d/m ² |
| Area | = 3 m ² |
| Width of the chamber | = 0.476 m |
| Length of chamber | = 6.30 (or) say 7.5r |
| Detention Period, V/Q = (3.5*0.2817*1440)/3500 | = 0.41 Min |

II. Primary Treatment -

a) Primary Settling Tank (1 mld)

| | |
|---|--|
| Peak factor | = 3 |
| Average flow | = 1.00 Mld |
| Surface loading rate | = 25 m ³ /d/m ² |
| Surface Area required | = 40 m ² |
| Area required for surface loading rate of 59m ³ /d/m ² for peak flow = 3000 / 59 = 50.5 m ² | = 50.85 m ² |
| Area needed for Solids loading rate of 125kg/day/m ² = (1000x3000)/(125x1000) | = 24 m ² |
| Area needed for Solids loading of 250kg/day/m ² for peak flow = (3000x3000)/(250x1000) | = 36 m ² |
| Adopting the higher Surface area of 59.32 (or) 50.85 m ² | = 50.85 m ² |
| Diameter | = 8.704 (or) say 8.80m |
| Detention period | = 2 1/2 hrs |
| Depth | = 1.71 (or) Adopt 2 |
| Weir loading rate = 1000/(πx8.8) | = 36.17 m ³ /d/m ² |
| Hence O.K | |

Outlet arrangement for Primary Clarifier-1Mld

1). Effluent weir

| | |
|---|--------------------------|
| Length of effluent weir plate π x 8.8 | = 27.64 m |
| Provide 90° v notches @ 25cm c/c | |
| Total No. of notches = 27.15 x 4 | = 110 |
| Average discharge per notch = 1000/(24x60x60x110) | = 0.0001052 |
| | 1.047 x 10 ⁻⁴ |

The discharge through a V notch is $Q = 8/15 cd \sqrt{2g \tan \theta/2} H^{5/2}$
 $cd = 0.584 \theta = 90^\circ$

$$\text{Head over V notch at peak flow} = [(15 \times 3.682 \times 10^{-4}) / (8 \times 0.584 \times \sqrt{2 \times 9.81})]^{2/5} = 0.037 \text{m}$$

Provide 5 cm deep 90° V notches @ 25cm c/c

Effluent Channel

Assume the width as 0.15m

Critical depth at the end of effluent channel Y_2 is

$$Y_2 = [(1000/(24 \times 3600))^2 / (0.15^2 \times 9.81)]^{1/3} = 0.085 \text{m}$$

Depth at upper end

$$Y_1 = \sqrt{Y_2 + 2(1000/(24 \times 3600) \times 2)^2 / 9.81 \times 0.15^2 \times 0.085} = \sqrt{0.085^2 + 2(1000/24 \times 3600) \times 2)^2 / 9.81 \times 0.15^2 \times 0.085} = 0.254$$

Provide a depth of 0.40m

III. Secondary Treatment

a). Aeration Tank

| | | |
|--|---|------------------------|
| Average Flow | = | 1000 m ³ /d |
| BOD of influent to aeration tank = 250x 0.65 | = | 162.5 mg/l |
| Efficiency = 142.5/162.50 | = | 0.88 |
| F/M = 0.3 , MLSS(Xt) = 3000mg/l | = | |
| F/M = (Q. LA)/(VXt/1000) | = | |
| = (1x162.5x1000)/(Vx3000) | = | 0.2 |
| V | = | 217 m ³ |
| Check for Hydraulic Retention time | | |
| HRT = (V / (Qx1000)) x 24 | | |
| = (217 / 1x1000) x 24 | = | 5.21 |
| Volumetric Loading Q x La / V = 1x195 / 217 | = | 0.749 (or) 0.8 |
| Within permissible range of 0.8 to 2 | | |
| Return Sludge (SVI = 100) | | |
| Q _v / Q = (Xt / ((10 ⁶ / SVI) - Xt)) | | |
| = (3000 / ((10 ⁶ / 100) - 3000)) | = | 42.86 % |
| With permissible range of 25 to 50% | | |

Tank dimensions

| | | |
|---------------------------------------|---|----------------------|
| Adopting a depth of 3m | | |
| Area = 217 / 3 | = | 72.33 m ² |
| Provide a tank of size 9m x 8m x 3.5m | | |

Excess Sludge

| | | |
|--|---|------------|
| Q _w X _s = 0.5x1000x175.5-0.06x3000x217 | = | 87750 g/d |
| | = | 87.75 kg/d |

Sludge Recirculation

| | | |
|--|---|-----------------------|
| Sludge Recirculation ratio = 3000/10000 | = | 0.00 |
| As this ratio is bet 0.25 & 0.8 it is acceptable however provide a ratio of 0.33 | | 0.33 |
| Sludge recirculation pump capacity = 0.33 x 1000 | | 330 m ³ /d |

Oxygen Requirement

| | | |
|---|---|-----------------|
| (Q(S ₀ -S)) / f - 1.42 Q _w X _s | | |
| ((1000*175.5)/0.68)-1.42*48690 | = | 133483.24 g / d |
| Kg O ₂ required / kg BOD removed | | |
| 188948.4/(1000*175.5) | = | 0.76 |

This is only marginally higher than that the permissible value of 0.8 to 1.0

Hence acceptable

Capacity available aerator equipment = 1.20 kg of O₂/kwh

| | | |
|---|--|----------|
| Therefore power requirement for aeration equipment ((188.948/24)/1.2) (1 Mld) | | 4.63 kwh |
|---|--|----------|

| | | |
|--------------------------------------|---|-------------------------|
| Sludge Generated | | |
| Primary Sludge Solids | | |
| 1000x480x0.75x1/1000 | = | 360 kg/d |
| Primary Sludge Volume | | |
| 360/40 (assumed) 40kg/m ³ | = | 9.00 m ³ /d |
| Secondary Sludge Solid | = | 4.87 m ³ /d |
| Total Sludge Volume | = | 15.51 m ³ /d |

(b). Secondary Clarifier

| | | |
|--|---|--|
| Peak factor | = | 3 |
| Average flow | = | 1000 m ³ /day |
| Peak flow | = | 3000 m ³ /day |
| Adopting a surface loading rate 20m ³ /d/m ² at average flow | | |
| Surface area required = 1000/20 | = | 50 m ² |
| Area required Surface loading of 50m ³ /d/m ² at peak flow =3000/50 | = | 60 m ² |
| Area needed for Solids loading rate of 125kg/day/m ² at average flow = (1000x2000) / (125x1000) | = | 16 m ² |
| Area needed for Solids loading rate of 250m ³ /d/m ² at peak flow = (3500x2000) / (250x1000) = 28m ² | = | 24 m ² |
| The higher surface area of 70m ² is adopted | | |
| Diameter | = | 9.44 (or) 9.5 m |
| Detention time | = | 2 hrs |
| Depth = 83.33 / 70.88 | = | 1.18 (or) say 2.0r |
| Weir loading = 1000/(π x9.5) < 150m ³ /d/m ² | = | 33.51 < 150 m ³ /d/m ² |
| Hence O.K | | |

Outlet arrangement for Secondary Clarifier

1). Effluent weir

| | | |
|---|---|-----------------------|
| Length of effluent weir plate = π x9.5 | = | 29.85 m |
| Provide 90° V notches @ 25cm c/c | | |
| Total No. of notches = 29.85 x 4 | = | 119 |
| Average discharge per notch = 1000 / (24x60x60x119) | = | 9.6951E-05 |
| | = | 9.65x10 ⁻⁵ |

The discharge through V notch is $Q = 8/15 cd \sqrt{2g \tan \theta/2} H^{5/2}$
 $cd = 0.584 \theta = 90^\circ$

Head over V notch at peak flow
 $= [(15 \times 3.378 \times 10^{-4}) / (8 \times 0.584 \times \sqrt{2 \times 9.81})]^{2/5} = 0.036m$
 Provide 5 cm deep 90° V notches @ 25cm c/c

Effluent Channel

Assume the width as 0.15m

Critical depth at the end of effluent channel Y_2 is

$$Y_2 = [(1000 / (24 \times 3600))^2 / (0.15^2 \times 9.81)]^{1/3} = 0.085m$$

Depth at upper end

$$Y_1 = \sqrt{(0.085^2 + 2(1000/24 \times 3600)^2 / 9.81 \times 0.15^2 \times 0.085)} \\ = 0.254$$

Provide a depth of 0.40m

(c). Sludge Well

| | |
|-----------------------------------|-------------------------|
| Volume of Primary sludge | 9 m ³ /d |
| Volume of excess secondary sludge | 4.87 m ³ /d |
| Total Volume of sludge | 13.87 m ³ /d |
| Volume of sludge well | 1.45 m ³ |
| Dia of well | 1.00 m |
| Depth of well | 1.85 (or) 2 m |

(d). Sludge digester

| | |
|--|-------------------------|
| 1). Raw effluent SS | 480 mg/l |
| 2). SS removal efficiency in primary sedimentation tank | 75% |
| 3). Quantity of Primary sludge generated $Q \times 0.48 \text{ kg/m}^3 \times 0.75$ | 360 kg/d |
| 4). At 4% consistency of 40 kg/m ³ SS concentration primary sludge volume | 9 m ³ /d |
| 5). Excess activated sludge generated | 48.70 kg/d |
| 6). At 1% consistency of SS concentration of 10 kg/m ³ the volume of excess activated sludge | 4.87 m ³ /d |
| 7). Total Volume of raw mixed Sludge | 13.87 m ³ /d |
| 8). Total quantity of raw mixed Sludge (360+48.70) | 408.7 kg/d |
| 9). SS concentration of raw mixed Sludge (408.7/13.87) | 29.47 kg/m ³ |
| 10). Appropriate % of Volatile Matter (VM) | 70% |
| 11). Quantity of VM in raw mixed sludge (0.7x408.7) | 286.09 kg/d |
| 12). Quantity of Non VM or inorganic (0.3x408.7) | 122.61 kg/d |
| For sludge temperature of 30°C the solid retention time (SRT) required | 20 days |
| Digester Volume 13.87x20 (Volume of fresh sludge x retention time) | 277 m ³ |
| Choosing Two digester | 2 nos. |
| Capacity each digester | 139 m ³ |
| Diameter 6m Φ | |
| Effective Depth | 4.92 m |
| Additional storage for monsoon period (12 days) 13.87 x 12 | 166.44 m ³ |
| Equivalent depth | 2.94 m |
| Free Board | 0.50 m |
| Total depth | 9.00 m |

(e). Sludge Drying Bed

| | |
|--|---------------------|
| 1). Volume of digested sludge ((286.09x0.5+122.61)/50) | 5.31 m ³ |
| 2). Dewatering, drying and sludge removal cycle | 10 d |
| 3). Depth of application of sludge | 0.30 m |
| 4). Total plan area of sludge drying bed | 177 m ² |
| 5). No. of beds | 4 |
| 6). Size of bed | 10 x 4.5 m |

DETAILS OF WARD 45 OF AMBATTUR MUNICIPALITY

| Sl. No. | Node | Name of Street | Pipes | | | No. of House Connections |
|---------|-------|-------------------------------|-------------|-----------|-----------|--------------------------|
| | | | Length (m) | Size (mm) | Depth (m) | |
| 1 | 1-2 | Vallalar Street | 140 | | | 35 |
| 2 | 3-4 | Kalaivanar Nagar Main Road | 149 | | | 37 |
| 3 | 5-6 | Dr.Radhakrishnan Street | 93 | | | 26 |
| 4 | 7-8 | Thiruvalluvar Street | 99 | | | 27 |
| 5 | 9-10 | J.N. Street | 182 | | | 44 |
| 6 | 11-12 | Rajaji Street | 180 | | | 44 |
| 7 | 12-17 | Nethaji Main Road | 839 | | | 0 |
| 8 | 13-14 | Logmania Thylakar Street | 99 | | | 28 |
| 9 | 15-16 | Kambar Street-1 | 98 | | | 27 |
| 10 | 17-18 | Subbash Chandra Boss Street | 167 | | | 42 |
| 11 | 19-20 | X1 | 34 | | | 14 |
| 12 | 21-22 | X2 | 37 | | | 16 |
| 13 | 23-24 | Part of Kattabomman Street | 41 | | | 16 |
| 14 | 25-26 | Kattabomman Street | 64 | | | 20 |
| 15 | 27-28 | Kambar Street-2 | 75 | | | 22 |
| 16 | 29-30 | Tank Street | 105 | | | 30 |
| 17 | 31-32 | Tank Cross Street | 34 | | | 14 |
| 18 | 21-33 | Kambar Street-3 | 144 | | | 0 |
| 19 | 34-35 | V.O.C Street | 133 | | | 35 |
| 20 | 35-47 | TVS Main Road Parallel Road | 195 | | | 0 |
| 21 | 36-37 | Jawahar Street | 135 | | | 36 |
| 22 | 38-39 | Bharathiyar Street | 139 | | | 35 |
| 23 | 40-41 | Ambatkar Street | 133 | | | 35 |
| 24 | 42-43 | Anna Street-1 | 132 | | | 34 |
| 25 | 43-44 | Anna Street-2 | 73 | | | 22 |
| 26 | 45-46 | Amman Koil Street | 189 | | | 45 |
| 27 | 47-48 | Thiruvalluvar Street | 219 | | | 50 |
| 28 | 49-50 | Raja Raja Chozhan Street | 151 | | | 33 |
| 29 | 24-51 | Manikkavasakam Street | 69 | | | 21 |
| 30 | 18-20 | Thiru Vi Ka Street | 179 | | | 44 |
| 31 | 48-22 | Thendral & Manikkavasakam St. | 109 | | | 29 |
| 32 | 52-53 | Vivekanandar Street | 153 | | | 38 |
| 33 | 53-20 | Part of Thiru Vi Ka Street | 31 | | | 13 |
| 34 | 20-54 | Bharathiyar Street | 178 | | | 43 |
| | | Total Length | 4798 | | | 955 |

Estimate for Sewage Treatment Plant (MASP) - 1 MLD for Ward 45- Ambattur Municipality

| Sl. No. | Description of work | Quantity | Unit | Rate (Rs.) | Amount (Rs.) |
|---------|---|----------|------|------------|--------------|
| 1 | Earth work excavation & depositing on bank with an initial lead of 10 m & lift of 2 m for depths in hard stiff clay, stiff black cotton, hard red earth mixed with small sized boulders & hard gravely etc all complete as per standard specification and as di | 844.16 | cum | 28.75 | 24,269.59 |
| 2 | Providing and laying base concrete in foundation using Plain Cement Concrete 1:3:6 including consolidation and levelling etc as per standard specifications | 63.98 | cum | 2,110.00 | 135,007.97 |
| 3 | Supplying & laying Reinforced Cement Concrete of M25 grade using machine crushed hard broken granite stone jelly 20 mm for RCC works in all types of foundations, floor slabs of all shapes (Excluding cost of providing centering & fabrication of reinforceme | 377.23 | cum | 3,539.00 | 1,335,025.21 |
| 4 | Supplying, fabricating & placing in position MS or deformed steel bars for all RCC items of work including cost of steel transporting, straightening, cutting, bending, cranking, binding etc. including cost of binding wire charids, laps to fix the reinforc | 37723.23 | Kg | 51.00 | 1,923,884.87 |
| 5 | Supplying & erecting centering for sides & walls including supports & strutting for plain surfaces with all cross bracings using 25 mm thick boards suitable purlined over silver oak (country wood) joists of size 10 x 6.5 cm spaced at about 90 cm centre to | 2538.19 | sqm | 428.00 | 1,086,343.18 |
| 6 | Supply and filling filtermedia in drying bed | | | | |
| | a) Clean river sand of eff size 0.5to0.75 mm and uni. Coeff.not>4 30 cm | 54 | cum | 580.50 | 31,347.00 |
| | b) HBG jelly 20mm 15cm | 27 | cum | 780.00 | 21,060.00 |
| | c) HBG jelly 40mm 15cm | 34 | cum | 560.00 | 19,040.00 |

| Sl. No. | Description of work | Quantity | Unit | Rate (Rs.) | Amount (Rs.) |
|---------|--|----------|------|------------|--------------|
| 7 | Supplying and installation of following machineries including all electrical works and labour charges etc complete as per standard specifications and as directed by Engineer-in-charge | | | | |
| | Machinery | | | | |
| | Bar screen | 1 | no. | 5,000.00 | 5,000.00 |
| | scraper motor-reduction gear primary clarifier (Including scraper mechanism) | 1 | no. | 20,000.00 | 20,000.00 |
| | aeration tank (1 HP) | 4 | nos. | 25,000.00 | 100,000.00 |
| | scraper motor- secondary clarifier | 1 | no. | 30,000.00 | 30,000.00 |
| | sludge recirculation pump | 1 | no. | 10,000.00 | 10,000.00 |
| | sludge well pump | 1 | no. | 8,000.00 | 8,000.00 |
| | stirrer- digester | 2 | nos. | 25,000.00 | 50,000.00 |
| | Filtrate pump (1 HP) | 1 | no. | 10,000.00 | 10,000.00 |
| 8 | Earth work excavation & depositing on bank with an initial lead of 10 m & lift of 2 m for depths in hard stiff clay, stiff black cotton, hard red earth mixed with small sized boulders & hard gravelly soil as directed by the Departmental Engineer. (Pipeline | 237 | cum | 57.50 | 13,627.50 |
| 9 | Supply of 200 mm diameter of DI pipes (K9 class) as per IS:8329-2000 with sulphate resistance cement with inner lining of high alumina cement as per IS:783 with epoxy coating outside of the spigot portion and poly solution coating inside the socket portio | 250 | m | 1,229.80 | 307,450.00 |
| 10 | Supply and laying 200 mm GSW pipe loose jointed underdrains drying beds | 40 | m | 197.00 | 7,880.00 |
| 12 | Supply and installation of following size of CI Double Flanged Sluice Valves (PN 1.0) with cap and confirming to IS:14846, to site, including flanged tail pieces and other specials as required, loading, unloading, transportation charges & stacking at site | | | | |
| | sluice valves 200 mm | 4 | nos. | 10,128.00 | 40,512.00 |
| | Sluice valve at Sludge drying beds 100mm | 4 | nos. | 4,100.00 | 16,400.00 |
| #REF! | #REF! | #REF! | | | 10,000.00 |

| Sl. No. | Description of work | Quantity | Unit | Rate (Rs.) | Amount (Rs.) |
|---------|---|----------|------|------------|------------------|
| 13 | Supplying and fixing of 150 W HPSV street light fixture with single piece, deep drawn aluminium reflector, copper wound ballast, capacitor, junction box, porcelain terminal box, 40 NB class 2 GI pipe for fixture mounting, cleats etc. complete in all respe | 6 | nos. | 4,500.00 | 27,000.00 |
| 14 | Providing Internal electrification arrangement including all cost of materials and labour charges etc complete as per standard specifications and as directed by Engineer incharge | 1 | | | 6,800.50 |
| 15 | Construction of Office cum Electrical room of size of 6 x 3 x 4 m at STP I premises including all cost of materials and labour charges etc complete as per standard specifications and as directed by Engineer-incharge | 1 | No. | 136,010.00 | 136,010.00 |
| 17 | Construction of Compound wall for 180 m length for STP I premises including all cost of materials and labour charges etc complete as per standard specifications and as directed by Engineer-incharge | 180 | m | 1,042.41 | 187,633.80 |
| | Gate 2.5x2.1m | 1 | no | 17,443.00 | 17,443.00 |
| 18 | Construction of WBM road in the STP site including a) supplying and spreading gravel of 100 mm thickness, including labour charges b) providing and laying WBM 75 mm (Grade II) compacted thickness with Grade II metal using 1 m ³ of 63 to 45 mm HBG metal wit | 43.75 | cum | 1,619.55 | 70,855.31 |
| | | | | | 410 |
| | TOTAL COST | | | | 5,651,000 |

| Detailed Estimate for Sewage Treatment Plant (MASP) 1 MLD for Zone II | | | | | | | | | |
|---|---|-----|----------------------------|-------|-------|---------------|------------|----------------|---------------|
| SI. No. | Description of work | No. | L (m) | B (m) | D (m) | Quantity | Unit | RATE | AMOUNT |
| 1 | Earth work excavation & depositing on bank with an initial lead of 10 m & lift of 2 m for depths in hard stiff clay, stiff black cotton, hard red earth mixed with small sized boulders & hard gravelly etc all complete as per standard specification and as directed by TWAD Board Officers | | | | | | | | |
| | Inlet Chamber (Stilling Chamber) column | 4 | 1.05 | 1.05 | 1.60 | 7.06 | | | |
| | Screen Chamber column | 1 | 1.05 | 1.05 | 1.60 | 1.76 | | | |
| | Grit Chamber column | 2 | 1.05 | 1.05 | 1.60 | 3.53 | | | |
| | Parshall flume column | 1 | 1.05 | 1.05 | 1.60 | 1.76 | | | |
| | Inlet chamber to primary clarifier column | 2 | 1.05 | 1.05 | 1.60 | 3.53 | | | |
| | Primary clarifier | 1 | 16.96 | | | 16.96 | | | |
| | Primary clarifier (central portion) | 1 | 3.141*1 ² /4 | | 0.50 | 0.39 | | | |
| | Aeration Tank | 1 | 10.40 | 9.40 | 1.25 | 122.20 | | | |
| | Secondary clarifier | 1 | 75.59 | | | 75.59 | | | |
| | Secondary clarifier (central portion) | 1 | 3.141*1 ² /4 | | 0.50 | 0.39 | | | |
| | Sludge well | 1 | 3.141*2.9 ² /4 | | 2.10 | 2.79 | | | |
| | Sludge digester | 2 | 3.141*7.26 ² /4 | | 2.00 | 113.08 | | | |
| | Sludge Drying Beds | 8 | 6.90 | 5.40 | 1.60 | 476.93 | | | |
| | Sludge drying Beds channel (central portion) | 4 | 10.30 | 1.00 | 0.50 | 20.60 | | | |
| | Filtrate well | 1 | 3.141*1.3 ² /4 | | 2.00 | 2.65 | | | |
| | Effluent well | 1 | 3.141*1.3 ² /4 | | 1.50 | 1.99 | | | |
| | Net quantity | | | | | 851.22 | cum | 26 | 22132 |
| 2 | Providing and laying base concrete in foundation using Plain Cement Concrete 1:3:6 including consolidation and levelling etc as per standard specifications | | | | | | | | |
| | Inlet Chamber (Stilling Chamber) column | 4 | 1.05 | 1.05 | 0.10 | 0.44 | | | |
| | Screen Chamber column footing | 1 | 1.05 | 1.05 | 0.10 | 0.11 | | | |
| | Grit Chamber column footing | 2 | 1.05 | 1.05 | 0.10 | 0.22 | | | |
| | Parshall flume column footing | 1 | 1.05 | 1.05 | 0.10 | 0.11 | | | |
| | Inlet chamber to primary clarifier column footing | 2 | 1.05 | 1.05 | 0.10 | 0.22 | | | |
| | Primary clarifier | 1 | 2.12 | | | 2.12 | | | |
| | Primary clarifier (central portion) | 1 | 3.141*1 ² /4 | | 0.10 | 0.08 | | | |
| | Aeration Tank | 1 | 10.40 | 9.40 | 0.10 | 9.78 | | | |
| | Secondary clarifier | 1 | 9.45 | | | 9.45 | | | |
| | Secondary clarifier (central portion) | 1 | 3.141*1 ² /4 | | 0.10 | 0.08 | | | |
| | Sludge well | 1 | 3.141*2.9 ² /4 | | 0.10 | 0.13 | | | |
| | Sludge digester | 2 | 3.141*7.26 ² /4 | | 0.10 | 5.65 | | | |
| | Sludge Drying Beds | 8 | 6.90 | 5.40 | 0.10 | 29.81 | | | |
| | Sludge drying Beds channel (central portion) | 8 | 6.90 | 1.00 | 0.10 | 5.52 | | | |
| | Filtrate well | 1 | 3.141*1.3 ² /4 | | 0.10 | 0.13 | | | |
| | Effluent well | 1 | 3.141*1.3 ² /4 | | 0.10 | 0.13 | | | |
| | Net quantity | | | | | 63.98 | cum | 2203.85 | 141013 |

| Sl. No. | Description of work | No. | L (m) | B (m) | D (m) | Quantity | Unit | RATE | AMOUNT |
|---------|--|-----|-------|-------|-------|----------|------|------|--------|
| 3 | Supplying & laying Reinforced Cement Concrete of M25 grade using machine crushed hard broken granite stone jelly 20 mm for RCC works in all types of foundations, floor slabs of all shapes (Excluding cost of providing centering & fabrication of reinforcement) | | | | | | | | |
| | Inlet/ stilling chamber | | | | | | | | |
| | side walls all around | 1 | 14.30 | 2.50 | 0.15 | 5.36 | | | |
| | base slab | 1 | 4.30 | 3.30 | 0.15 | 2.13 | | | |
| | columns | 4 | 0.30 | 0.30 | 3.00 | 1.08 | | | |
| | footing | 4 | 0.75 | 0.75 | 0.20 | 0.45 | | | |
| | baffles | 3 | 3.00 | 0.10 | 2.00 | 1.80 | | | |
| | screen chamber | | | | | | | | |
| | side walls | 1 | 3.60 | 1.00 | 0.15 | 0.54 | | | |
| | base slab | 1 | 1.80 | 0.45 | 0.15 | 0.12 | | | |
| | columns | 1 | 0.30 | 0.30 | 3.00 | 0.27 | | | |
| | footing | 1 | 0.75 | 0.75 | 0.20 | 0.11 | | | |
| | grit chamber | | | | | | | | |
| | side walls | 2 | 7.65 | 1.00 | 0.15 | 2.30 | | | |
| | base slab | 1 | 7.65 | 0.80 | 0.15 | 0.92 | | | |
| | columns | 2 | 0.30 | 0.30 | 3.00 | 0.54 | | | |
| | footing | 2 | 0.75 | 0.75 | 0.20 | 0.23 | | | |
| | Parshall flume | | | | | | | | |
| | side walls | 2 | 1.20 | 1.00 | 0.15 | 0.36 | | | |
| | base slab | 1 | 1.20 | 0.65 | 0.15 | 0.12 | | | |
| | columns | 1 | 0.30 | 0.30 | 3.00 | 0.27 | | | |
| | footing | 1 | 0.75 | 0.75 | 0.20 | 0.11 | | | |
| | Chamber- inlet to primary clarifier | | | | | | | | |
| | side walls around | 1 | 2.60 | 2.00 | 0.15 | 0.78 | | | |
| | base slab | 1 | 1.00 | 0.65 | 0.15 | 0.10 | | | |
| | columns | 1 | 0.30 | 0.30 | 1.90 | 0.17 | | | |
| | footing | 1 | 0.75 | 0.75 | 0.50 | 0.28 | | | |
| | Primary clarifier | | | | | | | | |
| | side wall | 1 | 28.10 | 0.15 | 3.00 | 12.65 | | | |
| | bottom slab | 1 | 65.01 | | 0.15 | 9.75 | | | |
| | effluent channel slab | 1 | 29.67 | 0.30 | 0.10 | 0.89 | | | |
| | effluent channel side wall | 1 | 30.93 | 0.10 | 0.40 | 1.24 | | | |
| | aeration tank | | | | | | | | |
| | side walls allround | 1 | 35.60 | 0.30 | 4.50 | 48.06 | | | |
| | base slab | 1 | 9.80 | 8.80 | 0.15 | 12.94 | | | |
| | beam for fixing aerators | 2 | 8.80 | 0.45 | 0.45 | 3.56 | | | |
| | Secondary clarifier | | | | | | | | |
| | side wall | 1 | 30.30 | 0.15 | 3.00 | 13.64 | | | |
| | bottom slab | 1 | 75.39 | | 0.15 | 11.31 | | | |
| | effluent channel slab | 1 | 31.71 | 0.30 | 0.10 | 0.95 | | | |
| | effluent channel side wall | 1 | 32.97 | 0.10 | 0.40 | 1.32 | | | |
| | Sludge well | | | | | | | | |
| | side wall | 1 | 6.75 | 0.15 | 2.50 | 2.53 | | | |
| | base slab | 1 | 4.15 | | 0.15 | 0.62 | | | |
| | Digester | | | | | | | | |
| | side wall | 2 | 19.88 | 0.33 | 9.00 | 118.06 | | | |
| | base slab | 2 | 34.82 | | 0.20 | 13.93 | | | |

| Sl. No. | Description of work | No. | L (m) | B (m) | D (m) | Quantity | Unit | RATE | AMOUNT |
|---------|---|-----|-------|-------|--------|---------------|------------|----------------|----------------|
| | roof | 2 | 36.42 | | 0.10 | 7.28 | | | |
| | Drying bed | | | | | | | | |
| | side wall | 8 | 21.60 | 0.15 | 2.00 | 51.84 | | | |
| | base | 8 | 6.90 | 5.40 | 0.15 | 44.71 | | | |
| | Filtrate well | | | | | | | | |
| | side wall | 1 | 3.61 | 0.15 | 2.50 | 1.35 | | | |
| | base slab | 1 | 1.33 | | 0.15 | 0.20 | | | |
| | Effluent well | | | | | | | | |
| | side wall | 1 | 3.61 | 0.15 | 4.00 | 2.17 | | | |
| | base slab | 1 | 1.33 | | 0.15 | 0.20 | | | |
| | Net quantity | | | | | 377.23 | cum | 3424.31 | 1291760 |
| 4 | Supplying, fabricating & placing in position MS or deformed steel bars for all RCC items of work including cost of steel transporting, straightening, cutting, bending, cranking, binding etc. including cost of binding wire charids, laps to fix the reinforc | 1 | 100 | | 377.23 | 37723 | Kg | 36.475 | 1375955 |
| 5 | Supplying & erecting centering for sides & walls including supports & strutting for plain surfaces with all cross bracings using 25 mm thick boards suitable purlined over silver oak (country wood) joists of size 10 x 6.5 cm spaced at about 90 cm centre to | | | | | | | | |
| | Inlet/ stilling chamber | | | | | | | | |
| | side walls all around | 2 | 14.30 | 2.50 | | 71.50 | | | |
| | base slab | 1 | 4.30 | 3.30 | | 14.19 | | | |
| | columns | 4 | | 1.20 | 3.00 | 14.40 | | | |
| | footing | 4 | 4.20 | | 0.50 | 8.40 | | | |
| | baffles | 3 | 6.00 | | 2.00 | 36.00 | | | |
| | screen chamber | | | | | | | | |
| | side walls | 1 | 3.60 | 1.00 | | 3.60 | | | |
| | columns | 1 | 1.20 | | 3.00 | 3.60 | | | |
| | footing | 1 | 4.20 | | 0.50 | 2.10 | | | |
| | grit chamber | | | | | | | | |
| | side walls | 2 | 7.65 | 1.00 | | 15.30 | | | |
| | base slab | 1 | 7.65 | 0.80 | | 6.12 | | | |
| | columns | 2 | 1.20 | | 3.00 | 3.60 | | | |
| | footing | 2 | 4.20 | | 0.50 | 2.10 | | | |
| | Parshall flume | | | | | | | | |
| | side walls | 2 | 1.20 | 1.00 | | 2.40 | | | |
| | base slab | 1 | 1.20 | 0.65 | | 0.78 | | | |
| | columns | 1 | 1.20 | | 3.00 | 3.60 | | | |
| | footing | 1 | 4.20 | | 0.50 | 2.10 | | | |
| | Chamber- inlet to primary clarifier | | | | | | | | |
| | side walls around | 1 | 2.60 | 2.00 | | 5.20 | | | |
| | base slab | 1 | 1.00 | 0.65 | | 0.65 | | | |
| | columns | 1 | 1.20 | | 1.90 | 2.28 | | | |
| | footing | 1 | 4.20 | | 0.50 | 2.10 | | | |
| | Primary clarifier | | | | | | | | |

| Sl. No. | Description of work | No. | L (m) | B (m) | D (m) | Quantity | Unit | RATE | AMOUNT |
|---------|---|-----|-------|-------|-------|----------------|------------|---------------|---------------|
| | side wall | 2 | 28.10 | | 3.00 | 168.60 | | | |
| | effluent channel slab | 1 | 28.73 | 0.15 | | 4.31 | | | |
| | effluent channel side wall | 2 | 30.14 | | 0.40 | 24.12 | | | |
| | aeration tank | | | | | | | | |
| | side walls allround | 2 | 35.60 | | 4.50 | 320.40 | | | |
| | base slab | 1 | 36.40 | | 0.15 | 0.00 | | | |
| | beam for fixing aerators | 2 | 8.80 | 1.25 | | 22.00 | | | |
| | Secondary clarifier | | | | | | | | |
| | side wall | 2 | 30.30 | | 3.00 | 181.80 | | | |
| | effluent channel slab | 1 | 31.56 | 0.15 | | 4.73 | | | |
| | effluent channel side wall | 2 | 32.34 | | 0.40 | 25.87 | | | |
| | Sludge well | | | | | | | | |
| | side wall | 2 | 6.75 | | 2.50 | 33.75 | | | |
| | Digester | | | | | | | | |
| | side wall | 4 | 19.88 | | 9.00 | 715.68 | | | |
| | roof | 2 | 36.42 | | | 72.84 | | | |
| | Drying bed | | | | | | | | |
| | side wall | 16 | 21.60 | | 2.00 | 691.20 | | | |
| | base | 8 | 21.60 | | 0.15 | 25.92 | | | |
| | Filtrate well | | | | | | | | |
| | side wall | 2 | 3.61 | | 2.50 | 18.06 | | | |
| | Effluent well | | | | | | | | |
| | side wall | 2 | 3.61 | | 4.00 | 28.89 | | | |
| | Net quantity | | | | | 2538.19 | sqm | 330.08 | 837804 |
| 6 | Supply and filling filtermedia in drying bed | | | | | | | | |
| | a) Clean river sand of eff size 0.5to0.75 mm and uni. Coeff.not>4 30 cm | 8 | 6 | 4.5 | 0.3 | 64.80 | cum | 580.5 | 37616 |
| | b) HBG jelly 20mm 15cm | 8 | 6 | 4.5 | 0.15 | 32.40 | cum | 713 | 23101 |
| | c) HBG jelly 40mm 15cm | 8 | 6 | 4.5 | 0.2 | 43.20 | cum | 518 | 22378 |
| 7 | Supplying and installation of following machineries including all electrical works and labour charges etc complete as per standard specifications and as directed by Engineer-incharge | | | | | | | | |
| | Machinery | | | | | | | | |
| | Bar screen | 1 | | | | 1 | no. | 5000 | 5000 |
| | scraper motor-reduction gear primary clarifier (Including scraper mechanism) | 1 | | | | 1 | no. | 20000 | 20000 |
| | aeration tank (1 HP) | 4 | | | | 4 | nos. | 25000 | 100000 |
| | scraper motor- secondary clarifier | 1 | | | | 1 | no. | 30000 | 30000 |
| | sludge recirculation pump | 1 | | | | 1 | no. | 10000 | 10000 |
| | sludge well pump | 1 | | | | 1 | no. | 8000 | 8000 |
| | stirrer- digester | 2 | | | | 2 | nos. | 25000 | 50000 |
| | Filtrate pump (1 HP) | 1 | | | | 1 | no. | 10000 | 10000 |
| 8 | Earth work excavation & depositing on bank with an initial lead of 10 m & lift of 2 m for depths in hard stiff clay, stiff black cotton, hard red earth mixed with small sized boulders & hard gravely soil as directed by the Departmental Engineer. (Pipeline | | | | | | | | |
| | Inlet chamber to primary clarifier | 1 | 10 | 0.80 | 1.00 | 8 | | | |

| Sl. No. | Description of work | No. | L (m) | B (m) | D (m) | Quantity | Unit | RATE | AMOUNT |
|---------|---|-----|-------|-------|-------|------------|------------|-------------|---------------|
| | Aeration to secondary clarifier | 1 | 10 | 0.80 | 1.00 | 8 | | | |
| | Primary clarifier to sludge well | 1 | 40 | 0.80 | 1.00 | 32 | | | |
| | Secondary clarifier to sludge well | 1 | 5 | 0.80 | 1.00 | 4 | | | |
| | Secondary clarifier to Aeration | 1 | 45 | 0.80 | 1.00 | 36 | | | |
| | Sludge well to Digester | 1 | 10 | 0.80 | 1.00 | 8 | | | |
| | Digester to sludge drying beds | 1 | 35 | 0.80 | 1.00 | 28 | | | |
| | Sludge drying bed to effluent well | 1 | 25 | 0.80 | 1.00 | 20 | | | |
| | Filtrate well to primary clarifier | 1 | 30 | 0.80 | 1.00 | 24 | | | |
| | Effluent well to sludge drying bed | 1 | 30 | 0.80 | 1.00 | 24 | | | |
| | Effluent well to surplus course | 1 | 25 | 0.90 | 2.00 | 45 | | | |
| | Net quantity | | | | | 237 | cum | 52 | 12324 |
| 9 | Supply of 200 mm diameter of DI pipes (K9 class) as per IS:8329-2000 with sulphate resistance cement with inner lining of high alumina cement as per IS:783 with epoxy coating outside of the spigot portion and poly solution coating inside the socket portio | | | | | | | | |
| | Inlet chamber to primary clarifier | 1 | 12 | | | 12 | | | |
| | Aeration to secondary clarifier | 1 | 18 | | | 18 | | | |
| | Primary clarifier to sludge well | 1 | 40 | | | 40 | | | |
| | Secondary clarifier to sludge well | 1 | 5 | | | 5 | | | |
| | Secondary clarifier to Aeration | 1 | 45 | | | 45 | | | |
| | Sludge well to Digester | 1 | 30 | | | 30 | | | |
| | Digester - sludge drying beds | 1 | 45 | | | 45 | | | |
| | Sludge drying bed to effluent well | 1 | 25 | | | 25 | | | |
| | Effluent well to sludge drying bed | 1 | 30 | | | 30 | | | |
| | Net quantity | | | | | 250 | m | 1520 | 380000 |
| 10 | Supply and laying 200 mm GSW pipe loose jointed underdrains drying beds | 4 | 10 | | | 40 | m | 197 | 7880 |
| 11 | Supply of 300 mm diameter NP 3 class RCC pipes with sulphate resistance cement with inner lining of high alumina cement as per IS:783 with epoxy coating outside of the spigot portion and poly solution coating inside the socket portion, lowering into trenc | 1 | 25 | | | 25 | m | 544.7 | 13618 |
| 12 | Supply and installation of following size of CI Double Flanged Sluice Valves (PN 1.0) with cap and confirming to IS:14846, to site, including flanged tail pieces and other specials as required, loading, unloading, transportation charges & stacking at site | | | | | | | | |
| | sluice valves 200 mm | 4 | | | | 4 | nos. | 12017.7 | 48071 |
| | Sluice valve at Sludge drying beds 100mm | 4 | | | | 4 | nos. | 4615.88 | 18464 |
| 13 | Supplying and fixing of 150 W HPSV street light fixture with single piece, deep drawn aluminium reflector, copper wound ballast, capacitor, junction box, porcelain terminal box, 40 NB class 2 GI pipe for fixture mounting, cleats etc. complete in all respe | 6 | | | | 6 | nos. | 4500 | 27000 |

| Sl. No. | Description of work | No. | L (m) | B (m) | D (m) | Quantity | Unit | RATE | AMOUNT |
|---------|---|-----|-------|-------|-------|----------|------|---------|---------|
| 14 | Providing Internal electrification arrangement including all cost of materials and labour charges etc complete as per standard specifications and as directed by Engineer-incharge | 1 | | | LS | 1 | | 6800.5 | 6801 |
| 15 | Construction of Office cum Electrical room of size of 6 x 3 x 4 m at STP I premises including all cost of materials and labour charges etc complete as per standard specifications and as directed by Engineer-incharge | 1 | | | | 1 | No. | 117622 | 117622 |
| 16 | Providing water supply and sanitary arrangement to Office cum Electrical room including all cost of materials and labour charges etc complete as per standard specifications and as directed by Engineer-incharge | | | | | 1 | NO | 3000 | 3000 |
| 17 | Construction of Compound wall for 180 m length for STP I premises including all cost of materials and labour charges etc complete as per standard specifications and as directed by Engineer-incharge | 1 | | | | 1 | M | 382538 | 382538 |
| | Gate 2.5x2.1m | | | | | 1 | No. | 17443 | 17443 |
| 18 | Construction of WBM road in the STP site including a) supplying and spreading gravel of 100 mm thickness, including labour charges b) providing and laying WBM 75 mm (Grade II) compacted thickness with Grade II metal using 1 m ³ of 63 to 45 mm HBG metal wit | 1 | 50.00 | 3.50 | 0.25 | 43.75 | cum | 1619.55 | 70855 |
| | | | | | | | | | |
| | LEVELLING THE SITE | | | | | | | | 1625 |
| | | | | | | | | | 5092000 |

